

A d d e n d u m

Iowa Department of Transportation
Office of Contracts

Date of Letting: August 16, 2011
Date of Addendum: August 3, 2011

B.O.	Proposal ID	Proposal Work Type	County	Project Number	Addendum
003	52-3715-651-A	Reconstruction - Bridge Widening	Johnson	STP-U-3715(651)--70-52	16aug003.a02

Notice: Only the bid proposal holders receive this addendum and responsibility for notifying any potential subcontractors or suppliers remains with the proposal holder.

Make the following changes to the PROPOSAL SCHEDULE OF PRICES:

Change Line No. 0240 2414-6445100 STRUCTURAL STEEL PEDESTRIAN HAND RAILING from 492.000 LF to 490.000 LF.

Change Line No. 0250 2414-6460000 ORNAMENTAL METAL RAILING from 464.000 LF to 462.000 LF.

If the quantity is not changed on the proposal form, the bid amount will be extended using the unit price times the correct quantity as shown here.

Make the following change to Plan Sheet V.20:

Change the following quantities:
Exterior Handrail from 492 LF to 490 LF
Interior Handrail from 464 LF to 462 LF

Make the following change to Plan Sheet V.21:

Detail 1 – REMOVE the text “AT 75’-9” SPANS” and ADD the text “14 PANELS”
Detail 2 – REMOVE the text “AT 96’-6” SPANS” and ADD the text “13 PANELS”
Detail 3 – REMOVE the text “AT 96’-6” SPANS” and ADD the text “26 PANELS”
Detail 7 – Modify the dimension of the 5” Sleeve to be two 2” overlaps with a 1” gap

Make the following change to Plan Sheet V.22:

ADD the note "ALL EXPOSED ENDS ARE TO HAVE 1/4" CAP PLATES (TYPICAL ALL PANELS)"

ADD the note "3/8" DIAMETER DRAIN HOLE TYPICAL AT BASE OF EACH POST (TYPICAL ALL PANELS)"

Detail 1 – REMOVE the text "2 LOCATIONS" and ADD the text "1 AS SHOWN, 1 MIRROR IMAGE"

Detail 2 – REMOVE the text "2 LOCATIONS" and ADD the text "1 AS SHOWN, 1 MIRROR IMAGE"

Detail 3 – REMOVE the text "2 LOCATIONS" and ADD the text "1 AS SHOWN, 1 MIRROR IMAGE"

Detail 4 – REMOVE the text "2 LOCATIONS" and ADD the text "1 AS SHOWN, 1 MIRROR IMAGE"