

A d d e n d u m

Iowa Department of Transportation
Office of Contracts

Date of Letting: January 18, 2012
Date of Addendum: January 12, 2012

B.O.	Proposal ID	Proposal Work Type	County	Project Number	Addendum
102	10-C010-078	PCC PAVEMENT - GRADE & REPLACE	BUCHANAN	HRRR-C010(78)--5R-10	18JAN102.A01

Notice: Only the bid proposal holders receive this addendum and responsibility for notifying any potential subcontractors or suppliers remains with the proposal holder.

Make the following change to the plan:

Sheet P.01, Add the following note:

Conduits from: *HH1* to *B108*, *HH2* to *B111*, *HH3* to *B102*, *HH4* to *B105* as shown on Sheet P.01 of the plans be reduced to 1.5" thereby providing enough room to fit 2 conduits through the 5" hole in the slip-base plate.