

# A d d e n d u m

Iowa Department of Transportation  
Office of Contracts

Date of Letting: March 20, 2012  
Date of Addendum: March 15, 2012

<b>B.O.</b>	<b>Proposal ID</b>	<b>Proposal Work Type</b>	<b>County</b>	<b>Project Number</b>	<b>Addendum</b>
013	77-1945-738	Bridge Replacement - CCS	Polk	BRM-1945(738)--8N-77	20mar013.a02

---

Notice: Only the bid proposal holders receive this addendum and responsibility for notifying any potential subcontractors or suppliers remains with the proposal holder.

---

Make the following change to the plan:

SHEET V.23 AND V.25:

Replace

ANCHORS SHALL BE IN ACCORDANCE WITH IOWA DOT IM 453.08,  
GUARD RAIL ANCHOR BOLT REQUIREMENTS.

With

ANCHORS SHALL BE IN ACCORDANCE WITH IOWA DOT IM 453.08,  
MISCELLANEOUS REQUIREMENTS, EXCEPT THAT THE ANCHOR  
BOLT GRADE SHALL BE IN ACCORDANCE WITH ASTM F-1554,  
GRADE 105.