

# A d d e n d u m

Iowa Department of Transportation  
Office of Contracts

Date of Letting: March 20, 2012  
Date of Addendum: March 19, 2012

| <b>B.O.</b> | <b>Proposal ID</b> | <b>Proposal Work Type</b>              | <b>County</b> | <b>Project Number</b>  | <b>Addendum</b> |
|-------------|--------------------|--|---------------|------------------------|-----------------|
| 151         | 07-2187-218        | HMA PAVEMENT -<br>GRADE AND<br>REPLACE | BLACK HAWK    | STPN-218-7(218)--2J-07 | 20MAR151.A02    |

---

Notice: Only the bid proposal holders receive this addendum and responsibility for notifying any potential subcontractors or suppliers remains with the proposal holder.

---

Make the following change to plan sheet C.2:

For Item Code 2102-0425070 SPECIAL BACKFILL replace the existing description with the following description:

As per Standard Notation MSA-20 on Sheet C.12, the bedding and full-depth backfill under pavement surfaces shall use special backfill and the contractor will be paid for all trench backfill under pavement areas with Special Backfill, TON. The Special backfill was calculated by length of pipe under pavement surfaces, by trench width, by trench depth.

For Item Code 2402-0425031 GRANULAR BACKFILL replace the existing description with the following description:

To be used as base material for areas under Curb and Gutter, Sidewalks and Driveways. Load tickets shall be provided to engineer.

For Item Code 2599-9999009 WATER MAIN, TRENCHLESS, HDPE, 12 IN., add the following to the reference note:

Certa-Loc PVC is an acceptable alternative to HDPE.