

# A d d e n d u m

Iowa Department of Transportation  
Office of Contracts

Date of Letting: October 20, 2015  
Date of Addendum: October 12, 2015

<b>B.O.</b>	<b>Proposal ID</b>	<b>Proposal Work Type</b>	<b>County</b>	<b>Project Number</b>	<b>Addendum</b>
004	39-0041-016	RCB CULVERT REPLACEMENT - TWIN BOX	GUTHRIE	BRFN-004-1(16)--39-39	20OCT004.A01

---

Notice: Only the bid proposal holders receive this addendum and responsibility for notifying any potential subcontractors or suppliers remains with the proposal holder.

---

Make the following changes to the PROPOSAL SCHEDULE OF PRICES:

Delete Proposal Line No. 0020 2401-6750001 REMOVALS, AS PER PLAN; 1.000 LS

Delete Proposal Line No. 0080 2401-6750001 REMOVALS, AS PER PLAN; 1.000 LS

If the above changes are not made, they will be made as shown here.

Make the following changes to the PLAN:

On Sheet 2:

Add the following note to Item No. 4 and 5 in the Estimate Reference Information:  
“Flowable mortar may be substituted for the porous backfill between precast sections at no additional cost to the state.”

On Sheet 6:

Add the following note to Item No. 4 and 5 in the Estimate Reference Information:  
“Flowable mortar may be substituted for the porous backfill between precast sections at no additional cost to the state.”