

A d d e n d u m

Iowa Department of Transportation
Office of Contracts

Date of Letting: May 17, 2016
Date of Addendum: May 11, 2016

B.O.	Proposal ID	Proposal Work Type	County	Project Number	Addendum
303	22-C022-077	SHOULDER GRADING	CLAYTON	FM-C022(077)--55-22	17MAY303.A01

Make the following changes to the PLAN; ESTIMATE REFERENCE INFORMATION:

SHEET C.1

ITEM NO. 9 2212-5070310 Patches Full-Depth Repair: The existing pavement is a composite section of 6” PCC which has been cracked and seated and with 3” HMA overlay. The full depth patch is proposed to be 4” HMA surfacing with a 6” granular subbase per standard spec 2529.03 C – see bid item 0170. The contractor is to protect the existing pavement and limit patching requirements with pavement surfacing being reviewed by the Engineer following the grading/rock removal work. actual location and quantity of full-depth repair patches to be determine by engineer following review.