

# A d d e n d u m

Iowa Department of Transportation  
Office of Contracts

Date of Letting: February 21, 2017  
Date of Addendum: February 14, 2017

<b>B.O.</b>	<b>Proposal ID</b>	<b>Proposal Work Type</b>	<b>County</b>	<b>Project Number</b>	<b>Addendum</b>
102	09-0036-063	PCC PAVEMENT - GRADE & REPLACE	BREMER	NHSN-003-6(63)--2R-09	21FEB102A03

Make the following changes to the PROPOSAL SCHEDULE OF PRICES:

Change Proposal Line No. 0120:

From: 2301-1003095 Standard or Slip Form Portland Cement Concrete Pavement, QM-C, Class 3 Durability, 9.5 in.

To: 2301-1033095 1033095 Standard or Slip Form Portland Cement Concrete Pavement, Class C, Class 3 Durability, 9.5 in.

Delete Proposal Line No. 0180 2401-6745765 Removal of Light Poles; 102.000 EACH

If the above changes are not made, they will be made as shown here.

Add the following to plan sheet C.4:

Estimate Reference Note for Item #64, 2524-6765010, Perforated Square Steel Tube Posts. Steel posts shall be 2" x 2", 12 Gauge posts for this project.