

A d d e n d u m

Iowa Department of Transportation
Office of Contracts

Date of Letting: July 19, 2011
Date of Addendum: July 12, 2011

B.O.	Proposal ID	Proposal Work Type	County	Project Number	Addendum
109	77-0187-627	PCC Sidewalk / Trail	Polk	STP-E-0187(627)--8V-77	19jul109.a03

Notice: Only the bid proposal holders receive this addendum and responsibility for notifying any potential subcontractors or suppliers remains with the proposal holder.

Make the following changes to the PROPOSAL SCHEDULE OF PRICES:

Change Line No. 0065 2212-5070330 PATCHES BY COUNT (REPAIR) from 1.000 EACH to 2.000 EACH.

If the quantity is not changed on the proposal form, the bid amount will be extended using the unit price times the correct quantity as shown here.

Make the following change to the plan:

SHEET C.01:

Add the following note to the reference notes for the item 2429-0000100, PRE-ENGINEERED STEEL TRUSS, TRAIL BRIDGE.:

Bridge shall be 12' x 30', refer to V sheets for additional details. Bridge deck shall be reinforced concrete, deck design to be provided by bridge manufacturer. Safety railings and rub rail shall be horizontal and meet the requirements of section 2429. A soils report is available upon request contact the IDOT office of contracts."