

A d d e n d u m

Iowa Department of Transportation
Office of Contracts

Date of Letting: January 18, 2012
Date of Addendum: January 13, 2012

B.O.	Proposal ID	Proposal Work Type	County	Project Number	Addendum
010	64-0141-500	Deck Joint Repair	Marshall	MB-014-1(500)102--77-64 MB-030-1(500)182--77-64	18jan010.a02

Notice: Only the bid proposal holders receive this addendum and responsibility for notifying any potential subcontractors or suppliers remains with the proposal holder.

Make the following change to the plan:

SHEET 3:

TABLE OF NEOPRENE GLAND

Delete the Watson-Bowman & Acme Corp. SE-400 Neoprene Gland and replace with the following note:

Shop drawings from the original construction of the extrusion are not available. Prior to ordering the gland the contractor shall field verify the extrusion dimensions in order to supply the correct neoprene gland. Extrusions that may have been used are:

Watson-Bowman Co., Type A-2 Extrusion
ACME, Type A Extrusion
D.S. Brown Co. Type SS Extrusion