Addendum

Iowa Department of Transportation Office of Contracts

Date of Letting: July 17, 2012 Date of Addendum: June 29, 2012

| B.O. | Proposal ID | Proposal Work Type | County | Project Number | Addendum |
|------|-------------|-------------------------|--------|--------------------|--------------|
| 013 | 86-C086-083 | RCB Culvert Replacement | Tama | BROS-C086(81)5F-86 | 17jul013.a01 |
| | | - Single Box | | BROS-C086(83)5F-86 | |

Notice: Only the bid proposal holders receive this addendum and responsibility for notifying any potential subcontractors or suppliers remains with the proposal holder.

Make the following change to the BROS-C086(81)--5F-86 plan:

SHEET 3:

Add the following note:

Proper fill depth for culvert 4'-7'

Make the following change to the BROS-C086(83)--5F-86 plan:

SHEET 3:

Add the following note:

Proper fill depth for culvert 4'-7'