## Addendum

Iowa Department of Transportation
Office of Contracts

Date of Letting: November 20, 2012 Date of Addendum: November 6, 2012

| B.O. | Proposal ID | Proposal Work Type                            | County | Project Number      | Addendum     |
|------|-------------|---|--------|---------------------|--------------|
| 153  | 34-2189-119 | HMA<br>RESURFACING/COLD<br>IN-PLACE RECYCLING | FLOYD  | STP-218-9(119)2C-34 | 20NOV153.A03 |

Notice: Only the bid proposal holders receive this addendum and responsibility for notifying any potential subcontractors or suppliers remains with the proposal holder.

Make the following change to Plan Sheet B.1, Typical MC-1:

Delete note 9:

Suspend C-I-P-R at continuously reinforced PC patches and other PC patches deemed necessary by the engineer.

Make the following change to Plan Sheets C.16 and C.17, Tabulation 102-6C:

Increase the thickness of all CRC patches from 12 inches to 16 inches.