

A d d e n d u m

Iowa Department of Transportation
Office of Contracts

Date of Letting: December 18, 2012
Date of Addendum: December 13, 2012

B.O.	Proposal ID	Proposal Work Type	County	Project Number	Addendum
103	79-C079-047	PCC PAVEMENT WIDENING / PCC RESURFACING	POWESHIEK	STP-S-C079(47)--5E-79	18DEC103.A01

Notice: Only the bid proposal holders receive this addendum and responsibility for notifying any potential subcontractors or suppliers remains with the proposal holder.

Make the following changes to plan sheet number 2, Estimate Reference Information:

For Item Code 2301-1033080 STANDARD OR SLIP FORM PORTLAND CEMENT CONCRETE PAVEMENT, CLASS C, CLASS 3 DURABILITY, 8 IN. delete the following existing note:

PCC Concrete cementitious substitution shall be 35% GGBFS and 15% Class C Flyash between May 1 and September 30. No cement substitution will be allowed October 1 to April 30.

For Item Code 2310-5151040 PORTLAND CEMENT CONCRETE OVERLAY, FURNISH ONLY delete the following existing note:

PCC Concrete cementitious substitution shall be 35% GGBFS and 15% Class C Flyash between May 1 and September 30. No cement substitution will be allowed October 1 to April 30.