

# A d d e n d u m

Iowa Department of Transportation

Date of Letting: April 16, 2013

Office of Contracts

Date of Addendum: April 4, 2013

<b>B.O.</b>	<b>Proposal ID</b>	<b>Proposal Work Type</b>	<b>County</b>	<b>Project Number</b>	<b>Addendum</b>
602	77-2351-508	Bridge Painting	Polk	MBIN-235-1(508)9--0M-77	16apr602.a01

---

Notice: Only the bid proposal holders receive this addendum and responsibility for notifying any potential subcontractors or suppliers remains with the proposal holder.

---

Make the following changes to the PROPOSAL SCHEDULE OF PRICES:

Add Proposal Line No. 0055 2528-8445110 TRAFFIC CONTROL; 1.000 LUMP SUM

If the above changes are not made, they will be made as shown here.

Make the following change to the Plan Attachment Sheets:

Replace SHEET 2 of 3 with the attached SHEET 2 of 3.

**ESTIMATE REFERENCE INFORMATION**

Data listed below is for informational purposes only and shall not constitute a basis for any extra work orders.

**ITEM NO.**

**DESCRIPTION**

All steel to be painted shall be blasted to SP-10. The paint system shall be the Epoxy system. This includes a Zinc-rich Epoxy, an Aluminum Epoxy Mastic intermediate coat, and an Aliphatic Polyurethane topcoat. Topcoat shall be Federal Color Number 20045-Semi Gloss.

BRIDGE # 7708.5A235

This bridge is to be painted. Paint the side and bottom of the exterior top flange, the exterior web, the top of the exterior bottom flange, the sides of the bottom flange, and the bottom of the bottom flange of the left exterior girders. This is the exterior line of girders next to the mainline girders.

The total area of structural steel in the zones designated to be painted is estimated to be 1,700 sq. ft. This estimate is given only for the contractor's information. There will be no additional payment if the actual areas in the zones vary from the estimated amounts shown. The contractor may obtain a copy of the original construction plans for the bridge from the Office of Contracts, Iowa Department of Transportation, 800 Lincoln Way, Ames, IA 50010 (Phone: 515-239-1414).

NOTE: Abrasives shall be steel shot and/or grit, aluminum oxide, or garnet abrasives. Do not use sand or coal slag.