

# A d d e n d u m

Iowa Department of Transportation  
Office of Contracts

Date of Letting: July 16, 2013  
Date of Addendum: June 21, 2013

<b>B.O.</b>	<b>Proposal ID</b>	<b>Proposal Work Type</b>	<b>County</b>	<b>Project Number</b>	<b>Addendum</b>
009	63-C063-112	BRIDGE DECK OVERLAY	MARION	FM-C063(112)--55-63	16JUL009.A01

---

Notice: Only the bid proposal holders receive this addendum and responsibility for notifying any potential subcontractors or suppliers remains with the proposal holder.

---

Make the following change to the Plan Sheet 2 of 5:

PLAN SHEET C.01:

Add the following note to the reference notes for the item 2413-0698066,  
BRIDGE DECK OVERLAY (CLASS O PCC):

Contractor is allowed to use Class HPC-O High Performance Concrete in place of Class O Portland Cement Concrete for the Bridge Deck Overlay. The substitution will be made at no additional cost to this bid item.