

A d d e n d u m

Iowa Department of Transportation
Office of Contracts

Date of Letting: February 18, 2014
Date of Addendum: February 14, 2014

B.O.	Proposal ID	Proposal Work Type	County	Project Number	Addendum
151	07-3807-110	HMA RESURFACING	BLACK HAWK	IMX-380-7(110)68--02-07	18FEB151.A03

Notice: Only the bid proposal holders receive this addendum and responsibility for notifying any potential subcontractors or suppliers remains with the proposal holder.

Add the following to the GENERAL NOTES on SHEET V.1 in the plan:

A minimum of 3,000 psi compressive strength must be obtained before cast on top of the paving notch. Stage II would have the same requirement.