

# A d d e n d u m

Iowa Department of Transportation  
Office of Contracts

Date of Letting: March 18, 2014  
Date of Addendum: February 21, 2014

<b>B.O.</b>	<b>Proposal ID</b>	<b>Proposal Work Type</b>	<b>County</b>	<b>Project Number</b>	<b>Addendum</b>
113	97-0296-186	PCC PAVEMENT - GRADE & REPLACE	WOODBURY	BRFIM-029-6(158)136--05-97 IM-029-6(186)136--13-97 IM-029-6(187)136--13-97 IM-029-6(212)136--13-97 STP-S-C097(121)--5E-97	18MAR113.A01

---

Notice: Only the bid proposal holders receive this addendum and responsibility for notifying any potential subcontractors or suppliers remains with the proposal holder.

---

Make the following changes to the PLAN for Project No. BRFIM-029-6(158)136--05-97:

Pier 1 and Pier 3 piles shall all be driven vertically. Indications of battered piles for Pier 1 and Pier 3, as shown in Section B-B and Plan of Footing details, on Sheets 7 and 11 are to be disregarded. In addition, notes on these sheets referencing battered piles are to be disregarded.

A plan revision will be issued at a later time clarifying these details.