

A d d e n d u m

Iowa Department of Transportation
Office of Contracts

Date of Letting: April 15, 2014
Date of Addendum: April 11, 2014

B.O.	Proposal ID	Proposal Work Type	County	Project Number	Addendum
004	21-0182-108	BRIDGE REPLACEMENT - CCS	CLAY	BRFN-018-2(108)--39-21	15APR004.A01

Notice: Only the bid proposal holders receive this addendum and responsibility for notifying any potential subcontractors or suppliers remains with the proposal holder.

Make the following change to plan sheet C.2:

Item No. 16, 2502-8212204, Subdrain, Perforated Plastic Pipe, 4 in. dia.;
Incidental Porous Backfill quantity change 222.8 CY to 133.8 CY.

Make the following change to plan Sheet C.7:

Replace TAB 104-9 10-15-13 LONGITUDINAL SUBDRAIN SHOULDER AND BACKSLOPE
with the attached tab.

LONGITUDINAL SUBDRAIN SHOULDER AND BACKSLOPE

Refer to Soils Sheets

① Refer to EW-203, EW-204, or EW-211.
*Not a bid item

Line No.	Road or Lane Ident.	Location		Longitudinal Subdrain (RF-19C)				Subdrain Outlet				Class "A" Crushed Stone CY	Remarks			
		Station to Station	Side	Shoulder		Backslope		Bridge Berms ①	RF-19C, RF-19E, or RF-19F		Porous Backfill CY					
				Depth	Station	Length	Size		Length	Size				Station	Standard Road Plan and Type	
		IN	FT	IN	FT	IN	FT	IN	FT	IN	FT	IN	FT			
1	US 18	31+85.00	34+19.00	LT	42.0	4.0	274.0					31+85.00	6.0	RF-19E	25.4	0.2
2	US 18	31+85.00	34+19.00	LT	42.0	4.0	274.0					34+19.00	6.0	RF-19E	25.4	0.2
3	US 18	37+07.00	41+15.00	RT	42.0	4.0	448.0					31+85.00	6.0	RF-19E	25.4	0.2
4	US 18	37+07.00	41+15.00	RT	42.0	4.0	448.0					34+19.00	6.0	RF-19E	41.5	0.2
												37+07.00	6.0	RF-19E	41.5	0.2
												41+15.00	6.0	RF-19E	41.5	0.2