

A d d e n d u m

Iowa Department of Transportation
Office of Contracts

Date of Letting: October 27, 2015
Date of Addendum: October 23, 2015

| B.O. | Proposal ID | Proposal Work Type | County | Project Number | Addendum |
|-------------|--------------------|---------------------------|---------------|--|-----------------|
| 001 | 78-0801-372 | BRIDGE NEW - STEEL GIRDER | POTTAWATTAMIE | IM-NHS-080-1(372)4--03-78 IM-NHS-080-1(373)4--03-78 IM-NHS-080-1(374)4--03-78 IM-NHS-080-1(375)4--03-78 IM-NHS-080-1(376)4--03-78 IM-NHS-080-1(377)4--03-78 IM-NHS-080-1(420)4--03-78 IM-NHS-080-1(462)4--03-78 | 27OCT001.A04 |

Make the following changes to ADDENDUM 27OCT001.A03

IM-NHS-80-1(372)4—03-78 Add note to sheet plan sheet 156

IF GUIDE BARS ARE USED TO RESIST UPLIFT FORCE PROVIDED ON THE PLANS FOR "MD" TYPE BEARINGS, THE TRANSVERSE MOVEMENT SHALL BE ½ INCH IN EACH DIRECTION.