
REPORT ON THE IMPACTS AND COSTS OF THE IOWA LOW-INCOME WEATHERIZATION PROGRAM -Calendar Year 2017

September 28, 2018

Iowa Local Weatherization Agencies



Voice: 608-845-6551

REPORT ON THE IMPACTS AND COSTS OF IOWA'S LOW-INCOME WEATHERIZATION PROGRAM Calendar Year 2017

September 28, 2018

Prepared for the

Iowa Statewide Low-Income Collaborative

by

Dalhoff Associates, LLC 533 Marshall Circle Verona, WI 53593

608-845-6551

email: Greg.Dalhoff@DalhoffAssociates.com

TABLE OF CONTENTS

EXECUTIVE SUMMARY	i
Program Costs and Impacts	i
Utility Expenditures and Impacts	ii
Fuel Consumption Analysis Results	iii
Changes in Program Delivery and Reporting	iii
1. SUMMARY OF PROGRAM IMPACTS AND EXPENDITURES	1
Program Savings and Expenditures	1
Client Energy Bill Savings by Fuel Type and End-Use	4
Utility Savings and Expenditures	8
Expenditures and Savings by Agency and Measure	13
Savings of Water Heater, Lighting, and Refrigeration Measures	21
Trends in the Installation Rates of Lighting, Refrigeration, and Heating System Replacem	ients22
Average Costs of Major Measures by Agency	25
2. FUEL CONSUMPTION ANALYSIS	1
Study Sample and Methodology	1
Model Selection	2
Screens for Poor Model Diagnostics	3
Screens for Poor Model Reliability	3
Attrition Analysis – Gas	4
Attrition Rates	4
Outliers	5
Gas Impact analysis	5

	Savings with Respect to Pre-Weatherization Usage	8
	Trends in Baseline Consumption and Energy Savings	. 10
At	ttrition Analysis – Electricity	11
	Outliers	.12
Ele	ectricity Impact analysis	12
Co	omparison of Sample and Overall Program Populations	14
3. D	DETAILED SPENDING AND IMPACT PROFILES BY FUNDING ENTITY	1
4. D	DETAILED SPENDING AND IMPACT PROFILES BY AGENCY	1
5. D	DETAILED SPENDING AND IMPACT PROFILES BY AGENCY FOR UTILITY EXPENDITURES	1
Арр	endix A Client Characteristics	1
Δnn	pendix B – Figure Data	1

EXECUTIVE SUMMARY

This report summarizes the state and utility low-income weatherization program activity for low-income dwellings weatherized to completion in Iowa during calendar year 2017 through the Iowa Weatherization Assistance Program. The report includes state, utility, and agency summaries of spending and impacts by measure, end-use, and fuel type. The base data consists of statewide program tracking databases of spending and measure installations maintained by the Iowa Division of Community Action Agencies. Fuel consumption histories were provided by the three co-funding utilities, including by Black Hills Energy, Interstate Power and Light Company, and MidAmerican Energy.

We estimated energy and coincident demand impacts for the program participants by using algorithms developed as part of the study of the calendar year 2007 program¹. The estimated impacts were adjusted using billing analysis of the program clients.

PROGRAM COSTS AND IMPACTS

The WAP program spent \$16,634,427 for materials, labor, and support while installing measures in 1,255 dwellings during calendar year (CY) 2017. Funding decreased by16.4% from the prior year. Federal and state funding accounted for 65.4% of overall expenditures while utilities funded the remaining 34.6%.

The program expenditures for materials, labor, and support averaged \$13,255 in 2017 compared to \$13,512 in 2016 (a 1.9% decrease). The major measures installed by the program in 2017 are essentially unchanged from the 2016 program.

First-year savings totaled 252,720 therms; 986,990 kWh electricity; 28,670 gallons of propane; and 1,932 gallons of fuel oil. First-year peak demand savings totaled 2,616 therms, 278 kW summer demand, and 273 kW winter demand.

Electricity savings averaged 786 kWh for 1,255 dwellings. The program saved an average of 240 therms of natural gas for 1,055 dwellings with gas impacts. In addition, the program delivered first-year savings of 276 gallons of propane in 104 dwellings with propane impacts, and 138 gallons of fuel oil in 14 dwellings with fuel oil impacts.

¹ Dalhoff Associates, LLC. <u>Report on the Impacts and Costs of the Iowa Low-Income Weatherization Program – Calendar Year 2007, October 15, 2008.</u>

First-year client energy cost savings totaled \$363,629, averaging \$290 per housing unit.

	Electi	ricity (kWh and	lkW)	Natura	al Gas (the	erms)	Propane (gals)	Fuel Oil (gals)
	Overall	DCAA	Utility	Overall	DCAA	Utility	DCAA	DCAA
Energy	986,990	324,980	662,010	252,720	75,400	177,320	28,670	1,932
Summer Demand	278	88	190	NA	NA	NA	NA	NA
Winter Demand	273	101	172	2,616	783	1,833	NA	NA

Average Impacts¹ per Dwelling (for those receiving measures with a given fuel type)

	E	Electricity (kWh)			Natural Gas (therms)			Fuel Oil (gals)
	Overall	DCAA	Utility	Overall	DCAA	Utility	DCAA	DCAA
Energy	786	261	717	240	72	205	276	138
Summer Demand	0.222	0.071	0.206	NA	NA	NA	NA	NA
Winter Demand	0.218	0.081	0.186	2.5	0.7	2.1	NA	NA

Expenditures and First Year Client Fuel Bill Savings

Tatala	On some II	DCAA	1 14:1:4.	A	0	DCAA	1 14:11:4
Totals	Overall	DCAA	Utility	Averages	Overali	DCAA	Utility
Expenditures ²	\$16,634,427	\$10,884,395	\$5,750,031	Expenditures	\$13,255	\$8,673	\$5,461
Client Fuel Savings	\$363,629	\$144,614	\$219,015	Client Fuel Savings	\$290	\$115	\$208

¹ Average impacts are for dwellings that received the measures, and so the averages of the Utility and DCAA will not total to the statewide average

UTILITY EXPENDITURES AND IMPACTS

The three major investor-owned utilities that provide gas and electricity in Iowa, Alliant-IPL, MidAmerican Energy, and Black Hills Energy, contributed \$5,750,031 for weatherization measures, accounting for 34.6% of total program expenditures. The utility expenditures averaged \$5,461 for the 1,053 dwellings that received utility-funded measures.

Utility-funded measures saved a total of 662,010 kWh, averaging of 717 kWh of electricity for the 923 dwellings with utility-funded electricity measures. Utility funded measures also saved a total of 177,320 therms, averaging 205 therms of natural gas for the 865 dwellings with utility-funded natural gas measures. Utility-funded measures reduced peak electricity demand by 190 kW in the summer and 172 kW in the winter, and provided 1,833 peak-day therms of gas savings. Utility-funded measures accounted for 70.2% of program electricity savings and 66.5% of program gas savings.

Utility-funded measures yielded first-year client bill savings of \$219,015, averaging \$208 per dwelling that received utility-funded efficiency measures. Electricity bill savings averaged \$82 per household for utility-funded electricity measures. Gas bill savings averaged \$166 for those with utility-funded gas measures.

² Measure expenditures, exclues utility admin expenses

FUEL CONSUMPTION ANALYSIS RESULTS

The natural gas savings were first estimated using the measure-specific revised algorithms developed for the CY 2007 program, and then adjusted based upon a billing analysis of the weatherization clients. The factors were applied to the estimated electricity, natural gas, propane, and fuel oil heating measures, and to natural gas and propane water heater measures. Along with providing better assessments of agency-level impacts, this procedure also provides a check on the accuracy of the algorithms used to estimate savings.

Natural gas savings for single family site-built dwellings averaged 247 therms \pm 17 at 90% confidence. This represents a 24.5% savings \pm 1.3% at 90% confidence for natural gas measures. Mobile home savings averaged 204 therms \pm 59 at 90% confidence, equating to a 21.7% savings \pm 5.1%.

Electricity savings were initially estimated using algorithms developed from savings of the 2005 and 2006 program. These estimates were adjusted based upon a billing analysis of electricity impacts of the 2012 and 2013 programs. The billing analysis for the CY 2017 program found that savings averaged 2,979 kWh \pm 1,592 for dwellings with electric main heat, and 577 kWh \pm 211 for dwellings heated with other fuels.

CHANGES IN PROGRAM DELIVERY AND REPORTING

The program began installing LEDs in 2017. Other than that, there were no significant changes in measures delivered for the CY 2017 program, as compared to the previous year.

Organization of the Report

Section 1, Summary of Program Impacts and Expenditures, provides the overall findings of the study, and relates these to prior year results. In addition, it provides broad summaries of impacts and costs for the agencies.

Section 2, Fuel Consumption Analysis and Assessment of Agency-Level Savings Adjustment Factors, details the methodology and results of the fuel consumption analysis. A standard comparison-adjusted pre/post weather-normalization methodology was used to assess impacts. A section was added at the end, entitled Comparison of Sample and Overall Program Populations.

Section 3, Detailed Spending and Impact Profiles by Funding Entity provides detailed result tables for the overall program, state funding, and for each of the three funding utilities. These tables include counts of installations and totals and average energy savings, demand impacts, and program expenditures by measure.

Section 4, Detailed Spending and Impact Profiles by Agency provides tables similar to those in Section 4 for each weatherization agency, for all measures installed.

Section 5, Detailed Spending and Impact Profiles by Agency for Utility Expenditures provides similar detail by agency, but is limited to measures funded by the utilities.

Appendix A provides a characterization of households and dwellings weatherized during 2017.

Appendix B provides tabular data of selected charts in Section 1 of the report.

iv Dalhoff Associates, LLC

1. SUMMARY OF PROGRAM IMPACTS AND EXPENDITURES

This section begins with impacts and expenditures for the overall program, followed by results attributed to utility funding. Various agency-level results and measure-specific results are presented in the final part.

PROGRAM SAVINGS AND EXPENDITURES

A total of 1,255 dwelling units were weatherized to completion during calendar year (CY) 2017, compared to 1,473 in 2016. First-year savings totaled 252,720 therms; 986,990 kWh electricity; 28,670 gallons of propane; and 1,932 gallons of fuel oil. First-year peak demand savings totaled 2,616 peak-day therms, 278 kW summer demand, and 273 kW winter demand.

First year natural gas savings are shown for the past ten years, by major measure groups in Figure 1.1 (historical data is listed in Appendix B as Fig 1.1).




Figure 1.1 First Year Energy Savings (therms) – Program

Taken together, insulation, infiltration reduction, and heating system replacement work accounted for 91% of gas savings (Table 1.1). Note that the portion of infiltration reduction savings (7% of gas savings) shown here is attributed to weather-stripping and leak sealing -- the bulk of air leakage savings are allocated to dense packed wall and cavity insulation and are included in insulation savings shown for those measures.

Table 1.1 Gas Measure Savings by Major Measure Category

Measure Group	Savings (therms)	Percentage
Heating System Work	89,404	35.4%
Infiltration Reduction	16,743	6.6%
Insulation	123,312	48.8%
Light/Water Heat/Other Utility	3,874	1.5%
Water Heater Replacement	23,656	9.4%
Whole House Ventilation	-4,269	-1.7%

Electricity savings totaled 986,990 kWh for the program overall (Figure 1.2).




Figure 1.2 First Year Energy Savings (kWh) – Program

Insulation measures were credited with 48% of electricity savings (includes cooling savings and heating savings for homes with electric heat). Lighting, electric water heating measures, and refrigerator and freezer replacements and removals accounted for 39% (Table 1.2, historical data is listed in Appendix B as Fig 1.2).

1.2 Dalhoff Associates, LLC

Table 1.2 Electricity Savings by Major Measure Category

Measure Group	Savings (kWh)	Percentage
Heating System Work	159,209	16.1%
Infiltration Reduction	42,306	4.3%
Insulation	470,351	47.7%
Light/Water Heat/Other Utility	369,048	37.4%
Water Heater Replacement	15,857	1.6%
Whole House Ventilation	-70,405	-7.1%

Program expenditures for materials, labor, and support totaled \$16,634,427, decreasing by 16.4 percent from \$19,903,775 spent in 2016 (see Figure 1.3).




Figure 1.3 Overall Program Expenditures

Expenditures by major measure groups are shown in Table 1.3 (historical data is listed in Appendix B as Fig 1.3). Program support, which provides for agency overhead and administration, accounts for 27.5% of expenditures. Spending for efficiency measures, including infiltration reduction, insulation, lighting and water heater efficiency measures, accounts for 28.4% of expenditures. Heating system work (replacements, repairs, and tune-ups) and water heater replacements are installed for efficiency and/or health and safety; taken together these account for 24.3% of expenditures. The remainder of costs including repairs, whole house ventilation, and health and safety measures which together total 19.8%.

Table 1.3 Expenditures by Major Measure Category

Measure Group	Expenditures	Percentage
Heating System Work	\$2,747,745	16.5%
Infiltration Reduction	\$1,045,485	6.3%
Insulation	\$3,440,858	20.7%
Light/Water Heat/Other Utility	\$241,252	1.5%
Other	\$1,558,300	9.4%
Repair	\$828,300	5.0%
Support	\$4,570,198	27.5%
Water Heater Replacement	\$1,289,234	7.8%
Whole House Ventilation	\$898,996	5.4%

The nominal average household expenditures for all dwellings weatherized in 2017 decreased by 2.1% to \$13,255 (Figure 1.4, historical data is listed in Appendix B as Fig 1.4).




Figure 1.4 Average Program Expenditures per Housing Unit

CLIENT ENERGY BILL SAVINGS BY FUEL TYPE AND END-USE

Fuel prices were taken from the Department of Energy's Energy Information Agency (EIA) state monthly average prices for electricity and natural gas, and seasonal fuel costs for propane and fuel oil. The

1.4 Dalhoff Associates, LLC

savings for each measure are allocated by month so that the estimated bill savings reflect the seasonal fluctuations in fuel prices. State taxes are included and electricity and gas prices are adjusted to include only the variable cost of an additional kWh or therm -- the fixed portion of the bills for customer charges are removed (Figure 1.5). Electricity prices increased by 2.3% from 2016, gas prices increased by 4.2%, fuel oil prices increased by 21% (though remaining below 2013 - 2014 prices), and propane prices increased by 26% (though still below 2013 - 2015 prices).




Figure 1.5 Average Fuel Cost per MBtu (Nominal Dollars)

The nominal first year client energy bill savings totaled \$369,629 (Figure 1.6, historical data is listed in Appendix B as Fig 1.6).




Figure 1.6 First Year Client Fuel Cost Savings (Nominal Dollars)

Insulation, infiltration reduction, and heating system work accounted for 84% of client bill savings (Table 1.4, historical data is listed in Appendix B as Fig 1.6). Lighting, water heating measures, and refrigeration measures accounted for 13%.

Table 1.4 First Year Client Fuel Cost Savings (Nominal Dollars)

Measure Group	Fuel Bill Savings	Percentage
Heating System Work	\$107,911	29.7%
Infiltration Reduction	\$21,220	5.8%
Insulation	\$174,531	48.0%
Light/Water Heat/Other Utility	\$46,038	12.7%
Water Heater Replacement	\$27,027	7.4%
Whole House Ventilation	-\$13,169	-3.6%

First-year client fuel bill savings averaged \$290 (Figure 1.7), increasing from \$262 in 2016.




Figure 1.7 Average Annual Client Fuel Bill Savings per Housing Unit

Natural gas savings provided 56% of client bill savings, electricity accounted for 31%, propane accounted for 12%, and fuel oil provided 1%.

Approximately 45% of client bill savings are attributable to the heating impacts of shell measures (insulation and infiltration reduction), and 25% was due to heating system work. Taken together, heating impacts from shell improvements and heating system measures accounted for 71% of total client bill savings. Cooling savings accounted for another 9% and lighting, refrigeration, and water heater measures accounted for 14%.

1.6 Dalhoff Associates, LLC

Table 1.5 provides a breakdown of first year energy and bill savings, and expenditures by housing type and main heat fuel. Expenditures for site built single family units averaged over \$13,000 for gas, propane, and fuel oil heated units, and had total savings of \$268 for gas heated units, \$514 for propane heated units, and \$462 for fuel oil heated units. Costs for electrically-heated site built homes were \$11,088 with bill savings of \$378.

Expenditures for gas-heated mobile homes averaged \$12,453 and saved \$219 per unit. Propane-heated mobile homes averaged \$9,509 in expenditures yielding \$342 in savings. Fuel-oil heated mobile home expenditures averaged \$12,844 and average \$320 in savings (only 2 cases). Expenditures were \$9,396 for electrically-heated mobile homes (only 3 cases) and saved \$79.

Expenditures for multi-family units heated with gas averaged \$10,319 and had first-year client bill savings of \$212. A single propane multi-family dwelling cost \$13,355 to weatherize and had \$662 in savings. Electrically-heated multi-family unit spending averaged \$4,182 and saved \$140 for nine units.

Table 1.5 First Year Energy and Bill Savings, and Expenditures by Housing Type and Main Heat Fuel

		Main Heat		Electricity		
	Number of	Savings	Bill Savings	Savings	Bill Savings	Expenditures
	Units	(therms, gals)	(\$)	(kWh)	(\$)	
Site Built Single Family						
Gas	943	244	\$196	625	\$72	\$13,685
Propane	93	283	\$426	764	\$88	\$13,747
Fuel Oil	12	144	\$360	884	\$102	\$13,187
Electricity	68	-	-	3,530	\$378	\$11,088
Mobile Home						
Gas	75	204	\$165	476	\$54	\$12,453
Propane	10	195	\$294	422	\$48	\$9,509
Fuel Oil	2	100	\$250	613	\$70	\$12,884
Electricity	3	-	-	748	\$79	\$9,396
Multi-Family						
Gas	37	193	\$155	498	\$57	\$10,319
Propane	1	388	\$586	677	\$76	\$13,355
Fuel Oil	-	-	-	-	-	-
Electricity	9	-	-	1,321	\$140	\$4,182

UTILITY SAVINGS AND EXPENDITURES

The utilities funded measures in 1,053 dwellings, with first year savings totaling 177,320 therms and 662,010 kWh. These measures reached 84% of all units weatherized by the program, and accounted for 70% of gas savings and 67% of electricity savings.

Figure 1.8 provides a ten year history of gas savings attained by utility-funded measures (Figure 1.8, historical data in Appendix B listed as Fig 1.8).




Figure 1.8 First Year Energy Savings (therms) – Utility only

Utility expenditures on gas measures were mostly due to insulation (53% of expenditures) and heating system work (33%). The heating system work was almost entirely for replacements, all of which were specified as replacements for efficiency (Table 1.6).

Table 1.6 First Year Energy Savings (therms) by Measure Group – Utility only

Measure Group	Savings (therms)	Percentage
Heating System Work	58,964	33.3%
Infiltration Reduction	5,275	3.0%
Insulation	93,879	52.9%
Light/Water Heat/Other Utility	2,838	1.6%
Water Heater Replacement	16,361	9.2%

.

1.8 Dalhoff Associates, LLC

The ten year history of electricity measure savings are shown in Figure 1.9, with first year savings totaling 662,010 kWh in 2017 (Figure 1.9 historical data in Appendix B listed as Fig 1.9).




Figure 1.9 First Year Energy Savings (kWh) - Utility only

The electricity savings attributed to insulation include cooling savings and heating savings in units with electric main heat; these accounted for 49% of electricity savings. Another 38% of electricity savings were due to lighting, refrigerator replacements or removals, electric water heater measures (Table 1.7).

Table 1.7 First Year Energy Savings (kWh) by Measure Group – Utility only

Measure Group	Savings (kWh)	Percentage
Heating System Work	66,476	10.0%
Infiltration Reduction	12,372	1.9%
Insulation	321,895	48.7%
Light/Water Heat/Other Utility	251,166	38.0%
Water Heater Replacement	9,580	1.4%




Figure 1.10 Utility Expenditures

The utilities spent \$5,750,031 for program measures, labor, and support in 2017, 6.3% less than in 2016 (Figure 1.10, Table 1.8, historical data in Appendix B listed as Fig 1.10). Utility expenditures accounted for 34.6% of the total low-income program expenditures.

Table 1.8 Expenditures by Measure Group – Utility only

Measure Group	Expenditures	Percentage
Heating System Work	\$1,379,543	24.0%
Infiltration Reduction	\$273,962	4.8%
Insulation	\$2,190,461	38.1%
Light/Water Heat/Other Utility	\$160,696	2.8%
Other	\$176,289	3.1%
Repair	\$168,145	2.9%
Support	\$585,371	10.2%
Water Heater Replacement	\$815,113	14.2%

In addition, the utilities spent \$260,580 on program administration. Utility expenditures totaled \$6,010,611 including spending on program measures, labor, support, and administration.

1.10 Dalhoff Associates, LLC




Figure 1.11 Average Utility Spending on Efficiency Measures (excludes Support and Administration), and Percentage of Homes Receiving Utility-Funded Measures with Impacts

Figure 1.11 provides the average utility funding for efficiency measures and percentages of dwellings with utility funding for the past five years. The utilities installed measures in 84% of units, increasing from 76-77% for the previous three years.

Table 1.9 provides details of utility expenditures and the percentage of units weatherized by the program for each utility.

Table 1.9 Utility Expenditures for Measures, Labor, and Support, and Counts of Units with Impacts

	Total Expenditures			Counts of Dwellings With Energy Impacts				
	Excluding With Program		Electric					
Utility	Pro	gram Support	pport	Impacts	Pct of Prg	Gas Impacts	Pct of Prg	
Alliant IPL	\$	2,498,500	\$	2,771,500	548	43.7%	379	35.9%
Black Hills Corp	\$	477,300	\$	527,200			113	10.7%
MidAmerican	\$	2,188,800	\$	2,451,300	376	30.0%	373	35.4%
Total Utilities	\$	5,164,700	\$	5,750,000	923	73.5%	865	82.0%

The savings and client bill savings for utility-funded measures are summarized by utility in Table 1.10.

Table 1.10 First Year Fuel and Client Bill Savings Impacts from Utility-Funded Measures

			•		•			
			Summer		Winter		First Year	
	First Yr Fuel		Demand		Demand		Fuel Cost	
Utility	Savings	Pct of Prg	Savings	Pct of Prg	Savings	Pct of Prg	Savings	Pct of Prg
Electricity	(kWh)		(kW)		(kW)			
Alliant IPL	380,120	38.5%	110	39.9%	95	34.9%	\$ 43,490	38.8%
MidAmerican	280,080	28.4%	80	28.3%	76	27.9%	\$ 31,920	28.5%
Total Electric Utilities	662,010	67.1%	190	68.2%	172	62.9%	\$ 75,620	67.5%
					Peak Day			
Gas	Therms				Therms			
Alliant IPL	79,880	31.6%			826	31.6%	\$ 64,490	31.7%
Black Hills Corp	19,280	7.6%			198	7.6%	\$ 15,590	7.7%
MidAmerican	78,130	30.9%			809	30.9%	\$ 63,280	31.1%
Total Gas Utilities	177,320	70.2%			1,833	70.1%	\$ 143,400	70.5%

Utility-funded measures yielded first-year client bill savings of \$219,015, averaging \$208 per dwelling that received utility-funded measures. Electricity bill savings from utility-funded measures averaged \$82 per household for utility-funded electricity measures. Gas bill savings from utility-funded measures averaged \$166 for households with utility-funded gas measures.

Table 1.11 provides the cost of energy savings for utility-funded measures with energy impacts. The cost of conserved energy over all housing types ranged from \$21.47 to \$22.78 per therm (first year savings) and \$1.22-\$1.23 per kWh.

Table 1.11 Costs of First-Year Energy Savings from Utility-Funded Measures

	Cost of		Cost of	
	Gas	Number of	Elec	Number of
	Savings	Units	Savings	Units
Alliant-IPL				
Overall	\$22.78	380	\$1.22	549
Site-Built	\$22.90	358	\$1.24	489
Mobile Home	\$16.45	13	\$1.32	38
Multi-family	\$22.77	9	\$0.75	22
Black Hills Corp				
Overall	\$22.59	113	-	
Site-Built	\$22.78	102	-	
Mobile Home	\$24.58	6	-	
Multi-family	\$16.46	5	-	
MidAmerican				
Overall	\$21.47	373	\$1.23	376
Site-Built	\$21.57	323	\$1.23	338
Mobile Home	\$21.22	38	\$1.46	26
Multi-family	\$18.21	12	\$0.85	12

1.12 Dalhoff Associates, LLC

Table 1.12 provides the percentages of total expenditures for measures that were funded by the utilities, and demonstrates the high funding percentage provided by the utilities for efficiency measures. The utilities funded the majority of insulation, heating system and water heater replacements, water heater efficiency measures, lighting and refrigerator replacements, programmable thermostats, and water heater ventilation.

Table 1.12 Utility Funding Percentages by Measure

	Expenditures					
			Utility			
Measure	Total	Utility	Percentage			
Wall Insulation	\$1,350,475	\$926,199	68.6%			
Attic Insulation	\$1,238,859	\$850,724	68.7%			
Kneewall Insulation	\$128,698	\$90,462	70.3%			
Floor/Crawlspace Insulation	\$326,441	\$209,731	64.2%			
Bandjoist Insulation	\$101,910	\$65,336	64.1%			
Infiltration Reduction	\$1,045,485	\$273,962	26.2%			
High Efficiency Htg Sys Repl.	\$2,168,346	\$1,319,903	60.9%			
Electric Htg Sy/Ht Pump Repl.	\$143,840	\$31,788	22.1%			
Pipe Wrap	\$16,288	\$11,357	69.7%			
Faucet Aerator	\$1,901	\$1,303	68.5%			
Shower Head	\$1,741	\$1,284	73.7%			
Water Heater Replacement - Hi Eff	\$1,289,234	\$815,113	63.2%			
Lighting	\$47,166	\$33,294	70.6%			
Exchange Refrigerator	\$149,737	\$103,411	69.1%			
Exchange Freezer	\$24,784	\$10,458	42.2%			
Repairs	\$828,300	\$168,145	20.3%			
Programmable Thermostat	\$8,017	\$8,017	100.0%			
Htg Sys Tune/Clean	\$75,601	\$19,836	26.2%			
Htg Sys Ventilation	\$155,412	\$85,593	55.1%			
Water Heater Ventilation	\$100,119	\$66,666	66.6%			
Support	\$4,570,198	\$585,371	12.8%			

Section 3 of this report, Detailed Spending and Impact Profiles by Funding Entity provides detailed result tables for the overall program, state funding, and for each of the three funding utilities. Those tables include counts of installations and totals and average energy savings, demand impacts, and program expenditures by measure.

EXPENDITURES AND SAVINGS BY AGENCY AND MEASURE

Figure 1.12 shows the average annual energy cost savings by agency. The series are arranged from left to right in the chart according to left to right and top to bottom and in the legend, e.g., Bldg Shell Cooling, then Bldg Shell Heating, then Heating system, etc.

Savings attained by each agency were adjusted according to results of the natural gas and electricity fuel consumption analyses, detailed in Section 2 of this report. The estimated impacts for propane and fuel oil were adjusted using the same factors as those used for natural gas.

Bear in mind that various factors affect the values shown in this chart, factors beyond quality or intensity of weatherization treatment (an example is climate variations within the state). Consequently, these results should not be used as a basis for comparing the quality, attention to detail, dedication, or other factors of agency performance.

The wide variation in results across agencies is typical of what we've observed in past years.

The statewide average client bill savings was \$290 per dwelling. The average first-year client bill savings widely varied across agencies, from a low of \$147 per dwelling for Matura to a high of \$388 for North lowa and \$376 for CA Southeast lowa.




Figure 1.12 Average Annual Fuel Bill Savings per Housing Unit by Agency

1.14 Dalhoff Associates, LLC

Figure 1.13 shows the average expenditures for all households with impacts, ranging from a low of \$7,882 for Northeast Iowa to \$16,563 for CA Southeast IA. The statewide average expenditure was \$13,255 per dwelling unit.




Figure 1.13 Average Expenditures per Housing Unit by Agency

The average installation rates, costs, and savings for energy efficiency and heating and water heating system replacement measures for calendar year programs 2015-2017 are shown in Figures 1.14a and 1.14b.

The installation rates of nearly all insulation measures and infiltration reduction remained about the same over the past three years (see Figure 1.14a, left chart).

Condensing heating system replacement rates declined by about 10% from 2016. Non-condensing heating system replacements increased to about 8% over the past year.

The installation rates of water heater efficiency measures decreased with the exception of pipe insulation. The rates of high-efficiency water heater replacements also decreased, down to 66% from 69% in 2016. Refrigerator and freezer replacement rates slightly to 16% and 4.2% respectively.

Figure 1.14a, right chart, shows that the average measure costs. Insulation costs fell in the same range as the prior two years. Condensing heating system costs have decreased for the past two years. Costs for non-condensing heating systems declined considerably, to \$1,830 in 2017. The cost of high efficiency water heater replacements was essentially unchanged (no standard efficiency water heaters were installed in 2017).

The average first-year energy gas and electricity savings for each major measure is shown in Figures 1.14b.

The average natural gas savings by measure declined over the past three years for wall insulation and ceiling/attic insulation. Floor/crawlspace savings increased slightly.

Gas savings for condensing heating system were similar to 2016 at 118 therms. Non-condensing heating system savings increased considerably in 2017. These installations occur in situations where condensing heating systems cannot be installed due to ventilation issues, and generally for atypical situations.

The average electricity savings from all insulation measures increased: there were only 33 homes with electric heat. These differences are driven in part by year-to-year variation in housing stock for the few housing units that use electric main heat.

Savings from refrigerator and freezer replacements were higher in 2017.

1.16 Dalhoff Associates, LLC




Figure 1.14a Average Installation Rates and Measure Costs of Efficiency Measures, Heating System and Water Heating Replacements




Figure 1.14b Average Gas and Electricity Savings of Efficiency Measures, Heating System and Water Heating Replacements

1.18 Dalhoff Associates, LLC

Tables 1.13 and 1.14 provide tabular data corresponding to data shown in Figure 1.14a&b and but over a five year period. Table 1.13 provides a listing of the percentage of households receiving measures. Small percentage changes from the previous year are to be expected, and typically correct for lower or higher installation rates of the prior year. The year over year (recent year) change tends to be greatest for measures with very low installation rates and/or savings which are not indicative of major changes in the installation protocols for these measures or program impacts.

Table 1.13 Installation Rates of Measures

Measure	2013	2014	2015	2016	2017	Recent Year Change (%)
Insulation and Infiltration Reduction						
Wall Insulation	59.8	60.4	61.4	55.1	58.9	6.9%
Ceiling/Attic Insulation	82.0	83.1	85.1	84.7	84.7	0.0%
Floor/Crawlspace Insulation	42.8	43.5	42.4	39.4	40.5	2.6%
Bandjoist Insulation	38.4	39.6	45.2	43.1	39.1	-9.3%
Infiltration Reduction	97.5	97.4	98.3	98.1	99.1	1.1%
Heating System Measures						
Htg. Sys. Replacement	58.4	64.0	66.6	70.3	68.1	-3.0%
High Eff Htg Sys Repl	50.6	58.7	62.7	66.8	60.2	-9.9%
Std/Unspec Eff Htg Sys Repl	7.8	5.3	3.9	3.4	7.9	130.8%
Htg. Sys. Tune and Clean	39.5	32.9	27.5	26.3	30.0	13.8%
Heating System Safety Check	15.0	13.1	15.2	9.3	0.1	-99.1%
Heating System Ventilation	33.3	24.4	43.4	52.9	59.1	11.8%
Water Heater Measures						
Pipe Wrap	75.0	76.6	86.3	86.9	89.7	3.3%
Shower Head	21.7	22.5	19.6	14.9	14.7	-1.1%
Faucet Aerator	33.0	35.4	33.0	27.7	24.9	-10.2%
Water Heater Replacement	48.2	54.1	65.9	69.2	65.9	-4.7%
Hi-Eff Wtr Htr Repl.	38.9	50.2	64.5	69.2	65.9	-4.7%
Std-Eff Wtr Htr Repl.	9.4	3.8	1.5	-	-	-
Water Heater Ventilation	20.3	29.8	31.5	39.8	50.9	27.8%
Water Heater Repair	9.7	7.7	5.4	6.5	9.4	44.8%
Lighting Measures						
Efficient Lighting	86.1	82.9	81.6	75.6	70.4	-6.9%
Refrigeration Measures	24.8	22.0	19.7	22.4	18.8	-16.1%
Refrigerator Removal	0.3	0.1	0.1	0.1	0.3	133.1%
Refrigerator Exchange	21.4	18.8	16.6	19.0	15.7	-17.4%
Freezer Removal	0.1	0.2	0.1	0.2	0.2	16.6%
Freezer Exchange	4.7	4.4	4.4	5.3	4.2	-20.8%
Health and Safety (other than heat	ing & wate	r heating i	measures l	isted abov	e)	
CO Detector	81.1	84.4	85.2	90.9	93.9	3.3%
Smoke Detector	59.9	59.8	61.2	65.3	68.4	4.7%
Exhaust Ventilation	80.4	82.4	84.5	89.3	89.8	0.5%
Fuses	0.1	0.5	0.9	0.7	0.8	16.6%
Repairs	88.4	87.3	88.1	87.9	92.3	5.0%

Table 1.14 shows details of the average installed costs for each measure over the past 5 years. As with the installation rates, the greatest changes tend to occur for measures with few installations and/or small costs.

Table 1.14 Average Measure Costs

Measure	2013	2014	2015	2016	2017	Recent Year Change (%)
Insulation and Infiltration Reduction N	1easures					
Wall Insulation	1,466	1,753	1,803	1,904	1,827	-4.0%
Ceiling/Attic Insulation	1,124	1,247	1,264	1,352	1,287	-4.8%
Infiltration Reduction	556	641	676	824	840	2.0%
Floor/Crawlspace Insulation	683	674	677	759	643	-15.3%
Bandjoist Insulation	164	203	223	238	208	-12.9%
Heating System Measures						
Htg. Sys. Replacement						
Condensing Htg Sys Repl	2,388	2,858	3,001	2,957	2,868	-3.0%
Non-Cond Htg Sys Repl	2,766	2,145	2,189	2,611	1,830	-29.9%
Htg. Sys. Tune and Clean	155	219	186	214	201	-6.1%
Heating System Safety Check	135	138	145	149	85	-43.0%
Heating System Ventilation	238	236	236	232	209	-9.7%
Water Heater Measures						
Pipe Wrap	5	12	14	15	14	-2.1%
Shower Head	9	10	9	9	9	4.2%
Faucet Aerator	4	6	6	6	6	-0.5%
Water Heater Replacement						
Hi-Eff Wtr Htr Repl.	1,175	1,448	1,569	1,561	1,559	-0.1%
Std-Eff Wtr Htr Repl.	1,097	1,638	1,426	-	-	-
Water Heater Ventilation	213	237	188	175	157	-10.7%
Water Heater Repair	102	115	122	130	120	-7.4%
Lighting Measures						
Efficient Lighting (avg spent per home)	60	63	59	53	53	0.2%
Refrigeration Measures						
Refrigerator Removal	18	20	28	58	25	-56.5%
Refrigerator Exchange	698	688	782	759	760	0.1%
Freezer Removal	25	23	25	30	27	-11.1%
Freezer Exchange	498	463	527	453	468	3.2%
Health and Safety (other than heating	& water	heating n	neasures l	isted abo	ve)	
CO Detector	49	57	62	66	72	9.2%
Smoke Detector	47	52	59	54	58	8.9%
Exhaust Ventilation	659	734	830	881	887	0.7%
Fuses	22	103	82	128	113	-11.6%
Repairs	636	668	589	723	715	-1.1%
Support	2,631	3,106	3,452	3,755	3,677	-2.1%

 $Note: Kneewall \ insulation \ was \ reported \ with \ wall \ insulation \ prior \ to \ 2007, it \ is \ now \ bundled \ with \ Ceiling./Attic \ Insulation \ prior \ to \ 2007, it \ is \ now \ bundled \ with \ Ceiling./Attic \ Insulation \ prior \ to \ 2007, it \ is \ now \ bundled \ with \ Ceiling./Attic \ Insulation \ prior \ to \ 2007, it \ is \ now \ bundled \ with \ Ceiling.$

1.20 Dalhoff Associates, LLC

SAVINGS OF WATER HEATER, LIGHTING, AND REFRIGERATION MEASURES

Table 1.15 shows the installation rates for energy efficiency measures other than space heating or cooling. These measures include water heater efficiency measures, lighting, and refrigeration measures. Statewide, client bill savings averaged \$37 for these measures. The highest average bill savings were attained by Siouxland at \$95 per unit. Matura averaged less than \$7 per dwelling.

Table 1.15 Installation Rates and Savings of Baseload Measures

	Water Heating			Lighting	Lighting Refrigeration				
									Average
		Eff Shower-	Eff Faucet	Efficient	Exchange	Exchange	Remove	Remove	First Year Bill
Agency	Pipe Wrap	head	Aerator	Lighting	Refrig	Freezer	Refrig	Freezer	Savings
New Opp	45%	2%	10%	88%	2%	10%	0%	0%	\$24.42
НАСАР	99%	1%	0%	77%	21%	8%	0%	0%	\$40.71
Eastern IA	92%	18%	56%	74%	13%	5%	0%	0%	\$26.62
Matura	67%	0%	0%	0%	7%	0%	0%	0%	\$6.25
MICA	58%	3%	4%	43%	11%	5%	1%	0%	\$20.18
Mid-Sioux	92%	16%	14%	84%	8%	0%	0%	0%	\$49.55
North Iowa	93%	38%	79%	85%	37%	12%	1%	3%	\$78.28
NE Iowa	90%	0%	0%	48%	8%	1%	1%	0%	\$15.99
New View	91%	0%	0%	89%	46%	6%	0%	0%	\$81.61
Threshold	99%	24%	2%	64%	8%	1%	0%	0%	\$18.45
Redrock	94%	6%	0%	94%	6%	0%	0%	0%	\$22.91
									•
SCICAP	55%	41%	32%	73%	9%	5%	0%	0%	\$31.22
SE Iowa	98%	0%	0%	58%	9%	4%	0%	0%	\$25.38
SIEDA	97%	1%	1%	52%	8%	3%	0%	0%	\$37.25
Upper Des Moines	100%	0%	0%	89%	19%	1%	0%	0%	\$48.55
West Central	91%	43%	70%	83%	2%	0%	0%	0%	\$23.24
CAA Siouxland	98%	63%	3%	93%	33%	15%	3%	0%	\$95.00
Polk County	99%	26%	77%	70%	21%	0%	0%	0%	\$34.81
State	90%	15%	25%	70%	16%	4%	0%	0%	\$36.68

TRENDS IN THE INSTALLATION RATES OF LIGHTING, REFRIGERATION, AND HEATING SYSTEM REPLACEMENTS

This section focuses on trends in the installation rates of several efficiency measures phased into the joint utility/WAP program, including efficient lighting, heating system replacements, and refrigeration measures. These are shown in Figures 1.15 through 1.18.




Figure 1.15 Percentage of Housing Units Receiving Lighting Measures

Figure 1.15 shows the percentage of dwellings receiving at least one lighting measure for each year, beginning in 1996. Lighting was installed in 38% of dwellings in 1996 and peaked in 2006 and 2007 at 89%. The installation rates for lighting have decreased over the past four years as more units already have efficient lighting installed. In 2017, 70% of units received lighting from the program.

1.22 Dalhoff Associates, LLC




Figure 1.16 Average Number of Bulbs Installed for Housing Units Receiving Lighting Measures

The average number of bulbs installed in dwellings that received at least one lighting measure averaged 8.7 bulbs per house 2017. Thirty-five percent of bulbs were LEDs. The peak installation rate for all bulbs occurred from 2010-2013 at 10.5 bulbs per dwelling (Figure 1.16).




Figure 1.17 Installation Rates of Refrigeration Measures

Figure 1.17 shows the initial ramp up of refrigeration measure installation rates as well as declines in recent years as the efficiency of in-place units is increasing in the client population. The refrigerator replacement rates are at their lowest (15.7%) since the program began ramping up in 2001.




Figure 1.18 Installation Rates of Natural Gas Heating System Replacements

Figure 1.18 shows the transition to condensing (90+ efficiency) furnaces from non-condensing (80% efficiency) heating systems. Overall, 68% of dwellings with natural gas heating received a heating system replacement during 2017, with the vast majority of these being condensing units (60%).

1.24 Dalhoff Associates, LLC

AVERAGE COSTS OF MAJOR MEASURES BY AGENCY

Figures 1.19-1.23 show the agency-specific average costs for ceiling, wall, and floor/crawlspace insulation and furnace replacements for the overall program and for utility-funded measures only. These costs represent the total expenditures for these measures averaged over the number of households that received the measure (as opposed to an average across all households that were treated by the agency).

CEILING AND ATTIC INSULATION EXPENDITURES




Figure 1.19a Average Program Expenditures on Ceiling Insulation by Agency

Figures 1.19a shows the average installed costs for ceiling and attic insulation (including cavity-fill blown attic insulation) for all expenditures. The statewide average cost for ceiling insulation was \$1,287 in 2017.

SE Iowa and CAA Siouxland averaged \$1,682 and \$1,629 per unit. The lowest average spending was reported by Northeast Iowa, averaging \$709.

Figure 1.19b shows the statewide average expenditure of utility funds on ceiling and attic insulation was \$1,131. MATURA spent the most at \$1,723, followed by DMCAA (\$1,632). Northeast Iowa spent the least utility funds (\$654) for ceiling and attic insulation.




Figure 1.19b Average Utility Expenditures on Ceiling Insulation by Agency

1.26 Dalhoff Associates, LLC

WALL INSULATION EXPENDITURES

Figures 1.20a shows the average installed costs for wall insulation for all funding. The state average expenditure for wall insulation was \$1,827 in CY 2017. North Iowa, HACAP, and Mid-Sioux each averaged more than \$2,500. MATURA spent the least, averaging \$295 per dwelling unit.




Figure 1.20a Average Program Expenditures on Wall Insulation by Agency

Figure 1.20b provides agency expenditures for utility-funded wall insulation. Statewide, the average expenditures for utility-funded wall insulation averaged \$1,608 in CY 2017. IMPACT, HACAP, Mid-Sioux, and MATURA spent the most utility funds, averaging over \$2,000; MATURA spent no utility funds for wall insulation in 2017.




Figure 1.20b Average Utility Expenditures on Wall Insulation by Agency

1.28 Dalhoff Associates, LLC

FLOOR/CRAWLSPACE INSULATION

Figures 1.21a shows the average expenditures for floor/crawlspace insulation from all funding sources. Statewide, the cost for floor/crawlspace insulation averaged \$643. CAA Siouxland and DMCAA spent the most, averaging over \$1,000 per unit, while North Iowa spent less than \$300.




Figure 1.21a Average Program Expenditures on Floor/Crawlspace Insulation by Agency

The average expenditure of utility funds for floor/crawlspace insulation(Figure 1.21b) was \$581. DMCAA and Siouxland spent over \$1,000 while SIEDA, North Iowa, and Mid-Sioux spent less than \$300.




Figure 1.21b Average Utility Expenditures on Floor/Crawlspace Insulation by Agency

1.30 Dalhoff Associates, LLC

NON-ELECTRIC HEATING SYSTEM REPLACEMENT EXPENDITURES

Figures 1.22a shows the average expenditures for all non-electric heating system replacements from all funding sources. Statewide average heating system replacement costs were \$2,986 in 2017. Three agencies reported average expenditures exceeding \$4,000, including SCICAP (\$4,705), Siouxland (\$4,250), and West Central (\$4,095). Three agencies averaged less than \$2,300, including (\$2,057), Threshold (\$2,249), and DMCAA (\$2,237).




Figure 1.22a Average Program Expenditures on Heating System Replacements by Agency

Figure 1.22b shows the average utility funding for replacement heating systems of \$2,458 statewide. SCICAP averaged the highest expenditure at \$3,215, followed by West Central (\$3,212) and MATURA (\$3,050). DMCAA pent the least, averaging \$1,917 per housing unit.




Figure 1.22b Average Utility Expenditures on Heating System Replacements by Agency

1.32 Dalhoff Associates, LLC

Section 4, Detailed Spending and Impact Profiles by Agency provides tables similar to those in Section 4 for each weatherization agency, for all measures installed.

Section 5, Detailed Spending and Impact Profiles by Agency for Utility Expenditures provides similar detail by agency, but is limited to measures funded by the utilities.

2. FUEL CONSUMPTION ANALYSIS

Savings were estimated for all clients based upon measures installed in each dwelling, using algorithms developed in prior studies of the lowa low-income program. The fuel consumption analysis provides adjustment factors to the estimated impacts, with gas adjustments applied to estimates of natural gas, propane, and fuel oil heating impacts.

STUDY SAMPLE AND METHODOLOGY

Weatherization jobs completed from January 1, 2017 through December 31, 2017 comprised our treatment group gas treatment group. Jobs weatherized from October, 2016 through May, 2017 comprised the electricity treatment group.

We used a comparison group to adjust for non-weatherization program factors that affect fuel usage, including but not limited to fuel price shocks, naturally-occurring conservation, and participation in other energy programs. Our comparison group consisted of all LIHEAP clients of the SLICE utilities and who applied for energy assistance from October, 2017 through March, 2018. In order to assess a change in consumption for the comparison group, we established a pseudo-treatment period for each comparison group household by assigning the same period as that of a randomly selected household from the treatment group.

Estimated usage readings were combined with subsequent actual readings. Phone/postcard readings and final or corrected readings were considered actual readings. Reading codes not corresponding to actual readings were considered estimated.

The weatherization period was defined as beginning with the audit date and ending with the date the dwelling was reported as complete. We truncated the usage data to a period of no more than to 390 days prior to the beginning of the weatherization period, and up to 390 days following end of the weatherization period.

Fuel consumption was weather-normalized using weather data from the same ten weather zones (Figure 2.1). Our long-term normal weather datasets are comprised of the 28-year period ending in Dec, 2017.

The comparison group records were matched with treatment group records based upon normalized annual pre-weatherization consumption, housing type, heating fuel, and model components (heating and or/ cooling and/or baseload).




Figure 2.1 Weather zones used in the weather-normalization

MODEL SELECTION

We investigated impacts using five model specifications for each dwelling:

- Heating/Baseload (gas and electricity)
 - o HB using floating point reference temperatures ranging between 40°F to 70°F
 - o HBF using fixed reference temperatures of 62°F for natural gas and 58°F for electricity
- Cooling/Baseload (electricity only)
 - o CB using floating point reference temperatures ranging between 60°F to 72°F
 - CBF using fixed reference temperatures of 68°F
- Heating only (gas only)
 - HO using floating point reference temperatures ranging between 40°F and 70°F
 - HOF using fixed reference temperatures of 62°F

2.2 Dalhoff Associates, LLC

- Heating/Cooling/Baseload (electricity only)
 - Heating floating point reference temperatures ranging between 40°F and 70°F
 - Cooling floating point reference temperatures ranging between 60°F and 72°F
 - HCF using fixed reference temperatures of 58°F for heating and 68°F for cooling
- BO Baseload (electricity and gas, but no gas models passed the selection process)
 - o flat usage, requiring nine months of data.

Three levels of screens were used, including:

- 1) Insufficient usage history or usage characteristics
- 2) Poor model diagnostics
- 3) Poor model reliability.

SCREENS FOR POOR MODEL DIAGNOSTICS

Models were dropped if:

- the coefficient of variation of NAC exceeded 0.1
- negative values for adjusted r²
- Gas: R² of at least 0.7, electricity: R² of at least 0.5

SCREENS FOR POOR MODEL RELIABILITY

Models were dropped if:

- the normalized annual heating consumption, heating slope, or baseload components were negative
- Minimal requirements for specific model types:
 - Heating models require usage during periods representing at least 50% of the annual heating days
 - Baseload models required 8.5 months of consumption
- Usage histories had insufficient data during heating and/or cooling seasons. Histories must have usage during periods of at least 50% of heating degree days (base 62 for gas, 58 for electricity heating models), and 50% of cooling degree days base 68 (electricity only)

Finally, we required that the normalized annual consumption was within 10% of the results for alternate model specifications where multiple models met other criteria.

ATTRITION ANALYSIS - GAS

We requested data for 1,215 weatherization client dwellings with gas heating and 70,196 LIHEAP client dwellings for our comparison group (also with gas heating). This request included dwellings weatherized in 2017.

ATTRITION RATES

Table 2.1 provides a breakout of the attrition rates of the natural gas billing data request, by state and utility.

The utilities returned useable data for 87% of the treatment client dwellings and 79% for the comparison group (LIHEAP) clients. Useable histories with sufficient pre- and post-weatherization data were available for 70% of the treatment group clients and 61% of the comparison group. Our final analytic dataset included 605 weatherization client dwellings and 34,911 comparison dwellings, representing 60% and 51% of the requested usage histories for the treatment and comparison groups, respectively.

Table 2.1 Gas Analysis Sample Attrition

		Stat	e	IP	L	вно	:	MA	E
		Trt	Cmpr	Trt	Cmpr	Trt	Cmpr	Trt	Cmpr
	Requested	1,005	68,989	394	18,583	144	10,759	467	39,647
Return Rate	Returned	872	54,545	372	17,865	131	9,906	369	26,774
	Percentage Returned	86.8%	79.1%	94.4%	96.1%	91.0%	92.1%	79.0%	67.5%
Useable Histories	Both Pre and Pst Cnt	698	41,971	263	10,444	100	7,502	335	24,025
Oseable Histories	Both Pre and Pst Pct	69.5%	60.8%	66.8%	56.2%	69.4%	69.7%	71.7%	60.6%
Passed Model	Both Pre and Pst Cnt	642	36,814	235	8,755	87	6,428	320	21,631
Diagnostics	Both Pre and Pst Pct	63.9%	53.4%	59.6%	47.1%	60.4%	59.7%	68.5%	54.6%
Passed Reliability	Both Pre and Pst Cnt	605	34,911	222	8,553	86	6,386	297	19,972
Screens	Both Pre and Pst Pct	60.2%	50.6%	56.3%	46.0%	59.7%	59.4%	63.6%	50.4%

Table 2.2 provides the attrition analysis broken out by housing type. Overall, 62% of the requested account data for weatherized single family site-built dwellings, 55% of mobile homes, and 33% of the few multi-family dwellings weatherized by the program passed all analytic screens.

2.4 Dalhoff Associates, LLC

Table 2.2 Gas Attrition by Housing Type

		Stat	e	IPI	L İ	вно	:	МА	E
		Trt	Cmpr	Trt	Cmpr	Trt	Cmpr	Trt	Cmpr
Single Family Deta	ched Framed Dwellings								
Requested		899	54,361	367	15,150	130	8,824	402	30,387
Returned		792	44,843	353	14,779	120	8,140	319	21,924
Percentage Return	ed	88.1%	82.5%	96.2%	97.6%	92.3%	92.2%	79.4%	72.1%
Passed Model	Both Pre and Pst Cnt	587	31,344	224	7,592	81	5,456	282	18,296
Diagnostics	Both Pre and Pst Pct	65.3%	57.7%	61.0%	50.1%	62.3%	61.8%	70.1%	60.2%
Passed Reliability	Both Pre and Pst Cnt	554	29,723	211	7,411	80	5,427	263	16,885
Screens	Both Pre and Pst Pct	61.6%	54.7%	57.5%	48.9%	61.5%	61.5%	65.4%	55.6%
Mobile Homes									
Requested		73	3,526	14	1,098	9	504	50	1,924
Returned		61	2,878	14	1,068	7	456	40	1,354
Percentage Return	ed	83.6%	81.6%	100.0%	97.3%	77.8%	90.5%	80.0%	70.4%
Passed Model	Both Pre and Pst Cnt	43	1,859	10	490	4	301	29	1,068
Diagnostics	Both Pre and Pst Pct	58.9%	52.7%	71.4%	44.6%	44.4%	59.7%	58.0%	55.5%
Passed Reliability	Both Pre and Pst Cnt	40	1,771	10	487	4	298	26	986
Screens	Both Pre and Pst Pct	54.8%	50.2%	71.4%	44.4%	44.4%	59.1%	52.0%	51.2%
Multi-Family									
Requested		33	11,102	13	2,335	5	1,431	15	7,336
Returned		19	6,824	5	2,018	4	1,310	10	3,496
Percentage Return	ed	57.6%	61.5%	38.5%	86.4%	80.0%	91.5%	66.7%	47.7%
Passed Model	Both Pre and Pst Cnt	12	3,611	1	673	2	671	9	2,267
Diagnostics	Both Pre and Pst Pct	36.4%	32.5%	7.7%	28.8%	40.0%	46.9%	60.0%	30.9%
Passed Reliability	Both Pre and Pst Cnt	11	3,417	1	655	2	661	8	2,101
Screens	Both Pre and Pst Pct	33.3%	30.8%	7.7%	28.1%	40.0%	46.2%	53.3%	28.6%

OUTLIERS

An outlier screen was then applied to models with reliable pre- and post-usage data using the Interquartile Rule for Outliers (Tukey Fence). Cases where the percentage savings were greater or less than 1.5 times the interquartile range were dropped.

The outlier screen dropped approximately 3% of treatment group observations and 14% of comparison group cases with pre and post savings models.

GAS IMPACT ANALYSIS

Our results are summarized in Table 2.3. The agency-specific results are summarized on each line, with the overall program impacts summarized on the bottom line. The column labeled 'Population' provides the count of all dwellings with natural gas heating that were treated by the weatherization program during the calendar year. The treatment group columns indicate the number of dwellings in our screened analysis dataset ('n'), the weather-normalized annual consumption prior to weatherization ('Baseline' consumption), the 90% confidence interval on the baseline consumption (interpreted as the variation from baseline for which we are 90% certain that the true mean value of the baseline consumption falls within), the unadjusted savings ('Savings') and the 90% confidence interval on the savings.

The next section of Table 3.2 provides results for the matched comparison group. To the right if those results are the net savings by agency, including average savings and percentage savings.

The rightmost section summarizes the average estimated savings which were developed using dwelling-specific measure data as well as a comparison between the estimated and observed savings, termed the realization rate. The realization rate is defined as the ratio of observed savings to estimated savings. Our final agency-specific results are developed by applying this ratio to the estimated savings for all dwellings with non-electric heating.

The overall adjusted savings (reported under the Net Savings column) averaged 247 therms for single family site-built dwellings. The 90% confidence interval was 17 therms, which is suggestive that 90% certain that the true population mean savings falls in the approximate range of 230 and 264 therms. The overall mean percent savings was 24.5%, with a 1.3% confidence interval.

Net gas savings for mobile homes averaged 204 therms ±59 therms. The overall percentage savings for mobile homes was 21.7%, with a 5.1% confidence interval.

We did not have enough data to provide reliable results for the few multi-family dwellings weatherized.

2.6 Dalhoff Associates, LLC

Table 2.3 Gas Fuel Consumption Analysis Results

	Population		Treatmen	t Group				Comparis	son Grou	ıp								
	(with gas heating source)	n	Baseline Cons. (therms)	90% CI	Savings (therms)	90% CI	n	Baseline Cons. (therms)	90% CI	Savings (therms)	90% CI	Net Savings (therms)	90% CI	Percent Savings (%)	90% CI	Estimated Savings	90% CI	Realization Rate (%)
Single Family Detache	ed Framed Dw	elling Re	esults															
New Opportunities	36	19	1,352	173	521	148	107	1,338	170	64	32	457	138	33.8%	6.9%	365	65	125.2%
HACAP	90	41	1,127	78	269	56	341	1,118	77	5	33	264	60	23.5%	4.6%	274	30	96.6%
Eastern IA	103	78	896	60	206	33	505	896	59	-16	17	223	33	24.8%	3.4%	307	33	72.5%
MATURA	11	5	1,207	268	369	265	55	1,176	209	10	85	358	198	29.7%	15.3%	201	110	178.6%
MICA	79	60	988	89	269	57	371	991	87	-13	17	283	62	28.6%	4.8%	268	31	105.6%
Mid-Sioux	32	16	956	81	217	59	158	948	80	52	29	164	71	17.1%	7.4%	231	47	71.0%
North Iowa	79	53	1,008	73	328	60	400	1,000	73	17	20	311	61	30.8%	4.2%	366	37	84.9%
NE Iowa	57	23	953	12.5	131	59	218	957	120	30	19	99	62	10.4%	5.9%	168	46	59.1%
New View	19	7	974	232	181	194	97	963	206	7	16	174	183	17.8%	18.7%	269	92	64.6%
Threshold	71	37	1,173	92	312	46	319	1,169	91	57	26	255	49	21.7%	3.8%	366	52	69.5%
IMPACT	28	12	981	167	223	92	204	993	150	2	29	220	99	22.5%	8.1%	290	48	75.9%
SCICAP	15	7	823	188	91	190	55	849	172	20	24	72	158	8.7%	22.4%	223	56	32.1%
SE Iowa	50	15	1,168	134	322	139	160	1,165	127	15	23	307	134	26.3%	10.1%	405	80	75.8%
SIEDA	29	17	789	148	199	80	165	797	140	-8	24	209	80	26.5%	6.1%	249	51	83.8%
Upper Des Moines	72	49	839	61	158	34	396	839	62	13	19	145	30	17.3%	3.3%	231	29	62.9%
West Central	37	19	796	142	232	102	327	800	137	2	18	230	97	28.8%	7.6%	247	47	93.1%
CAA Siouxland	19	11	1,169	147	217	109	199	1,178	140	73	26	146	100	12.5%	9.0%	219	49	66.4%
Polk County	115	75	1,114	65	325	44	505	1,114	64	27	20	297	47	26.7%	3.3%	308	19	96.4%
Overall	942	544	1,009	25	261	17	4,582	1,008	25	14	6	247	17	24.5%	1.3%	291	11	84.8%
Mobile Home Results	(entire state)																	
Overall	75	38	942	62	182	60	148	934	64	-21	21	204	59	21.7%	5.1%	150	21	136.3%

SAVINGS WITH RESPECT TO PRE-WEATHERIZATION USAGE

We plotted the relationship between the normalized annual consumption and the net savings for single family site-built dwellings (Figure 2.2). The upward trending regression line indicates the population-weighted fit between NAC and savings, and demonstrates savings in relation to baseline consumption. The statewide average is shown at the center, labeled 'State'.




Figure 2.2 Savings in relation to the pre-weatherization normalized annual consumption (single family site-built dwellings).

The 90% confidence intervals are extremely wide for several agencies, including SCICAP, New View, MATURA, and New Opportunities. The high variation in savings can be attributed to various factors including wide variations in housing stock, agency practices, and lower sample sizes. These factors are becoming a hindrance to assessing agency-specific results in recent years as fewer numbers of homes weatherized annually.

The 90% confidence intervals of the average adjusted savings for each agency are shown in the error bars. Agencies with confidence intervals overlapping the regression line produced savings consistent with the state overall for dwellings relative to the baseline consumption for those agencies. The most significant underperforming agency was Upper Des Moines. This suggests that significant differently different housing stock, weatherization procedures, or other factors

2.8 Dalhoff Associates, LLC

resulted in comparatively lower savings for these agencies relative to pre-weatherization consumption.

In addition, agencies in which the confidence intervals range extend into or above the confidence interval for the state overall had similar or higher savings relative to the state. All agencies achieved this except Upper Des Moines.

Figure 2.3 provides another view of the savings with respect to baseline consumption. The plot shows a point for the savings for dwellings in our billing dataset, a regression line through all points, and an assessment of the percentage savings as determined by this regression line (shown by the curved line). The chart provides confirmation that absolute savings increase as higher-consumption dwellings are targeted. Percent savings increases significantly as baseline consumption increases at the lower range, and less so at higher ranges as the curve flattens out.




Figure 2.3. Relationship between baseline consumption, savings, and percentage savings

TRENDS IN BASELINE CONSUMPTION AND ENERGY SAVINGS

Figure 2.4 provides a yearly summary of baseline consumption, savings, and percentage savings for billing analyses conducted since the calendar year 1998 program. The treatment group normalized annual consumption approached 1,394 therms per site-built dwelling in the CY 1998 program. Baseline consumption has declined by 28% since then, and averaged 1,009 therms in CY 2017. Generally speaking, net savings has declined through 2010 and has increased slightly since then. Overall percentage savings has increased through the period, from around 23% to slightly more than 24.5% in the 2016 program.




Figure 2.4 Annual Baseline Consumption, Savings, and Percentage Savings

2.10 Dalhoff Associates, LLC

ATTRITION ANALYSIS - ELECTRICITY

We requested data for 839 weatherization client dwellings and 87,501 LIHEAP client dwellings for our comparison group. The electricity analysis was restricted to home weatherized from Oct, 2017 through May, 2017 to allow for up to a year of pre and post-weatherization periods.

Overall we had 520 treatment and 45,486 comparison group homes which passed all screens.

Table 2.5 Electricity Analysis Sample Attrition

		Stat	e	IPL	_	MA	E
		Trt	Cmpr	Trt	Cmpr	Trt	Cmpr
	Requested	839	87,501	469	40,547	370	46,925
Return Rate	Returned	738	73,269	442	39,745	296	33,524
	Percentage Returned	88.0%	83.7%	94.2%	98.0%	80.0%	71.4%
Useable Histories	Both Pre and Pst Cnt	601	57,768	332	24,904	269	32,848
Oseable Histories	Both Pre and Pst Pct	71.6%	66.0%	70.8%	61.4%	72.7%	70.0%
Passed Model	Both Pre and Pst Cnt	539	47,996	290	21,363	249	26,625
Diagnostics	Both Pre and Pst Pct	64.2%	54.9%	61.8%	52.7%	67.3%	56.7%
Passed Reliability	Both Pre and Pst Cnt	520	45,486	283	21,037	237	24,444
Screens	Both Pre and Pst Pct	62.0%	52.0%	60.3%	51.9%	64.1%	52.1%

Table 2.6 provides the attrition analysis broken out by housing type. Most of the cases with electricity results were for weatherized single family detached frame dwellings, totaling 479 cases. Twenty-nine mobile homes and twelve multi-family units weatherized by the program passed all screens.

Table 2.6 Electricity Attrition by Housing Type

		Stat	e	IPI	L	МА	E
		Trt	Cmpr	Trt	Cmpr	Trt	Cmpr
Single Family Deta	ached Framed Dwellings						
Requested		744	60,891	403	28,759	341	32,109
Returned		665	52,329	389	28,167	276	24,162
Percentage Return	ed	89.4%	85.9%	96.5%	97.9%	80.9%	75.2%
Passed Model	Both Pre and Pst Cnt	496	35,910	263	16,177	233	19,728
Diagnostics	Both Pre and Pst Pct	66.7%	59.0%	65.3%	56.3%	68.3%	61.4%
Passed Reliability	Both Pre and Pst Cnt	479	34,136	257	15,922	222	18,210
Screens	Both Pre and Pst Pct	64.4%	56.1%	63.8%	55.4%	65.1%	56.7%
Mobile Homes							
Requested		52	3,376	31	1,550	21	1,825
Returned		45	2,814	30	1,513	15	1,301
Percentage Return	ed	86.5%	83.4%	96.8%	97.6%	71.4%	71.3%
Passed Model	Both Pre and Pst Cnt	31	1,851	19	786	12	1,065
Diagnostics	Both Pre and Pst Pct	59.6%	54.8%	61.3%	50.7%	57.1%	58.4%
Passed Reliability	Both Pre and Pst Cnt	29	1,750	18	771	11	979
Screens	Both Pre and Pst Pct	55.8%	51.8%	58.1%	49.7%	52.4%	53.6%
Multi-Family							
Requested		43	23,234	35	10,238	8	12,991
Returned		28	18,126	23	10,065	5	8,061
Percentage Return	ed	65.1%	78.0%	65.7%	98.3%	62.5%	62.1%
Passed Model	Both Pre and Pst Cnt	12	10,235	8	4,400	4	5,832
Diagnostics	Both Pre and Pst Pct	27.9%	44.1%	22.9%	43.0%	50.0%	44.9%
Passed Reliability	Both Pre and Pst Cnt	12	9,600	8	4,344	4	5,255
Screens	Both Pre and Pst Pct	27.9%	41.3%	22.9%	42.4%	50.0%	40.5%

OUTLIERS

An outlier screen was then applied to models with reliable pre and post usage data using the Interquartile Rule for Outliers (Tukey Fence). Cases where the percentage savings were greater or less than 1.5 times the interquartile range were dropped.

The outlier screen dropped approximately 6% of treatment group observations and 13% of comparison group cases with pre and post savings models.

ELECTRICITY IMPACT ANALYSIS

We developed state-level electricity savings results for two groups, those with non-electric space heat and for those with electric space heat. Our results are summarized in Table 2.7.

2.12 Dalhoff Associates, LLC

Table 2.7 Electricity Fuel Consumption Analysis Results (State Level Results)

	Population		Treatme	nt Group				Compa	rison G	roup								
			Baseline					Baseline				Net		Percent		Estimated		
			Cons.	90%	Savings	90%		Cons.	90%	Savings	90%	0	90%	Savings	90%	Savings	90%	Realization
	n	n	(kWh)	CI	(kWh)	CI	n	(kWh)	CI	(kWh)	CI	(kWh)	CI	(%)	CI	(kWh)	CI	Rate (%)
Electric S	avings for I	Owellin	gs with No	n-Electr	ic Space l	Heat												
Overall	932	455	10,368	389	967	195	3,280	10,002	390	387	128	577	2 11	4.8%	1.8%	515	23	111.9%
Electric S	avings for I	Owellin	gs with Ele	ectric Sp	ace Heat		·			,								
Overall	71	35	22,472	2,586	3,298	1,575	338	22,364	2,544	372	492	2,979	1,592	9.4%	6.8%	2,136	494	139.5%

Dwellings with non-electric space heat averaged 577 kWh net savings from lighting, refrigerators and freezers, water heating, and cooling measures. The average net savings for dwellings with electric heat averaged 2,979 kWh per dwelling.

COMPARISON OF SAMPLE AND OVERALL PROGRAM POPULATIONS

Measure-level savings are estimated for all weatherization clients. These are based upon the actual installed quantities and measure type (e.g., r-value and amount of insulation installed) and measured reductions in the air leakage rate. Consequently the dwelling-specific estimate savings provide a good basis of comparison between the sample and overall population. Table 2.8 provides a comparison of the estimated savings for the population and billing analysis sample for site-built single family homes and mobile homes.

Table 2.8 Estimated Savings for the Population and Billing Analysis Sample – Gas Heated Dwellings

		Natu	ral Gas		1	Elect	tricity	
	Population		Sample		Population		Sample	
	Est Savings	Count						
	(therms)		(therms)		(kWh)		(kWh)	
Site-Built Single Family	_				_			
Overall	288	942	291	544	533	436	545	218
New Opportunities	343	36	365	19	600	10	621	8
HACAP	263	90	274	41	505	31	552	21
Eastern IA	306	103	307	78	508	52	463	30
MATURA	153	11	201	5	217	6	238	2
MICA	268	79	268	60	465	45	480	25
Mid-Sioux	237	32	231	16	618	9	582	5
North Iowa	367	79	366	53	771	32	782	18
NE Iowa	179	57	168	23	352	35	349	15
New View	276	19	269	7	898	7	707	1
Threshold	331	71	366	37	399	37	442	20
IMPACT	266	28	290	12	432	9	559	2
SCICAP	251	15	223	7	345	7	279	2
SE Iowa	416	50	405	15	677	25	677	12
SIEDA	265	29	249	17	550	27	585	7
Upper Des Moines	228	72	231	49	525	34	531	16
West Central	237	37	247	19	496	21	469	11
CAA Siouxland	264	19	219	11	1,031	4	1,687	2
Polk County	310	115	308	75	618	45	632	21
Mobile Home	i		1				1	
Overall	150	75	150	38	325	65	311	30
Multi-Family			1		1		1	
Overall	228	37	252	6	532	337	516	203

The gas estimated savings for single family homes statewide were similar between the population (288 therms) and sample (291 therms). There is a little more variability between the population and sample at the agency levels though most compared to within 10%. The estimated savings for the mobile home sample was nearly the same as the population overall as well (150 therms in each case). The population and estimated gas savings were also close for multi-family, at 228 and 252 therms, respectively.

2.14 Dalhoff Associates, LLC

Estimated electricity savings shown in Table 2.8 are for housing units heated with natural gas heat. The estimated electricity savings for single family homes were also similar for the state overall, with 533 kWH for the population and 545 kWh for the sample. The estimated electricity savings for the mobile homes in the billing analysis sample also was within 4% of the population.

It's important to recognize that differences in estimated savings between the sample and population don't directly affect the adjustment factors that are applied to the estimated savings. The adjustment factors are the percentage difference between the estimated and observed savings of the sample. For example, if the observed sample impacts are 10% greater than the sample estimated impacts, then a 10% adjustment is applied to all houses. We need only be concerned if there are large differences between the estimated savings of the sample and the population, and the above table indicates that there are no significant differences.

Table 2.9 provides a similar comparison for the electricity billing analysis. The first line shows nearly identical estimates of savings for the population and sample in units with non-electric heat (propane, fuel oil, natural gas, wood, etc.), at 516 kWh and 515 kWh respectively. The population and estimated savings for units heating with electricity varied by approximately 10%, which is reasonable given the few units that heat with electricity.

Table 2.9 Estimated Savings for the Population and Billing Analysis Sample - Electricity

	Popula	ation	Samı	ole
	Est Savings	Count	Est Savings	Count
	(kWh)		(kWh)	
Overall, non-electric ht	516	838	515	455
Overall, electric heat	1,924	63	2,136	35

2.16 Dalhoff Associates, LLC

3. DETAILED SPENDING AND IMPACT PROFILES BY FUNDING ENTITY

This section provides tables of spending and impacts for the utilities, the state, and the overall program. The tables are designed to provide information to meet the filing requirements for cost recovery.

The summaries of impacts for state and utility funding are similar in format to those provided in the earlier SLICE reports.

We show a second table for each of the utilities in this report. These tables show the combined impacts of electricity and natural gas measures from all funding sources. These tables should prove useful for the energy and demand planning departments at the utilities to account for the aggregate impacts of the low-income program, and not just the impacts funded by a specific utility.

Total Reported Labor, Materials and Utility Admin Expenditures: \$16,881,496

Utility Administration Expenditures: \$260,580

Total Labor and Material Expenditures: \$16,620,915

														lotal Labor a	and Material E	xpenaitures:	\$16,620,91	•	
					Billing A	Adjusted Fi	irst-Year S	avings				Avera		Adjusted Fir			ngs		
	Number of Dwellings with Impacts	Number of Dwellings with kWh Impacts						ı.						elling Receiv	-			ń.	
	Fuel	Season	Spending on Materials	Summer	Electricity	inter	Annual	Pk-Day	Gas Annual	Propage	Fuel Oil Othe	Spending on Materials	Sumn	Electric		nual Pk-Day	Gas Annual	Propage	Fuel Oil Other
Measure		Cooling Heating	& Labor (\$)	kW kW		kWh	kWh	therms	therms	gallons	gallons Mbt	u & Labor (\$)		kWh kW	kWh k\	Wh therms	therms		gallons Mbtu
Total Efficiency Measures	1,255 1,255 1,055 104 14 2	1,252 1,255	0.445.200	278.3	273.1		986,992	2 040	252,720	28,672	1,932 3	F 7.000	0.222	0.218		786 2.48	240	276	420 47
Total Efficiency Measures	1,255 1,255 1,055 104 14 2	1,252 1,255	9,115,286	210.3	2/3.1		900,992	2,010	252,720	20,072	1,932 3	5 7,263	0.222	0.210)	700 2.40	240	2/6	138 17
Total Shell & Htg. Sys. Repl	1,255 1,255 1,055 104 14 2 1,254 1,254 1,055 104 14 2		7,584,254			332,373 327,601	601,461				1,932 3			219 0.173		479 2.33	213		138 17
Total Shell Measures Wall Insul.	1,254 1,254 1,055 104 14 2 739 668 642 59 9 0	1,228 1,253 666 29	5,090,864 1,350,475		,088 213.7 ,261 24.6	327,601	596,689 147,044	1,475 509	135,209 46,663			5 4,060 0 1,827		219 0.17° 164 0.847		476 1.40 220 0.79	128 73		92 12 41 -
Open Blown Ceiling Insul	1,003 928 845 82 11 2	923 63	795,012	90.0 108	,567 75.5	115,469	224,036	434	39,751	4,006	494	7 793	0.098	118 1.198	3 1,833	241 0.51	47	49	45 4
Cavity Fill Insul Sloped Attic Insul	325 254 288 21 3 0 341 300 299 25 4 1	252 13 299 12	260,783 183,064		,324 5.8 ,165 6.0	9,012 9,115	24,335 28,281	136 120			93 101	0 802 6 537	0.050	61 0.448 64 0.50°		96 0.47 94 0.40	43 37	56 41	31 - 25 6
Kneewall Insul	293 249 257 21 2 1	248 12	128,698		,166 4.5	6,890	14,056	41	3,764		15	3 439		29 0.374		56 0.16	15		8 3
Infil. Reduction	1,244 1,152 1,048 103 14 2	1,147 77	1,045,485	18.0 21	,691 13.5	20,615	42,306	183			119	5 840	0.016	19 0.175		37 0.18	16	18	8 2
Found./Crawl. Insul Bandjoist Insul.	508 165 420 49 8 2 491 37 383 62 9 0	153 29 - 37	326,441 101,910	9.5 11 0.0	,436 8.1 0 5.8	12,295 8,868	23,731 8,868	75 29			89 40	4 643 0 208		75 0.280 0 0.156		144 0.18 240 0.08	16 7		11 2 4 -
Furnace Blower Fan ¹	1,175 1,159 1,055 104 14 2	- 1,159	0	0.0	0 100.6	154,437	154,437	(6)			(6)		0.000	0 0.087		133 (0.01)	(1		(0) (0)
Exhaust Ventilation	948 948 807 73 6 1	948 948	898,996		,523) (30.5)	(46,882)	(70,405)	(46)			(24)	1)		(25) (0.032		(74) (0.06)	(5	(6)	(4) (1)
Total Heating System Repl Condensing Htg Sys Rep	835 30 717 79 8 1 756 0 673 76 6 1	- 30	2,493,389	0.0	0 3.1	4,772	4,772	984 870	89,981 79,444			0 2,986 0 2,868		0 0.104	159	159 1.37	125		80 10 86 10
Non-Cond Htg Sys Repl	99 0 88 9 2 0		181,203	0.0	0 0.0	0	0	114				0 1,830				- 1.29	120		60 -
Electric Htg Sys Repl	20 20 0 0 0 0	- 20	73,915	0.0	0 2.0	2,980	2,980	0	0	0	-	0 3,696		0 0.098		149 -	-	-	
Heat Pump Repl Other Htg Sys Repl	11 11 0 0 0 0 0 0 0 0 0	- 11 - 0	69,924 0	0.0 0.0	0 1.2 0 0.0	1,793 0	1,793 0	0	0	0	0	0 6,357	0.000	0 0.106	163	163 -		-	
																			
	Fuel	Number of Measures Installed by Fuel Type Fuel		Summer	Winter		Annual	Pk-Day	Annual	Propane	Fuel Oil Other	,	Summer	Winte	r An	nual Pk-Day	Annual	Propane	Fuel Oil Other
	Total Electric Gas Propane Oil Other	Total Electric Gas Propane Oil Other		kW	kW		kWh	therms	therms	gallons	gallons Mbt	и	kW	kW	k\	Wh therms	therms	gallons	gallons Mbtu
Water Heating Temp. Reduct.	1,213 338 833 42 0 0 7 6 1 0 0 0	2,653 565 2,010 78 0 0 7 6 1 0 0 0	1,309,164	0.0	0.7		41,780 720	156.7	27,529 7	1,358	0	0 1,079	0.000	0.002		124 0.188 120 0.02	33	32	
WH Wrap	0 0 0 0 0 0	0 0 0 0 0 0	0	0.0	0.0		0	0.0	0			0 0	-	-					
Pipe Insul. LF Showerhead	1,126 315 778 33 0 0 185 43 138 4 0 0	1,126 315 778 33 0 0 204 48 151 5 0 0	16,288 1,741	0.0	0.0 0.2		14,229 8.258	6.6 3.2	2,297 999		0	0 14	0.000	0.000		45 0.01 192 0.02	3		1 1
Faucet Aerator	312 51 256 5 0 0	489 78 405 6 0 0	1,901	0.0	0.1		2,717	1.9			0	0 6	0.000	0.00		53 0.01	2		
Std-Eff Wtr Htr Repl. Hi-Eff or Electric Wtr Htr Repl.	0 0 0 0 0 0 827 118 675 34 0 0	0 0 0 0 0 0 0 827 118 675 34 0 0	0 1,289,234	0.0	0.0		0 15,857	0.0 145.0	0 23,656	0 1,211		0 1 559	0.000	0.003	,	 134 0.21	- 35	36	
Lighting	883 883	7,773 7,773	47,166	21.3	39.4		203,184	145.0	23,030	1,211		. 53		0.003	5	230 -	- 30	-	
Refrigerator/Freezer ³	236 236	266 266	174,702	17.2	16.1		140,567	-	-	-		740		0.068		596 -		-	
Refrigerator Removal Refrigerator Exchange	4 4 197 197	5 5 204 204	100 149,737	0.3 13.0	0.3 12.2		2,558 106.276	- 1	- :	-	- :	760	0.079	0.074		640 - 539 -		-	1 1
Freezer Removal	3 3	3 3	80	0.2	0.2		1,769	-	-	-		. 27	0.073	0.068	3	590 -	-	-	
Freezer Exchange	53 53	54 54	24,784	3.7	3.4		29,963	-	-	-	-	468	0.070	0.065	5	565 -	-	-	
Total Non-Efficiency Measures	1,255		7,505,630									5,981							
Misc Ins,Attic Access/Ven	1,084 381		294,476 69 494									272 182	2						
Duct Insulation	543		59,284									109	9						
Damming Material	664		46,668									70							
Htg. Sys. Tune & Clean Htg. Sys./WH Other	376 310		75,601 170,738									201 551							
Air Conditioning Work	28		4,614									165	5						
Water Heater Repair Refrigerator Coil Clean	118 0		14,173 0									120							
Waterbed Mattress Pad	0		0									C)						
Programmable Tstat Unspecified Utility Meas	82 0		8,017									98	3						
CO Detector	1,178		84,344									72	2						
Smoke Detector	859		50,179									58	3						
Fuses Htg Sys Safety Check	10		1,130 85									113 85	5						
Htg Sys Ventilation	742		155,412									209	9						
Water Heater Ventilation Bathroom Ventilation	639 489		100,119 81,874									157 167							
Dryer Ventilation	835		89,626									107							
Kitchen Ventilation	0		0									C)						
Other Exhaust Ventilation Asbestos Removal (Minor)	434 20		18,705 26,229									43 1,311							
Health/Safety Repairs	860		443,566									516	3						
Health/Safety Other Consumables	137 382		10,199 16,630									74							
General Repairs	1,158		828,300									715	5						
Meter Refrig (no action) Meter Freezer (no action)	915 322		0									0							
Support (no action)	1,243		4,570,198									3,677	7						
Transportation Allowance	253		35,244									139	9						
Landlord Contr Misc Landlord Contr Furnace	1 0		(2,000)									-2,000							
Landlord Contr DHW	0		0									6	ó						
Client Contr (Any)	0		0									0)						
Lead Safe Work Unspecifed/Other	820 0		252,727 0									308							

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed by the percentage of expenditures for each appliance is totaled to get the total number of measures installed by the percentage of expenditures for each appliance is totaled to get the total number of measures installed by the percentage of expenditures for each appliance is totaled to get the total number of measures installed to the percentage of expenditures for each appliance is totaled to get the total number of measures installed to the percentage of expenditures for each appliance is totaled to get the total number of measures installed to the percentage of expenditures for each appliance is totaled to get the total number of measures installed to the percentage of expenditures for each appliance is totaled to get the total number of measures installed to the percentage of expenditures for each appliance is totaled to get the total number of measures installed to the percentage of expenditures for each appliance is totaled to get the total number of measures installed to the percentage of expenditures for each appliance is totaled to get the total number of measures installed to get the percentage of expenditures for each application and the per

Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

impacts from communications are required by As-inches cut. 2. The winter impacts exceed summer occasion required association measure replacements of swellings was electric near.

"The field in market of idvallions may exceed the number of measures included in cases where the utility notability funds refliciencing measure replacements." The procreation of expreditions for each application of measures included in a cases where the utility notability funds refliciencing measure replacements. The procreation of expreditions for each application of measures included in a case where the utility to addition measures included.

Total Reported Labor, Materials and Utility Admin Expenditures: \$10,870,884

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$10,870,884

Property of the property of		I N							Billing A	djusted F	rst-Year S	avings				Avera		Adjusted F			ınd Savin	gs		
Part		Number of Dweilings w	•			Spendin											1	Elect	ricity				L.	
Part	Measure	Total Electric Gas Pro																						
Control Cont	Total Efficiency Measures	1,251 1,247 1,049	104 14 2	1,218	1,247	4,370	,921 88.	4	101.4		324,984	783	75,404	28,672	1,932 3	5 3,494	0.073	0.0	81	261	0.75	72	276	138 17
STATE NO. 1985 1985 1985 1985 1985 1985 1985 1985	Total Shell & Htg. Sys. Repl																							
Contenting fine Contenting																								
Cache Cland 1																								
Contact 1	Cavity Fill Insul	134 90 83	21 3 0	87	8	92	,233 4.	4 5,322	3.7	5,671	10,994	38	3,548	1,174	93	688	0.051	61 0.4	59 70	9 122	0.46	43	56	31 -
The property of the property																								
Product Name 18				٠.																				
Purple Control Contr																								
Property belief Property Pr			62 9 0			36	,574 0.	0 0	2.2	3,424	3,424	6	599	541		204				5 285	0.07	6	9	4 -
Part																								
Contact Cont				948																				
Mary Control Mary				-	26						-, -,							0 0.0	93 14	3 143				
Control Spring Fine Spring Sp				- :	-												-	1 1		- :				
Call	Electric Htg Sys Repl			-								0	0	-	0						-		-	
The column The				-	11	62				1,716	1,716	0	0	0	0	5,720	0.000	0 0.1	02 15	6 156	-	-	-	
Marke Mark	Other Hig Sys Repi	0 0 0	0 0 0		U		0 0.	0 0	0.0	U	U	U	U	U	U	0	-				-		-	
Mary				Number o	f Measures Installed by Fuel_Ty	yp€								_			_							
Martine Gig 100 452 27 0 98 78 10 98 79 0 9 800 10 10 10 10 10 10 1		Total Electric Gas Pro		Total E	Fue lectric Gas Propane Oi	el il Other	•	er																
Mark Prop. 0		682 158 482			194 546 78	0 0 480	,107 0.	-	0.2		14,611	47.8				704	0.000	0.0	02	92	0.099			
Pige Train Sept				4									0	0		0	0.000	0.0	00	122	-	-	-	
Le Blowerheader 40 12 30 4 0 0 49 12 22 5 0 0 457 00 0 1 220 0 7 228 0 0 0 6 1 0 000 000 10 1 3 2 - 1																14	0.000	0.0	00	- 45	0.01	- 3	- 3	1 1
SEASE MY PER PEREL 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0		46 12 30		49	12 32 5		457 0.		0.1		2,229	0.7	228				0.000	0.0	04	186	0.02			
Machine 1985											1,026			-		0 8	0.000	0.0	01	64	0.01	3	2	
Expine Company Compa											6 277					0 0	- 0.000	- 0.0	na	- 00	- 0.11	- 10	- 26	
RefrigorationTreases 123 125 96 90 90,1703 62 5.8 5,1008			34 0 0																					
February February 3 3 4 4 60 0.3 0.2 2.04												-	-	-								-	-	
Freezer Penerous 3 3 3 3 3 8 80 02 02 1706 27 073 0.088 59	Refrigerator Removal											-	-	-									-	
Freeze Extrarge 34 34 34 31 31 31 44,327 2.1 2.9 17.06						46						-	-	-									-	
Misc Installation Signature Signat						14																		
Misc Installation Signature Signat	T. (11)	1 4 055				0.400	000									5 470								
Duct Inculation																								
Damming Material																								
Hig. Sys. Tune & Clear Hig. Sys. Tune & Clear Hig. Sys. Med Difference of the Control of the Con																								
Hg. Sys./WH-Ofber 310																								
Water Header Required 118 14,173 120 14,173 120 14,173 120 14,173 120 14,173 120 14,173 120 14,173 120 14,173 120 14,173 120 14,173 120 14,173 120 14,173 120 14,173 120 14,174 1		310				170	,738									551								
Refrigerator Coil Cleam Valenteed Matters Pard O O O O O O O O O O O O O																								
Walerbed Mattress Pad 0						14										120								
Unspecified Utility Meas 0 0 0 0 0 0 0 0 0																0								
CO Detector							0									0								
Smoke Detector 58 Fuses 10 1,130 113 Hig Sys Safety Check 1 65 85 Hig Sys Ventilation 33 68,818 210 Water Heater Ventilation 203 33,453 165 Bathroom Ventilation 489 81,874 167 Oper ventilation 35 86,26 107 Kitchen Ventilation 43 43 Abestors Removal (Minor) 20 68,279 1,311 Heatin/Safety Repairs 86 43 43 Heatin/Safety Other 137 10,199 74 Consumables 382 16,630 44 Consumables 382 16,630 44 General Repairs 44 666 Meter Refing (no action) 86,82 68,155 686 Meter Refing (no action) 82 38,487 9 Tamportation Allowance 23 38,487 139 Tamportation Mac 23 2,260 1,236<																0								
Fuses 10 1,130 1,130 1,130 1,130 1,130 1,131 1,130 1,131 1,130 1,131 1,130 1,1																72 58								
Hig Sys Ventilation 333 68,818 210 Water Heater Ventilation 203 33,453 165 Bathroom Ventilation 489 167 Dryer Ventilation 835 167 Kitchen Ventilation 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0																113								
Water Feater Ventilation 203 33.453 165 Bathroom Ventilation 489 81.874 167 Dyer Ventilation 0 0 0 Kitchen Ventilation 0 0 0 Other Exhaust Ventilation 434 43 43 Asbestos Removal (Minor) 20 22 2.62.29 1,311 Health/Safety Repairs 806 43 43 Health/Safety Other 137 10,199 74 Consumables 382 16,630 44 General Repairs 949 600,155 606 Meter Refig (no action) 688 0 0 Support 1,223 3,984,827 3,256 Transportation Allowance 253 3,984,827 3,256 Transportation Allowance 253 3,244 139 Landiord Contri Furnace 0 0 0 Landiord Contri Furnace 0 0 0 Landiord Contri Furnace 0 0 <td< td=""><td></td><td>1</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>85</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></td<>		1														85								
Bathroom Ventilation 489 81.874 167 Dyer Ventilation 8355 89.626 107 Kitchen Ventilation 0 0 0 Other Exhaust Ventilation 20 0 0 Asbestos Removal (Minor) 20 1,311 437 Asbestos Removal (Minor) 20 1,311 441 Health/Safety Repairs 806 541 441 Health/Safety Other 137 10,199 74 Consumables 382 16,630 44 General Repairs 949 660,155 696 Meter Freezer (no action) 688 0 0 Meter Freezer (no action) 262 0 0 Support 1,223 3,884,827 3,258 Transportation Allowance 253 3,584,827 3,384,827 Transportation Allowance 253 3,254 1,39 Landiord Contr Furnace 0 0 0 Landiord Contr Furnace 0 0 0																								
Kitchen Ventilation 0																167								
Other Exhaust Ventilation 434 18,705 43 Absetsor Removal (Minor) 20 13,71 435,763 541 Health/Safety Repairs 806 435,763 541 Health/Safety Other 137 10,199 74 Consumables 382 16,630 44 General Repairs 949 680,155 686 Meter Refrig (no action) 688 0 0 Meter Freezer (no action) 262 0 0 Support 1,223 3,984,827 3,258 Transportation Allowance 1,223 3,984,827 3,258 Transportation Misc 1 (2,000) -2,000 Landlord Contr Furnace 0 0 0 Landlord Contr Furnace 0 0 0 Landlord Contr DHW 0 0 0 Clear Safe Work 819 0 0						89	,626									107								
Asbestos Removal (Minor)						40										0								
Health/Safety Repairs 806																								
Consumables 382 16,630 44 General Repairs 949 660,155 696 Meter Refrig (no action) 68 0 0 Meter Freezer (no action) 282 0 0 Support 1,225 3,984,827 3,256 Transportation Allowance 253 35,244 139 Landiord Contr Misc 1 (2,000) -2,000 Landiord Contr Furnace 0 0 0 Landiord Contr DHW 0 0 0 Client Contr (Any) 0 0 0 Lead Safe Work 819 255,607 306	Health/Safety Repairs	806				435	,763									541								
General Repairs 949 660,155 696 Meter Refrig (no action) 688 0 0 Meter Freezer (no action) 262 0 0 Support 1,223 3,984,827 3,258 Transportation Allowance 253 35,244 139 Landlord Contr Misc 1 (2,000) -2,000 Landlord Contr Furnace 0 0 0 Landlord Contr DHW 0 0 0 Client Contr (Any), 0 0 0 Lead Safe Work 819 255,607 306																								
Meter Ferfig (no action) 688 0 0 Meter Freezer (no action) 262 0 0 Support 1,228 3,984,827 3,258 Transportation Allowance 253 35,244 139 Landlord Contr Misc 1 (2,000) -2,000 Landlord Contr Furnace 0 0 0 Landlord Contr DHW 0 0 0 Client Contr (Any) 0 0 0 Lead Safe Work 819 255,607 306						16 660	,630 .155									44 696								
Meter Freezer (no action) 262 0 0 Support 1,223 3,984,827 3,258 Transportation Allowance 253 35,244 139 Landinor Contr Misc 1 (2,000) -2,000 Landinor Contr Furnace 0 0 0 Landior Contr DHW 0 0 0 Client Contr (Any) 0 0 0 Lead Safe Work 819 255,607 306	Meter Refrig (no action)	688				000										0								
Transportation Allowance 253 35,244 139 Landiord Contr Misc 1 (2,000) -2,000 Landiord Contr Furnace 0 0 0 Landiord Contr Furnace 0 0 0 Client Contr (Anry) 0 0 0 Lead Safe Work 819 252,607 308	Meter Freezer (no action)	262					0									0								
Landlord Contr Misc 1 (2,000) Landlord Contr Furnace 0 0 Landlord Contr DHW 0 0 Client Contr (Any) 0 0 Lead Safe Work 819 255,607		II 1.223														3,258								
Landlord Contr Furnace 0 0 Landlord Contr DHW 0 0 Client Contr (Any) 0 0 Lead Safe Work 819 252,607 308		252															1							
Client Contr (Any) 0 0 Lead Safe Work 819 252,607 308	Transportation Allowance	253 1																						
Lead Safe Work 819 252,607 308	Transportation Allowance Landlord Contr Misc	1					,000)																	
Lospecific/Other 0 0 0 0 0	Transportation Allowance Landlord Contr Misc Landlord Contr Furnace Landlord Contr DHW	1 0 0					,000) 0																	
	Transportation Allowance Landlord Contr Misc Landlord Contr Furnace Landlord Contr DHW Client Contr (Any)	1 0 0 0				(2	,000) 0 0 0									-2,000 0 0								

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

The total number of dwellings ma Dalhoff Associates, LLC

Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

repacts from continuous examins train's required by Assirtives 622. In the winter impacts exceed summer decause traines also indusine nearing season impacts for desiring summer required by Assirtives 622. In the winter impacts exceed summer decause traines also indusine nearing season impacts for desirings winter exercise near.

The follar jumple of desirings many exceed the number of measures installed in cases where the full filt anniable (incase where the full filt) anniable (incase repaired) (indicate frincipation).

Total Reported Labor, Materials and Utility Admin Expenditures: \$2,911,284

Utility Administration Expenditures: \$139,762

Total Labor and Material Expenditures: \$2,771,522

	Numbe	r of Dwel	llings	Number	of Dwellings			ı	Billing A	Adjusted F	irst-Year S	avings		Averag				t Year C		nd Savin	gs
		with Impact			tricity Impacts	Spending on		E	lectricity			1	Gas	Spending on	po. 2.		Electricit			G	as
Measure	Total	Electric	Gas	Seas Cooling		Materials & Labor (\$)	Sum kW	mer kWh	Wi kW	inter kWh	Annual kWh	Pk-Day therms	Annual therms	Materials & Labor (\$)	Sum kW	mer kWh	Win kW	iter kWh	Annual kWh	Pk-Day therms	Annual therms
Total Efficiency Measures	621	549	380	545	549	2,286,936	111.2		95.5		381,713	826	79,909	3,683	0.204		0.174		695	2.17	210
Total Shell & Htg. Sys. Repl	601	530	378	488	528	1,814,359	95.5	115,198	72.2	110,668	225,866	779	71,736	3,019	0.196	236	0.137	210	426	2.06	190
Total Shell Measures	601	530	378	488	527	1,170,169	95.5	115,198	71.6	109,830	225,028	490	45,210	1,947	0.196	236	0.136	208	425	1.30	120
Wall Insul.	332	273	229	273	11	441,480	35.7	43,112	9.3	14,154	57,266	177	16,336	1,330	0.131	158	0.847	1,287	210	0.77	71
Open Blown Ceiling Insul. Cavity Fill Insul.	467 103	396 79	302 79	395 79	24 3	265,322 70,044	37.7 4.1	45,467 4.895	25.0 2.1	38,112 3.268	83,579 8.163	156 36	14,449 3,257	568 680	0.095	115 62	1.043	1,588 1.089	211 103	0.52 0.45	48 41
Sloped Attic Insul.	163	135	118	135	5	66,930	6.8	8,180	2.1	4,359	12,538	47	4,358	411	0.051	61	0.568	872	93	0.40	37
Kneewall Insul.	137	110	94	109	6	49,651	2.9	3,515	2.9	4,589	8,104	16	1,462	362	0.027	32	0.490	765	74	0.17	16
Infil. Reduction	458	375	330	374	28	163,118	3.6	4,314	3.1	4,708	9,023	29	2,678	356	0.010	12	0.111	168	24	0.09	8
Found./Crawl. Insul.	200	80	158	76	10	82,467	4.7	5,714	3.0	4,569	10,284	21	1,948	412	0.062	75	0.305	457	129	0.14	12
Bandjoist Insul.	146	14	132	-	14	31,156	0.0	0	1.7	2,555	2,555	9	855	213	0.000	0	0.119	183	183	0.07	6
Furnace Blower Fan	569	498	378	-	498	0	0.0	0	21.6	33,516	33,516	(1)	(132)	0	0.000	0	0.043	67	67	(0.00)	(0)
Exhaust Ventilation	0	0	0	0	0	0	0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	-
Total Heating System Repl	254	8	246	-	8	644,190	0.0	0	0.6	838	838	290	26,526	2,536	0.000	0	0.070	105	105	1.18	108
Condensing Htg Sys Repl Non-Cond Htg Sys Repl	246 0	0	246 0	-	-	618,650 0	0.0	0	0.0	0	0	290 0	26,526 0	2,515	-	-	-	-	-	1.18	108
Electric Htg Sys Repl	6	6	0		- 6	18,540	0.0	0	0.5	761	761	0	0	3,090	0.000	- 0	0.084	127	127		
Heat Pump Repl	2	2	Ö	-	2	7,000	0.0	0	0.1	77	77	0	0	3,500	0.000	0	0.026	39	39	-	-
Other Htg Sys Repl	0	0	0	-	0	0	0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	-
				by	per of Measures		Summer		Winter		Annual	Pk-Day	Annual		Summer		Winter		Annual	Pk-Day	Annual
<u></u>	Total	Electric	Gas	Total	Electric Gas		kW		kW		kWh	therms	therms		kW		kW		kWh	therms	therms
Water Heating	429	153	276	800	221 578		0.0		0.2		15,679	47.0	8,174	897	0.000		0.002		102	0.170	30
Temp. Reduct. WH Wrap	1 0	1	0	1 0	1 0	0	0.0 0.0		0.0		115 0	0.0	0	0	0.000		0.000		115	-	-
Pine Insul	354	141	213	354	141 213		0.0		0.0		6,313	1.8	612	11	0.000		0.000		45	0.01	- 3
LF Showerhead	48	13	35	48	13 35	293	0.0		0.1		2,491	0.8	242	6	0.000		0.004		192	0.02	7
Faucet Aerator	101	17	84	134	20 114	322	0.0		0.0		681	0.5	154	3	0.000		0.001		40	0.01	2
Std-Eff Wtr Htr Repl.	0	0	0	0	0 0	0	0.0		0.0		0	0.0	0	0					-		
Hi-Eff or Electric Wtr Htr Repl.	289	52	237	263	46 216		0.0		0.2		6,079	43.9	7,166	1,315	0.000		0.003		117	0.19	30
Lighting Refrigerator/Freezer ³	361 97	361 97		3,139 99	3,139	16,614 71,261	9.3		17.1 6.0		88,279 51,888	-	-	46 735	0.026		0.047		245 535	-	-
Refrigerator Removal	97	97 1		1	99 1	40	6.4 0.1		0.1		51,888	-	-	735	0.063		0.059		512	-	
Refrigerator Exchange	92			87	87	65,962	5.6		5.2		45,279			717	0.061		0.057		492		
Freezer Removal	0	0		0	0	0	0.0		0.0		0	-	-	0	-		-		-	-	-
Freezer Exchange	11	11		11	11	5,260	8.0		0.7		6,098	-	-	478	0.068		0.064		554	-	-
Total Non-Efficiency Measures	620					484,586								782							
Misc Ins,Attic Access/Vent	202					30,937								153							
Duct Sealing	19					4,213								222							
Duct Insulation	6					692								115							
Damming Material	0					0 433								0							
Htg. Sys. Tune & Clean Htg. Sys./WH Other	80 0					8,132 0								102 0							
Air Conditioning Work	0					ő								0							
Water Heater Repair	0					0								0							
Refrigerator Coil Clean	0					0								0							
Waterbed Mattress Pad	0					0								0							
Programmable Tstat	38 0					3,667								97 0							
Unspecified Utility Meas. CO Detector	0					0	-							0							
Smoke Detector	0					ő								ő							
Fuses	0					0								0							
Htg Sys Safety Check	0					0								0							
Htg Sys Ventilation	221					35,071								159							
Water Heater Ventilation Bathroom Ventilation	207					26,430 0								128 0							
Dryer Ventilation	0					0								0							
Kitchen Ventilation	ő					ő								ő							
Other Exhaust Ventilation	0					0								0							
Asbestos Removal (Minor)	0					0								0							
Health/Safety Repairs	66					3,884								59							
Health/Safety Other Consumables	0					0								0							
General Repairs	377					98,514								261							
Meter Refrig (no action)	121					96,514	 							0							
Meter Freezer (no action)	39					ő								ő							
Support	611					273,046								447							
Transportation Allowance	0					0								0							
Landlord Contr Misc	0					0								0							
Landlord Contr Furnace Landlord Contr DHW	0					0								0							
Client Contr (Any)	0					0								0							
Lead Safe Work	0					0								0							
Unspecifed/Other	0					0								0							

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

² Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

³ The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Alliant - Interstate Power and Light Billing Adjusted Impacts for All Customers of the Utility From All Funding Sources

With Impacts Value Value	Gas Annual therms 236 212 128 73 48 42 37 16 15 12
Total Shell & Htg. Sys. Repl 650 571 394 562 570 104.6 117,744 88.1 134,903 252,647 907 83,429 0.186 210 0.155 237 442 2.30 Total Shell Measures 650 571 394 562 570 104.6 117,744 86.7 132,753 250,496 547 50,439 0.186 210 0.152 233 439 1.39 Wall Insul. 355 288 245 288 11 38.1 45,910 9.5 14,430 60,340 193 17,837 0.132 159 0.863 1,312 210 0.79 Open Blown Ceiling Insul. 501 419 321 418 25 40.1 48,320 25.9 39,503 87,822 167 15,491 0.096 116 1.037 1,580 210 0.52 Cavity Fill Insul. 113 83 86 83 3 4.3 5,152 2.1	212 128 73 48 42 37 16 15
Total Shell & Htg. Sys. Repl 650 571 394 562 570 104.6 117,744 88.1 134,903 252,647 907 83,429 0.186 210 0.155 237 442 2.30 Total Shell Measures 650 571 394 562 570 104.6 117,744 86.7 132,753 250,496 547 50,439 0.186 210 0.152 233 439 1.39 Wall Insul. 355 288 245 288 11 38.1 45,910 9.5 14,430 60,340 193 17,837 0.132 159 0.863 1,312 210 0.79 Open Blown Ceiling Insul. 501 419 321 418 25 40.1 48,320 25.9 39,503 87,822 167 15,491 0.096 116 1.037 1,580 210 0.52 Cavity Fill Insul. 113 83 86 83 3 4.3 5,152 2.1	212 128 73 48 42 37 16 15
Total Shell Measures 650 571 394 562 570 104.6 117,744 86.7 132,753 250,496 547 50,439 0.186 210 0.152 233 439 1.39 Wall Insul. 355 288 245 288 11 38.1 45,910 9.5 14,430 60,340 193 17,837 0.132 159 0.863 1,312 210 0.79 Open Blown Ceiling Insul. 501 419 321 418 25 40.1 48,320 25.9 39,503 87,822 167 15,491 0.096 116 1.037 1,580 210 0.52 Cavity Fill Insul. 113 83 86 83 3 4.3 5,152 2.1 3,268 8,420 39 3,616 0.051 62 0.698 108 10 0.46 Sloped Attic Insul. 178 144 128 144 5 7.4 8,874 2.8 4,359	128 73 48 42 37 16 15
Total Shell Measures 650 571 394 562 570 104.6 117,744 86.7 132,753 250,496 547 50,439 0.186 210 0.152 233 439 1.39 Wall Insul. 355 288 245 288 11 38.1 45,910 9.5 14,430 60,340 193 17,837 0.132 159 0.863 1,312 210 0.79 Open Blown Ceiling Insul. 501 419 321 418 25 40.1 48,320 25.9 39,503 87,822 167 15,491 0.096 116 1.037 1,580 210 0.52 Cavity Fill Insul. 113 83 86 83 3 4.3 5,152 2.1 3,268 8,420 39 3,616 0.051 62 0.699 1,089 101 0.46 Sloped Attic Insul. 178 144 128 144 5 7.4 8,874 2.8 4,589	73 48 42 37 16 15
Open Blown Ceiling Insul. 501 419 321 418 25 40.1 48,320 25.9 39,503 87,822 167 15,491 0.096 116 1.037 1,580 210 0.52 Cavity Fill Insul. 113 83 86 83 3 4.3 5,152 2.1 3,268 8,420 39 3,616 0.051 62 0.699 1,089 101 0.46 Sloped Attic Insul. 178 144 128 144 5 7.4 8,874 2.8 4,359 13,232 51 4,757 0.051 62 0.568 872 92 0.40 Kneewall Insul. 146 115 98 114 6 3.0 3,643 2.9 4,589 8,232 17 1,541 0.026 32 0.490 765 72 0.17 Infil. Reduction 628 528 393 527 30 7.8 9,461 5.0 7,564 17,025	48 42 37 16 15
Cavity Fill Insul. 113 83 86 83 3 4.3 5,152 2.1 3,268 8,420 39 3,616 0.051 62 0.699 1,089 101 0.46 Sloped Attic Insul. 178 144 128 144 5 7.4 8,874 2.8 4,359 13,232 51 4,757 0.051 62 0.568 872 92 0.40 Kneewall Insul. 146 115 98 114 6 3.0 3,643 2.9 4,589 8,232 17 1,541 0.026 32 0.490 765 72 0.17 Infil. Reduction 628 528 393 527 30 7.8 9,461 5.0 7,564 17,025 64 5,899 0.015 18 0.166 252 32 0.16	42 37 16 15 12
Sloped Attic Insul. 178 144 128 144 5 7.4 8,874 2.8 4,359 13,232 51 4,757 0.051 62 0.568 872 92 0.40 Kneewall Insul. 146 115 98 114 6 3.0 3,643 2.9 4,589 8,232 17 1,541 0.026 32 0.490 765 72 0.17 Infil. Reduction 628 528 393 527 30 7.8 9,461 5.0 7,564 17,025 64 5,899 0.015 18 0.166 252 32 0.16	37 16 15 12
Kneewall Insul. 146 115 98 114 6 3.0 3,643 2.9 4,589 8,232 17 1,541 0.026 32 0.490 765 72 0.17 Infil. Reduction 628 528 393 527 30 7.8 9,461 5.0 7,564 17,025 64 5,899 0.015 18 0.166 252 32 0.16	16 15 12
Infil. Reduction 628 528 393 527 30 7.8 9,461 5.0 7,564 17,025 64 5,899 0.015 18 0.166 252 32 0.16	15 12
	12
Found/Oracid Institute	
Found./Crawl. Insul. 222 89 171 84 11 5.2 6,313 3.1 4,641 10,954 23 2,055 0.062 75 0.281 422 123 0.13	
Bandjoist Insul. 159 14 145 - 14 0.0 0 1.7 2,579 2,579 10 937 0.000 0 0.120 184 184 0.07	6
Furnace Blower Fan 612 533 394 - 533 0.0 0 46.4 71,514 71,514 (2) (211) 0.000 0 0.087 134 134 (0.01)	(1)
Exhaust Ventilation 466 402 286 402 402 -1.2 (9,929) (12.8) (19,693) (29,622) (16) (1,483) -0.003 (25) (0.032) (49) (74) (0.06)	(5)
Total Heating System Repl 283 15 268 - 15 0.0 0 1.4 2,151 2,151 360 32,990 0.000 0 0.095 143 143 1.34	123
Condensing Htg Sys Repl 260 0 260 0.0 0 0.0 0 328 29,994 1.26	115
Non-Cond Htg Sys Repl 25 0 25 0.0 0 0.0 0 0 32 2,996 1.29	120
Electric Htg Sys Repl 12 12 0 - 12 0.0 0 1.2 1,738 1,738 0 0 0 0.000 0 0.096 145 145 -	-
Heat Pump Repl 3 3 0 - 3 0.0 0 0.3 412 412 0 0 0.000 0 0.090 137 137 -	-
Other Htg Sys Repl 0 0 0 - 0 0.0 0 0 0 0 0	-
Number of Measures	
by Fuel Type Summer Winter Annual Pk-Day Annual Summer Winter Annual Pk-Day Total Electric Gas Total Electric Gas kW kW kWh therms therms kW kW kWh therms	Annual therms
Water Heating 463 172 291 0 0 0.0 0.3 17,969 54.6 9,494 0.000 0.002 104 0.188	33
Temp. Reduct. 1 1 0 0 0 0 0.0 0.0 115 0.0 0 0.000 0.000 115 -	
WH Wrap 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	_
Pipe Insul. 418 160 258 0 0 0 0.0 0.0 7,137 2.1 743 0.000 0.000 45 0.01	3
LF Showerhead 50 12 38 0 0 0 0.0 0.1 2,272 0.9 262 0.000 0.004 189 0.02	7
Faucet Aerator 104 17 87 0 0 0 0.0 0.0 706 0.5 161 0.000 0.001 42 0.01	2
Std-Eff Wtr Htr Repl. 0 0 0 0 0 0 0 0.0 0.0 0 0 0 0 0 0 0 0	
Hi-Eff or Electric Wtr Htr Repl. 307 59 248 0 0 0 0.0 0.2 7,738 51.0 8,327 0.000 0.003 131 0.21	34
Lighting 374 374 0 0 0 9.5 17.5 90,440 0.025 0.047 242 -	-
Refrigerator/Freezer ³ 113 113 0 0 8.2 7.6 66.520 0.072 0.068 589 -	-
Refrigerator Removal 2 2 0 0 0 0.1 0.1 1,023 0.063 0.059 512 -	-
Refrigerator Exchange 97 97 0 0 6.2 5.8 50,650 0.064 0.060 522 -	-
Freezer Removal 1 1 0 0 0.1 0.1 545 0.067 0.063 545 -	-
Freezer Exchange 25 25 0 0 1.8 1.6 14,302 0.070 0.066 572 -	<u>-</u>

Total Reported Labor, Materials and Utility Admin Expenditures: \$552,679

Utility Administration Expenditures: \$25,479

Total Labor and Material Expenditures: \$527,200

	Numbe	er of Dw	ellings	Number	r of Dwellings			Billing Adjus	sted Fi	rst-Year S	avings		Avera			ted First Year Receiving Me		nd Savir	gs
	,	with Impa	cts	with Elec	tricity Impacts on	Spending on Materials	Summer	Electricity Winter		Annual	Pk-Day	Gas Annual	Spending on Materials	Summ	ner	Electricity Winter		Pk-Day	Sas Annual
Measure	Total	Electric	Gas	Cooling	Heating	& Labor (\$)	kW kV	Vh kW kV	V h	kWh	therms	therms	& Labor (\$)	kW	kWh	kW kWh	kWh	therms	therms
Total Efficiency Measures	113	(113	0	0	435,514	0.0	0.0		0	198	19,275	3,854	-		-	-	1.75	171
Total Shell & Htg. Sys. Repl	111	() 111	0	0	355,706	0.0	0 0.0	0	0	186	17,170	3,205	-	-		-	1.67	155
Total Shell Measures	111	(0	0	188,230	0.0	0 0.0	0	0	107	9,965	1,696	-	-		-	0.97	90
Wall Insul.	56	(0	69,502	0.0	0.0	0	0	41	3,754	1,241	-	-		-	0.72	67
Open Blown Ceiling Insul.	82			0	0	42,298	0.0	0 0.0	0	0	24	2,204	516	-	-		-	0.29	27
Cavity Fill Insul.	17	(0	10,920	0.0	0 0.0	0	0	12	1,100	642	-	-		-	0.69	65
Sloped Attic Insul.	25		25		0	13,684	0.0	0 0.0	0	0	12	1,155	547	-	-		-	0.50	46
Kneewall Insul. Infil. Reduction	25 65) 25) 65	0	0	9,785 18,814	0.0	0 0.0 0 0.0	0	0	4 6	395 536	391 289	-	-			0.17	16 8
Found./Crawl. Insul.	31	(0	0	16,801	0.0	0 0.0	0	0	6	525	542	-				0.09	17
Bandjoist Insul.	33		33		0	6,426	0.0	0 0.0	0	0	3	321	195	_	-			0.10	10
Furnace Blower Fan ¹	111		111		0	0	0.0	0 0.0	0	0	(0)		0					(0.00)	(0)
Exhaust Ventilation	0) ()	0	0	0	0.0	0 0.0	0	0	0	(24)	0	_	_		_	(0.00)	(0)
Total Heating System Repl	66				0	167,476	0.0	0 0.0	0	0	78	7,205	2,538					1.19	109
Condensing Htg Sys Repl	66				-	167,476	0.0	0 0.0	0	0	78	7,205	2,538					1.19	109
Non-Cond Htg Sys Repl	0				-	0	0.0	0 0.0	0	0	0	0,200	2,000	_	_			-	-
Electric Htg Sys Repl	ō		0	-	0	ō	0.0	0 0.0	ō	0	0	0	ō	-	-		-	-	-
Heat Pump Repl	0		0 0		0	0	0.0	0.0	0	0	0	0	0	-	-		-	-	-
Other Htg Sys Repl	0	(0	-	0	0	0.0	0 0.0	0	0	0	0	0	-	-		-	-	-
					ber of Measures / Fuel Type		Summer	Winter		Annual	Pk-Day	Annual		Summer		Winter	Annual	Pk-Day	Annual
	Total	Electric		Total	Electric Gas		kW	kW		kWh	therms	therms		kW		kW	kWh	therms	therms
Water Heating	77	(0 14		0.0	0.0		0	12.0	2,105	1,036	-		-	-	0.156	27
Temp. Reduct.	0	(0		0 0	0.0	0.0		0	0.0	0	0	-		-	-	-	-
WH Wrap	0		0	0		0 0	0.0	0.0		0	0.0	0	0	-		-	-	-	-
Pipe Insul. LF Showerhead	67 8		67	67 8		7 1,082 8 66	0.0 0.0	0.0 0.0		0	0.6 0.2	196 55	16 8	-		-	-	0.01	3 7
Faucet Aerator	15	(2 84	0.0	0.0		0	0.2	30	6	-		-	-	0.02	2
Std-Eff Wtr Htr Repl.	0) 13	0		0 0	0.0	0.0		0	0.0	0	0					- 0.01	
Hi-Eff or Electric Wtr Htr Repl.	56	Č		52		2 78,575	0.0	0.0		0	11.2	1,824	1,403	_		-		0.20	33
Lighting	0	- 0)	0	0	0	0.0	0.0		0		-	0	-		-	-	-	-
Refrigerator/Freezer ³	0	()	0	0	0	0.0	0.0		0		-	0			-	-	-	-
Refrigerator Removal	0	(0	0	0		0.0		0	-	-	0	-		-	-	-	-
Refrigerator Exchange	0)	0	0	0	0.0	0.0		0	-	-	0	-		-	-	-	-
Freezer Removal	0	()	0	0	0	0.0	0.0		0	-	-	0	-		-	-	-	-
Freezer Exchange	0)	0	0	0	0.0	0.0		0	-		0	-		-	-	-	
Total Non-Efficiency Measures	113					91,686							811						
Misc Ins,Attic Access/Vent	24					3,483							145						
Duct Sealing	0					0							0						
Duct Insulation	5					696							139						
Damming Material Htg. Sys. Tune & Clean	22					2,329							106						
Htg. Sys./WH Other	0					0							0						
Air Conditioning Work	ő					ő							0						
Water Heater Repair	0					0							0						
Refrigerator Coil Clean	0					0							0						
Waterbed Mattress Pad	0					0							0						
Programmable Tstat	0					0							0						
Unspecified Utility Meas.	0					0							0						
CO Detector	0					0							0						
Smoke Detector	0					0							0						
Fuses	0					0							0						
Htg Sys Safety Check Htg Sys Ventilation	64					12,633							197						
Water Heater Ventilation	50					9,344							187						
Bathroom Ventilation	0					9,344							0						
Dryer Ventilation	ő					0							o o						
Kitchen Ventilation	0					0							0						
Other Exhaust Ventilation	0					0							0						
Asbestos Removal (Minor)	0					0							0						
Health/Safety Repairs	11					903							82						
Health/Safety Other	0					0							0						
Consumables	0 52					0 12,432							0 239						
General Repairs	52					12,432							239						
Meter Refrig (no action) Meter Freezer (no action)	0					0							0						
Support Support	110					49,866							453						
Transportation Allowance	0					49,000							0						
Landlord Contr Misc	ő					ő							ő						
Landlord Contr Furnace	ō					0							0						
Landlord Contr DHW	0					0							0						
Client Contr (Any)	0					0							0						
Lead Safe Work	0				-	0							0						
Unspecifed/Other	0					0	1						0						

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

² Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The projection of executable of

Black Hills Energy Billing Adjusted Impacts for All Customers of the Utility From All Funding Sources

	Numbe	er of Dwe	llings	Numbe	er of Dwe	llings		Billing Adjusted First-Year Savings Average Billing Adjusted Savin per Dwelling Receiving Measur												
Measure	with Impacts Total Electric Gas			with Ele Sea Cooling		pacts	Sumi kW		Electricity W kW	inter kWh	Annual kWh	Pk-Day therms	Gas Annual therms	Sumr kW		Electricit Win kW	iter A		Pk-Day therms	as Annual therms
Total Efficiency Measures	145	0	144	0	1		0.0		0.0		218	305	29,698	0.000		0.000		218	2.12	206
Total Shell & Htg. Sys. Repl	144	0	144	0	0		0.0	0	0.0	0	0	287	26,640	_	-	-	-	-	1.99	185
Total Shell Measures	144	0	144	0	0		0.0	0		0	0		15,721	-	-	-	-	-	1.17	109
Wall Insul.	80	0	80	0	0		0.0	0	0.0	0	0	59	5,531	-	-	-	-	-	0.74	69
Open Blown Ceiling Insul.	114	0	114	0	0		0.0	0	0.0	0	0	38	3,567	-	-	-	-	-	0.34	31
Cavity Fill Insul.	25	0	25	0	0		0.0	0	0.0	0	0	15	1,447	-	-	-	-	-	0.62	58
Sloped Attic Insul.	41	0	41	0	0		0.0	0	0.0	0	0	20	1,859	-	-	-	-	-	0.48	45
Kneewall Insul.	33	0	33	0	0		0.0	0	0.0	0	0	5	508	-	-	-	-	-	0.17	15
Infil. Reduction	141	0	141	0	0		0.0	0	0.0	0	0	22	2,065	-	-	-	-	-	0.16	15
Found./Crawl. Insul.	47	0	47	0	0		0.0	0	0.0	0	0	10	948	-	-	-	-	-	0.22	20
Bandjoist Insul.	51	0	51	-	0		0.0	0	0.0	0	0	5	468	-	-	-	-	-	0.10	9
Furnace Blower Fan ¹	144	0	144	-	0		0.0	0	0.0	0	0	(1)	(69)	-	-	-	-	-	(0.01)	(0)
Exhaust Ventilation ²	115	0	115	0	0		0.0	0	0.0	0	0	(7)	(603)	-	-	-	-	-	(0.06)	(5)
Total Heating System Repl	94	0	94	-	0		0.0	0	0.0	0	0	118	10,918	-	-	-	-	-	1.26	116
Condensing Htg Sys Repl	88	0	88	-	-		0.0	0	0.0	0	0	112	10,349	-	-	-	-		1.27	118
Non-Cond Htg Sys Repl	6	0	6	-	-		0.0	0	0.0	0	0	6	570	-	-	-	-	-	1.03	95
Electric Htg Sys Repl	0	0	0	-	0		0.0	0	0.0	0	0	0	0	-	-	-	-	-	-	-
Heat Pump Repl	0	0	0	-	0		0.0	0	0.0	0	0	0	0	-	-	-	-	-	-	-
Other Htg Sys Repl	0	0	0	-	0		0.0	0	0.0	0	0	0	0	-	-	-	-	-	-	-
				Nun	nber of Me	asures														
			_		y Fuel Typ		Summer		Winter		Annual	Pk-Day	Annual	Summer		Winter			Pk-Day	Annual
Water Heating	Total 108	Electric	Gas 107	Total 0	Electric 0	Gas 0	kW		kW		kWh 218	therms 17.5	3,058	kW 0.000		kW		kWh 218	therms	therms
Temp. Reduct.	0	0	0	0	0	0	0.0		0.0		0	0.0	3,056	0.000		0.000		210	0.163	29
WH Wrap	0	0	0	0	0	0	0.0		0.0		0	0.0	0	-		-		-	-	-
Pipe Insul.	102	0	102	0	0	0	0.0		0.0		0	0.0	301	-		-		-	0.01	- 3
LF Showerhead	11	0	102	0	0	0	0.0		0.0		218	0.3	69	0.000		0.000		218	0.01	7
Faucet Aerator	16	0	16	0	0	0	0.0		0.0		0	0.2	31	0.000		0.000		- 210	0.02	2
Std-Eff Wtr Htr Repl.	0	0	0	0	0	0	0.0		0.0		0	0.0	0	_		-		-	0.01	_
Hi-Eff or Electric Wtr Htr Repl.	77	0	77	0	0	0	0.0		0.0		0	16.3	2,657	_		_		_	0.21	35
Lighting	0			0	0		0.0		0.0		0	-	-	_		-		_	-	-
Refrigerator/Freezer ³	0	0		0	0		0.0		0.0		0			_				-	-	_
Refrigerator Removal	0			0	0		0.0		0.0		0	-	-	-		-		-	-	-
Refrigerator Exchange	0	0		0	0		0.0		0.0		0	-	-	-		-		-	-	-
Freezer Removal	0	0		0	0		0.0		0.0		0	-	-	-		-		-	-	-
Freezer Exchange	0	0		0	0		0.0		0.0		0	-	-	-		-		-	-	

Total Reported Labor, Materials and Utility Admin Expenditures: \$2,546,650

Utility Administration Expenditures: \$95,340

Total Labor and Material Expenditures: \$2,451,309

Billing Adjusted First-Year Savings Average Billing Adjusted First Year Costs and Savings per Dwelling Receiving Measures Number of Dwellings **Number of Dwellings** with Impacts with Electricity Impacts Spending on Electricity Gas Spending on Electricity Season Materials Summer Winter Annual Pk-Day Annual Materials Winter Annual Pk-Day Annual & Labor (\$) kW kWh Measure Total Electric Gas Cooling Heating kW kWh kWh kWh therms therms & Labor (\$) kW kWh kW kWh therms therms **Total Efficiency Measures** 0.203 463 376 373 366 376 2,021,915 78.7 76.2 280,295 809 78,132 4,367 0.215 745 2.17 209 Total Shell & Htg. Sys. Repl 448 362 1.598.040 68.2 82.207 60.8 92.670 174.877 69.21: 188 363 369 317 759 3.567 0.215 259 0.168 256 482 2.06 Total Shell Measures 448 363 369 317 362 1.058.015 68.2 82.207 60.6 92.448 174.655 479 43.691 2,362 0.215 259 0.168 255 481 1.30 118 Wall Insul. 254 195 216 194 415.217 27.2 32.856 4.8 7.121 39.977 166 15.144 1,635 0.140 169 0.681 1.017 205 0.77 70 347 282 Open Blown Ceiling Insul 269 266 20 252.081 27.4 33.037 28.1 43.040 76.077 157 14.300 726 0.103 124 1.405 2.152 283 0.56 51 123 Cavity Fill Insul. 92 116 87.585 5.106 5.178 4.558 712 0.046 56 0.024 0.43 39 92 4.2 0.0 72 50 36 56 Sloped Attic Insul. 98 97 72 88 41,860 4,945 1.6 2,377 7,321 2,970 427 0.058 70 0.812 1,188 102 0.37 34 71 4.1 33 14 14 Kneewall Insul. 63 89 63 31,027 1,467 0.5 726 2,193 1,237 320 0.019 23 0.495 0.15 1.2 726 35 253 182 229 18 Infil. Reduction 92,030 2.0 2,426 0.6 923 3,349 22 2,062 364 0.011 13 0.087 132 0.10 Found./Crawl. Insul. 147 129 31 110,462 2.0 2,370 2.2 3,400 5,770 29 2,617 751 0.063 76 0.221 340 160 0.22 20 Bandjoist Insul. 143 131 12 27,754 1.9 2,889 2,889 10 0.158 241 241 0.08 Furnace Blower Fan 423 338 369 338 0.0 20.9 31 901 31,901 (1) (132) 0.000 0.062 94 (0.00) (0) Ω 94 Ω Exhaust Ventilation 0.0 0.0 Total Heating System Repl 230 228 540,025 0.0 0.1 222 222 280 25,521 2,348 0.000 1.23 Condensing Htg Sys Repl 228 228 533,777 0.0 280 25,521 2,341 1.23 Non-Cond Htg Sys Repl 0.0 0.0 Electric Htg Sys Repl 2 6,248 0.0 0.1 222 222 3,124 0.000 0 0.071 111 111 Heat Pump Repl 0.0 0.0 0 Other Htg Sys Repl 0.0 0.0 Number of Measures by Fuel Type Summe Winter Annual Pk-Dav Annual Summer Winter Annual Pk-Day **Annual** Total Electric Gas Total Electric Gas kW kW kWh therms therms kW kW kWh therms 364,547 Water Heating 380 303 886 149 737 0.0 0.2 11.490 49.9 8,919 959 0.000 0.002 149 0.165 29 Temp Reduct 0.0 0.0 115 0.0 0.000 0.000 115 0.02 WH Wrap 0 0.0 0.0 0.0 356 72 284 356 72 284 6.212 3.326 835 0.000 0.000 0.01 Pipe Insul. 0.0 0.0 2.4 17 46 LF Showerhead 84 66 99 23 924 0.0 0.1 3,538 1.5 475 0.000 0.004 197 76 11 0.02 Faucet Aerator 119 18 101 198 28 170 896 0.0 0.0 1,009 0.8 232 0.000 0.001 56 0.01 Std-Eff Wtr Htr Repl 0.0 0.0 0.0 Hi-Eff or Electric Wtr Htr Repl. 229 231 206 356,515 3.501 7,370 1,377 0.000 0.003 117 0.20 32 0.0 45.2 Lighting 275 275 2,497 16,680 5.9 10.9 56,277 61 0.021 0.040 205 Refrigerator/Freeze 66 71 42.647 4.6 4.3 37.652 646 0.070 570 66 71 0.066 Refrigerator Removal 0 0.0 Refrigerator Exchange 56 56 59 59 37.449 3.8 3.6 30.883 669 0.068 0.063 551 Freezer Removal 0.0 0.0 Freezer Exchange 5.198 6.769 433 0.069 0.065 564 Total Non-Efficiency Measures 468 429,395 Misc Ins,Attic Access/\ 118 13,588 Duct Sealing 25 6,661 266 Duct Insulation 10 3,766 377 Damming Material Htg. Sys. Tune & Clean 93 9,374 101 Htg. Sys./WH Other Air Conditioning Work Water Heater Repair 0 Refrigerator Coil Clean 0 0 Waterbed Mattress Pad 0 Programmable Tstat 44 4.350 99 0 Unspecified Utility Meas CO Detector 80 Smoke Detector 80 Fuses Htg Sys Safety Check Htg Sys Ventilation 216 37,888 175 Water Heater Ventilation 204 30,892 151 Bathroom Ventilation Dryer Ventilation Kitchen Ventilation Other Exhaust Ventilation Asbestos Removal (Minor) Health/Safety Repairs 51 3,017 59 0 Health/Safety Other Consumables 57,199 General Repairs 225 254 Meter Refrig (no action) Meter Freezer (no action) 21 Support 443 262.460 592 Transportation Allowance Landlord Contr Misc Landlord Contr Furnace 0 Landlord Contr DHW Client Contr (Any) Lead Safe Work 120 120 Unspecifed/Other

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

² Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

² The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

MidAmerican Energy Billing Adjusted Impacts for All Customers of the Utility From All Funding Sources

	Numbe	er of Dwe	llings		er of Dwe				Billing A	Adjusted I	First-Year	Average per Dw								
	v	vith Impact	ts	with Ele	ctricity Imp	pacts	Sur	Electricity Summer Winter Ann					Gas Annual	Summ		Electrici Wir	Annual	Pk-Day	Gas Annual	
Measure	Total	Electric	Gas	Cooling			kW			kWh	kWh	Pk-Day therms	therms	kW	kWh	kW	kWh	kWh	therms	therms
Total Efficiency Measures	567	472	467	471	472		110.2		106.2		375,762	1,221	118,083	0.234		0.225		796	2.61	253
Total Shell & Htg. Sys. Repl	567	472	467	461	471		96.5	108,123	86.0	131,062	239,185	1,141	104,064	0.209	235	0.183	278	507	2.44	223
Total Shell Measures	566	471	467	461	470		96.5	108,123	85.1	129,655	237,778	688	62,649	0.209	235	0.181	276	505	1.47	134
Wall Insul.	341	266	290	264	12		37.9	45,747	8.1	12,294	58,041	230	20,962	0.144	173	0.675	1,025	218	0.79	72
Open Blown Ceiling Insul.	448	352	371	348	25		36.0	43,373	33.3	50,891	94,264	209	18,957	0.103	125	1.333	2,036	268	0.56	51
Cavity Fill Insul.	180	133	169	133	4		6.4	7,776	0.6	993	8,769	75	6,881	0.048	58	0.161	248	66	0.45	41
Sloped Attic Insul.	133	100	118	99	4		5.4	6,470	1.9	2,734	9,203	43	3,953	0.054	65	0.463	683	92	0.37	33
Kneewall Insul.	131	91	117	91	4		1.9	2,236	1.2	1,821	4,057	18	1,612	0.020	25	0.307	455	45	0.15	14
Infil. Reduction	559	429	465	425	29		7.1	8,620	5.5	8,339	16,959	86	7,866	0.017	20	0.188	288	40	0.19	17
Found./Crawl. Insul.	199	53	177	47	12		3.0	3,565	2.5	3,902	7,467	39	3,541	0.063	76	0.211	325	141	0.22	20
Bandjoist Insul.	191	16	175	-	16		0.0	0	2.3	3,554	3,554	13	1,187	0.000	0	0.145	222	222	0.07	7
Furnace Blower Fan ¹	534	439	467	-	439		0.0	0	42.0	63,981	63,981	(3)	(274)	0.000	0	0.096	146	146	(0.01)	(1)
Exhaust Ventilation ²	465	392	378	392	392		-1.2	(9,663)	(12.4)	(18,853)	(28,516)	(22)	(2,037)	-0.003	(25)	(0.032)	(48)	(73)	(0.06)	(5)
Total Heating System Repl	328	8	320	-	8		0.0	0	0.9	1,407	1,407	453	41,415	0.000	0	0.115	176	176	1.42	129
Condensing Htg Sys Repl	292	0	292	-	-		0.0	0	0.0	0	0	381	34,715	-	-	-	-	-	1.30	119
Non-Cond Htg Sys Repl	54	0	54	-	-		0.0	0	0.0	0	0	72	6,701	-	-	-	-	-	1.34	124
Electric Htg Sys Repl	4	4	0	-	4		0.0	0	0.4	613	613	0	0	0.000	0	0.100	153	153	-	-
Heat Pump Repl	5	5	0	-	5		0.0	0	0.5	793	793	0	0	0.000	0	0.104	159	159	-	-
Other Htg Sys Repl	0	0	0	-	0		0.0	0	0.0	0	0	0	0	-	-	-	-	-	-	<u> </u>
				None																
				-	ber of Me		Summer		Winter		Ammuni	Pk-Day	A	Summer		Winter		Annual	Dir Dav	A
	Total	Electric	Gas		y Fuel Typ Electric	Gas	kW		kW		Annual kWh	therms	Annual therms	kW		kW		kWh	therms	Annual therms
Water Heating	493	88	405	0	0	0	0.0		0.2		14,187	79.2	14,019	0.000		0.003		161	0.195	35
Temp. Reduct.	2	1	1	0	0	0	0.0		0.0		115	0.0	7	0.000		0.000		115	0.02	7
WH Wrap	0	0	0	0	0	0	0.0		0.0		0	0.0	0	-		-		-	-	
Pipe Insul.	475	84	391	0	0	0	0.0		0.0		3,882	3.4	1,172	0.000		0.000		46	0.01	3
LF Showerhead	109	22	87	0	0	0	0.0		0.1		4,238	2.1	647	0.000		0.004		193	0.02	7
Faucet Aerator	170	19	151	0	0	0	0.0		0.0		1,075	1.2	375	0.000		0.001		57	0.01	2
Std-Eff Wtr Htr Repl.	0	0	0	0	0	0	0.0		0.0		0	0.0	0.0	-		-		-	-	
Hi-Eff or Electric Wtr Htr Repl.	359	35	324	0	0	0	0.0		0.1		4.877	72.4	11,817	0.000		0.003		139	0.22	36
Lighting	352	352		0	0		7.8		14.4		74,135	-	-	0.022		0.041		211	-	-
Refrigerator/Freezer ³	81	81		0	0		5.9		5.5		48,255	-	-	0.073		0.069		596	-	-
Refrigerator Removal	1	1		0	0		0.1		0.1		1,023	-	-	0.126		0.118		1,023	-	-
Refrigerator Exchange	68	68		0	0		4.7		4.4		38,110	_	-	0.069		0.064		560	-	-
Freezer Removal	1	1		0	0		0.1		0.1		679	-	-	0.084		0.078		679	-	-
Freezer Exchange	15	15		0	0		1.0		1.0		8,442	-	-	0.069		0.065		563	-	
Freezer Exchange	15	15		0	0		1.0		1.0		8,442	-	-	0.069		0.065		563	-	

This page intentionally left blank

4. DETAILED SPENDING AND IMPACT PROFILES BY AGENCY

This section provides tables of spending and impacts by agency for state and utility expenditures. Energy impacts were estimated according to the statewide algorithms, which include agency-specific adjustments.

Total Reported Labor, Materials and Utility Admin Expenditures: \$746,449

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$746,449

	1 1													Billing Adjusted First-Year Savings										Average Billing Adjusted First Year Costs and Savings											
	Numb	er of Dv	vellings	with Imp	oacts	Nι	ımber o	f Dwellir	gs with I	kWh Impa		pending on			Electricity	-		-	Gas			Spending on	per Dw	elling Re	eceivin ectricity	•	ures		as	1					
Measure	Total E	lectric	Gas Pr		Fuel Oil Otl	her Cooli	Season ing Heat	ting			l i	Materials Labor (\$)	Sum kW		Wir	nter kWh	Annual kWh				Fuel Oil Oth gallons Mb	er Materials	Summ kW	ner	Wint	ter .		Pk-Day therms	Annual therms		Fuel Oil Other gallons Mbtu				
Total Efficiency Measures	49	49	37	7	0	0	49	49				405,941	12.3		14.6		44,231	113	10,602	2,414	0	0 8,285	0.252		0.299		903	3.05	287	345					
Total Shell & Htg. Sys. Repl	49	49	37	7	0	0	48	49				362,082	11.3	13,126	13.0	19,932	33,059	109	9,953	2,327	0	0 7,389	0.235	273	0.266	407	675	2.95	269	332		-			
Total Shell Measures	49	49	37	7	0		48	49				219,240	11.3	13,126	12.9	19,779	32,905	60		1,365	0	0 4,474	0.235		0.264	404	672		149						
Wall Insul.	26	25	19	5	0		25 45	2				29,444	3.7	4,460	1.3	2,050	6,510	12		401	0	0 1,132 0 935			0.670	1,025	260	0.63	58						
Open Blown Ceiling Insul Cavity Fill Insul	46 13	45 13	36 9	2	0		45 12	2				43,030 11,202	3.8 0.7	4,643 794	3.5 0.7	5,340 1,097	9,983 1,891	14 4	1,286 372	398 60	0	0 935 0 862	0.086 0.055		1.164 0.359	1,780 548	222 145	0.39 0.45	36 41		1 1				
Sloped Attic Insul	29	28	20	5	0	0	27	4				13,996	1.7	1,991	1.7	2,602	4,593	11	988	183	0	0 483	0.061	74	0.426	651	164	0.54	49	37					
Kneewall Insul	16 49	15 48	13	2	0		15	1				6,531 62,780	0.4	491	0.2	329	820	3	250 771	42 95	0	0 408			0.215	329 136	55 34	0.21	19 21						
Found./Crawl. Insul	49 21	48 6	37 17	3	0	0	48 5	5				10,662	0.8	956 380	0.4 0.2	679 381	1,634 761	8 2		114	0	0 1,281 0 508			0.089 0.249	381	127		13		1 1				
Bandjoist Insul.	39	4	29	6	Ö	0 -		4				5,246	0.0	0	1.7	2,558	2,558	7	618	99		0 135			0.418	640	640	0.23	21	16					
Furnace Blower Fan ¹	44	44	37	7	0	0 -		44				0	0.0	0	4.0	6,096	6,096	(0)	(17)	(4)	0	0 0	0.000	0	0.091	139	139	(0.00)	(0	(1)					
Exhaust Ventilation	23	23	17	4	0		23	23				36,350	-0.1	(588)	(0.9)	(1,354)	(1,942)	(1)		(22)	0	0 1,580	-0.003		(0.039)	(59)	(84)	(0.06)	(5			_			
Total Heating System Repl Condensing Htg Sys Rep	41 40	0	34	6	0	0 -		1				142,841 136,252	0.0	0	0.1	154	154	49 49		962 962	0	0 3,484 0 3,406		0	0.101	154	154	1.44	131 131	160 160		_			
Non-Cond Htg Sys Repl	0	0	0	0	0	0 -		-				0	0.0	0	0.0	0	0	0	4,430	0	0	0 3,400	-	-	-	-	- :	-	-	-					
Electric Htg Sys Repl	1	1	0	0	0	0 -		1				6,589	0.0	0	0.1	154	154	0		0		0 6,589	0.000	0	0.101	154	154	-	-	-					
Heat Pump Repl Other Htg Sys Repl	0	0	0	0	0	0 -		0				0	0.0	0	0.0	0	0	0	0	0	0	0 0	-	-		-		-	-	-	1 1				
Galor ring Gya Nepi	,	U	U	U	v			Ū				J	0.0	U	0.0	U	U	0	0	U	U		-	-	-		-	1	-	<u> </u>		-			
					Fuel	Nun	nber of M	leasures I	stalled by	Fuel Type			Summer		Winter		Annual	Pk-Day	Annual	Propage	Fuel Oil Othe		Summer	w	Vinter		Annual	Pk-Day	Annual	Propage	Fuel Oil Other				
	Total E				Oil Ot				s Propa	ne Oil	Other		kW		kW		kWh	therms	therms	gallons	gallons Mb	u	kW		kW		kWh	therms	therms	gallons	gallons Mbtu				
Water Heating Temp. Reduct	48	20	25 0	3	0	0	57 0	23	31 0	0 0	0	39,542 0	0.0		0.0		1,814	3.9	649	87 0	0		0.000	-	0.002			0.155	26	29		_			
WH Wrap	0	0	0	0	0		0	0		0 0	0	0	0.0		0.0		0	0.0		0	0	0 0	-		-			- 1	- :	1					
Pipe Insul.	22	13	9	0	0		22	13	9	0 0	0	192	0.0		0.0		599	0.1	26	0	0	0 9	0.000		0.000		46	0.01	3	-					
LF Showerhead	1 5	1	0	0	0	0	1	1 2		0 0	0	9 24	0.0		0.0		218	0.0	0	0	0	0 9	0.000		0.005		218	0.01	- 2	-					
Faucet Aerator Std-Eff Wtr Htr Repl.	0	1 0	4	0	0		0	0		0 0	0	0	0.0		0.0		66 0	0.0		0	0	0	0.000		0.001		66	0.01	. 2	1	1 1				
Hi-Eff or Electric Wtr Htr Repl.	26	7	16	3	Ö	0	26	7	16	3 0	0	39,317	0.0		0.0		931	3.8			ő	0 1,512			0.003		133		38	29					
Lighting	43	43				2		269				1,153	0.6		1.2		6,122		-	-	-	- 27			0.028		142		-	-					
Refrigerator/Freezer ³ Refrigerator Removal	6	6					0	6				3,165	0.4		0.4		3,236	-	-	-		- 527	0.066	-	0.062		539	-		-					
Refrigerator Exchange	1	1					1	1				585	0.0		0.0		512		- :	-	-	- 585	0.063		0.059		- 512		- :	1					
Freezer Removal	0	0					0	0				0	0.0		0.0		0	-	-	-	-	- 0	-		-		-	-	-	-					
Freezer Exchange	5	5					5	5				2,580	0.3		0.3		2,725	-	-	-	-	- 516	0.067		0.063		545	-	-	-		_			
Total Non-Efficiency Measures	49											340,508										6,949													
Misc Ins,Attic Access/Ven	48 8											27,817 3,240										580 405													
Duct Insulation	19											3,856										203													
Damming Material	26											2,330										90													
Htg. Sys. Tune & Clean Htg. Sys./WH Other	8											1,337 6,999										167 778													
Air Conditioning Work	0											0,555										,,,													
Water Heater Repair	4											3,798										950													
Refrigerator Coil Clean Waterbed Mattress Pad	0											0																							
Programmable Tstat	0											0																							
Unspecified Utility Meas	0											0										C	4												
CO Detector Smoke Detector	48 38											2,606 594										54 16													
Fuses	0											0										"0													
Htg Sys Safety Check	0											0																							
Htg Sys Ventilation Water Heater Ventilation	39 19											8,797 3.617										226 190													
Bathroom Ventilation	11											1,834										167													
Dryer Ventilation	38											4,523										119													
Kitchen Ventilation Other Exhaust Ventilation	0 35											0 1,896										54													
Asbestos Removal (Minor)	0											0																							
Health/Safety Repairs	44											32,298										734	1												
Health/Safety Other Consumables	7											426 0										61	1												
General Repairs	49											42,874										875													
Meter Refrig (no action)	47											0										C]												
Meter Freezer (no action) Support	16 48											190,359										3,966	-												
Transportation Allowance	0											190,359										3,960													
Landlord Contr Misc	0											0										ď	1												
Landlord Contr Furnace	0											0										9													
Landlord Contr DHW Client Contr (Any)	0											0											1												
Lead Safe Work	10											1,306										131	1												
Unspecifed/Other	0											0											1												

Estimates are based upon reduced usage of the furnace due to shell improvements

Impacts from continuous exhaunt fore required by ASPARE 622. The writter impacts exceed summer because these also include healing season impacts for deellings with electric heat.

The botal number of deelings may exceed the number of measures installed in case where the utility partially furnish refrigeration measure replacements. The percentage of expenditures for each appliance is lotated to get the bold number of measures installed.

The bold number of deelings may exceed the number of measures installed.

Total Reported Labor, Materials and Utility Admin Expenditures: \$1,890,812

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$1,890,812

																											Total	Labor an	iu wateri	iai Exper	naitures:	\$1,890,8	12		
							1									Bill	ing Ad	djusted Fi	irst-Year S	avings					Averag	je Billing	Adjust	ed First	t Year (Costs a	nd Savin	gs			
	Νι	umber	of Dwe	ellings	with Imp	pacts		Number	of Dwe	ellings	vith kW	h Impacts														per Dw	-	Receivir	•	sures					
						Fuel		Seasor					Spending Material	on	Summer	Elec	tricity Wint	tor	Annual	Pk-Day	Gas Annual	Propane	Euol Oil	Othor	Spending on Materials	Sumn		Electricit Win		Annual	l Pk-Day	Sas Annual	Bronon	Fuel Oil Oth	
Measure	Total	Elect	ric G	as Pr	opane	Oil O	ther	Cooling H	eating				& Labor	\$) kW		Vh k		kWh	kWh	therms			gallons		& Labor (\$)	kW	kWh	kW			therms	therms		gallons Mb	
Total Efficiency Measures	123	1	123	110	8	1	0	123	123				970,8	67 20.8	8		20.7		82,079	240	23,515	2,229	235	0	7,893	0.169		0.168		667	2.18	21	4 27	235 -	
Total Shell & Htg. Sys. Repl	123			110	8	1	0	122	123				796,9				14.4	22,250	39,534	221	20,274	2,109		0	6,480	0.134	142	0.117	181	321	2.01	18		235 -	
Total Shell Measures Wall Insul.	123 57		123 49	110 52	8	1	0	122 49	123				641,8 145,1				14.3 0.9	21,973 1,437	39,258 8.457	151 40	13,911 3,720	847 341	155 74		5,218 2,546	0.134 0.119	142 143	0.116 0.933	179 1.437	319 173		12	6 10		
Open Blown Ceiling Insul	81		73	74	3	1	0	73	3				81,8				6.3	9,708	18,218	58					1,010	0.097	117	2.101	3,236			7			
Cavity Fill Insul	19		11	18	1	0	0	11	0				24,0	0.5		548	0.0	0	548	11	996	32			1,264	0.041	50	0.000	0		0.60	5	5 3:	2	
Sloped Attic Insul Kneewall Insul	24 31		18 24	22 28	0	1	0	18 24	1				15,7 15,3				0.5	773 156	1,536 720	7	652 398				656 494	0.035 0.019	42 23	0.502	773 156				0 -	19 -	
Infil. Reduction	123			110	8	1	ő	112	4				133,8	27 1.6			0.7	1,138	3,073	23					1,088	0.013	17	0.185	285	27	0.13		9 2		
Found./Crawl. Insul	58	3	13	52	3	1	0	12	2				48,8				0.6	869	1,620	13		139	5		843	0.052	63	0.282	435		0.24		2 4		
Bandjoist Insul. Furnace Blower Fan ¹	62 119		2	57 110	2 8	1	0	-	2 116				11,6	0.0			0.2 7.7	357 11,873	357 11,873	3					188	0.000	0	0.116	179 102				5 (_	
Exhaust Ventilation	118			105	8	1	0	- 118	118				165.3				(2.8)	(4.338)	(7.145)	(1)					1.401	-0.003		(0.024)						0) (0) - 7) (4) -	
Total Heating System Repl	60		2	52	5	1	0	-	2				155,1				0.2	276	276						2,586	0.000		0.090	138			12			
Condensing Htg Sys Rep	56		0	50	5	1	0	-	-				141,4				0.0	0	0	64	5,906	940	80		2,525	-	-	-	-	-	1.29	11			
Non-Cond Htg Sys Repl Electric Htg Sys Repl	4		0	3 0	0	0	0	-	- 2				6,6 7,1	63 0.0			0.0	276	0 276	5	457 0	322			1,653 3,582	0.000	- 0	0.090	138	138	1.66	15	2 32	2	
Heat Pump Repl	C		0	0	0	0	0	-	0				.,	0.0	0	0	0.0	0	0	0	0		0	0	0,002	-	-	-	-	-	-	-	-		
Other Htg Sys Repl	0)	0	0	0	0	0	-	0					0 0.0	0	0	0.0	0	0	0	0	0	0	0	0	-	-	-	-	-	-	-	-		
								Number o	f Measur	es Instal	led by F	uel Type																							
						Fuel					•	Fuel		Summe	er		nter		Annual	Pk-Day	Annual	Propane				Summer		Winter			Pk-Day	Annual		Fuel Oil Oth	
Water Heating	Total 122		ric G	85 Pr	ropane 3	Oil O	Other	Total E	lectric 43	Gas 164	Propane 6	Oil O	0 150,2	71 0.0	0		W 0.0		kWh 2,686	therms 19.0	3,241		gallons		1,232	kW 0.000		kW 0.001		kWh 79	0.223	therms	gallons 8 4	gallons Mb	tu
Temp. Reduct.	0		0	0	0	0	0	0	0	0	0	0	0 130,2	0 0.0			0.0		0	0.0	0,241	0	0	0	0	-		-		-	-	-	-		
WH Wrap	0		0	0	0	0	0	0	0	0	0	0	0	0 0.0			0.0		0	0.0	0		0		0			-				-	-		
Pipe Insul. LF Showerhead	122		34	85 1	3	0	0	122	34 0	85 1	3	0	0 2,2	61 0.0 10 0.0			0.0		1,498	0.8	272 11	11			19 10	0.000		0.000		44	0.01 0.04	1	3 -		
Faucet Aerator	d)	0	ó	ő	Ö	ő	ò	Ö	Ö	0	ő	Ö	0 0.0			0.0		0	0.0	0		ő		0	-		-		-	-	- '			
Std-Eff Wtr Htr Repl.	0		0	0	0	0	0	0	0	0	0	0	0	0.0			0.0		0	0.0	0				0	-		-		-	-	-	-		
Hi-Eff or Electric Wtr Htr Repl. Lighting	90		95	78	3	0	0	90 648	648	78	3	0	0 148,0				0.0 4.0		1,188 20,853	18.1	2,958	109	- 0	0	1,644 50	0.000		0.003		132 220	0.23	3	8 3		
Refrigerator/Freezer ³	33		33					36	36				18,8				2.2		19,005		-	-	-	-	572			0.066		576			-		
Refrigerator Removal	0		0					0	0					0 0.0			0.0		0	-	-	-	-	-	0					-	-	-	-		
Refrigerator Exchange Freezer Removal	26		26					26 0	26 0				15,4	96 1.7			1.6 0.0		13,556 0	-		1 1	- 1		596	0.064		0.060		521	-	- :	1 - 1		
Freezer Exchange	10		10					10	10				3,3				0.6		5,449	-		-	-	-	338	0.067		0.063		545		-	-		
Total Non-Efficiency Measures	123	,											919.9	AE											7.479										
Misc Ins,Attic Access/Ven	98												35,9												367										
Duct Sealing	74	ļ											21,2	:69											287										
Duct Insulation Damming Material	61 57	,											13,6 2.3	91											224 41										
Htg. Sys. Tune & Clean	68												6,												91										
Htg. Sys./WH Other	39												17,9												460										
Air Conditioning Work Water Heater Repair	13												1,7	85											85 138										
Refrigerator Coil Clean	ď												1,,	0											0										
Waterbed Mattress Pad	0													0											0										
Programmable Tstat Unspecified Utility Meas	0													0											0										
CO Detector	119)											11,5												97										
Smoke Detector Fuses	95	5											9,0	97											96 0										
Htg Sys Safety Check	d													0											0										
Htg Sys Ventilation	50												8,6												173										
Water Heater Ventilation Bathroom Ventilation	61												9,2	168 109											152 162										
Dryer Ventilation	64												6,1												96										
Kitchen Ventilation	0)												0											0										
Other Exhaust Ventilatior Asbestos Removal (Minor)	0												6.8	U 55											0 1,371										
Health/Safety Repairs	97												41,4	10											427										
Health/Safety Other	17												1,7	22											101										
Consumables General Repairs	97 112												7,7 108.2												80 966										
Meter Refrig (no action)	81												.00,2	0											0										
Meter Freezer (no action)	24	1											F 10.	0											0										
Support Transportation Allowance	123 93												540,9 15,8												4,398 170										
Landlord Contr Misc	0												15,6	0											0										
Landlord Contr Furnace	0													0											0										
Landlord Contr DHW Client Contr (Any)	0													0											0										
Lead Safe Work	98	3											52,4	23											535										
Unspecifed/Other	0													0											0										

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

³ The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Total Reported Labor, Materials and Utility Admin Expenditures: \$1,702,781

281

Utility Administration Expenditures: Total Labor and Material Expenditures: \$1,702,781

Average Billing Adjusted First Year Costs and Savings **Billing Adjusted First-Year Savings Number of Dwellings with Impacts** Number of Dwellings with kWh Impacts per Dwelling Receiving Measures Spending on Pk-Day Materials Summer Winter Annual Annual Propage Fuel Oil Other Materials Winter Annual Pk-Day Annual Propage Fuel Oil Other Measure Total Electric Gas Propane Oil Other Cooling Heating & Labor (\$) kW kWh kWh gallons gallons & Labor (\$) kWh therms gallons gallons Mbtu **Total Efficiency Measures** 125 940.002 62,025 317 30.597 7.520 2.60 Total Shell & Htg. Sys. Repl 768,154 281 Total Shell Measures Wall Insul. 422,201 126,312 35,117 10,474 124 19.5 8.6 13,221 13 199 0.060 281 1.18 108 0.72 80 31 27 Open Blown Ceiling Insul 7,371 0.50 7,371 3,604 75 Cavity Fill Insul Sloped Attic Insul 25 26 31 25 26 16,190 13 1.624 0.0 1.624 1 525 522 0.054 0.000 65 0.54 49 26 1,391 1,391 354 36 9,569 0.0 936 0.044 0.000 0.39 Kneewall Insul 25 124 21 122 11,090 444 0.020 24 17 0.15 14 18 Infil Reduction 122 122 116,706 1.6 1.981 0.1 118 2.099 23 2,157 941 0.013 0.077 118 0.19 306 0.07 Found./Crawl. Insul 20 24 19 6.129 429 0.0 429 24 0.051 61 0.000 61 24 Bandjoist Insul. 24 12,164 0.0 0.0 116 507 0.05 Furnace Blower Fan1 123 121 122 121 0.0 10.2 15,748 15,748 (1) (55) (0) 0.000 0 0.084 130 130 (0.00)(0) Exhaust Ventilation² (23) (0.021) (57 (2,645)(4,523 -0.003 (33) Total Heating System Repl 93 345,953 167 Condensing Htg Sys Rep Non-Cond Htg Sys Repl 311 643 0.0 123 33 3 463 167 21 34,310 3,054 1,634 1.58 Electric Htg Sys Repl 0.0 0.0 Heat Pump Repl 0.0 0.0 Other Htg Sys Repl Number of Measures Installed by Fuel Type Winter Pk-Day Annual Propane Fuel Oil Other Annual Pk-Day Annual Propane Fuel Oil Other Gas Propane Oil Othe Total Electric Gas kW kW kWh therms therms gallons gallons kW kWh therms therms gallons gallons Mbtu 166 0.185 Water Heating 154,116 4,812 0.0 WH Wrap 0.0 0.0 Pipe Insul. 2,196 0.0 0.0 1,135 257 0.000 0.000 0.01 LF Showerhead 23 70 24 99 240 494 0.0 0.0 1,225 0.4 115 112 10 0.000 0 004 175 0.02 11 59 16 526 0.01 Faucet Aerator 83 0.4 0.000 0.001 48 Std-Eff Wtr Htr Repl. 0.0 0.0 0.0 Hi-Eff or Electric Wtr Htr Repl. 151 186 1 027 15 nη 0.0 1 680 0.003 128 0.21 Lighting 10,639 628 0.012 114 13.370 1.4 1.3 11.456 637 0.063 546 Refrigerator/Freeze 21 21 22 22 0.067 Refrigerator Removal 512 Refrigerator Exchange 16 16 10,262 1.0 8,187 641 0.063 0.059 Freezer Removal 0.0 0.0 0.067 Freezer Exchange Total Non-Efficiency Measures 762,779 6,102 125 Misc Ins.Attic Access/Ver 21,498 194 150 Duct Sealing 14.296 Duct Insulation 6,798 88 46 Damming Material 2,654 Htg. Sys. Tune & Clear Hta. Sys./WH Other 24 36.541 1.523 Air Conditioning Work Water Heater Repair 396 132 Refrigerator Coil Clear Waterbed Mattress Pad Programmable Tstat 71 6.947 98 Unspecified Utility Me 11,060 6,873 89 62 0 CO Detector 110 Smoke Detector Fuses Htg Sys Safety Check 0 82 Htg Sys Ventilation 13,431 164 128 144 80 Water Heater Ventilation 65 8,336 5,033 7,764 Bathroom Ventilation 35 97 Dryer Ventilation 0 49 Kitchen Ventilation Other Exhaust Ventilation 96 4.740 1,375 458 Asbestos Removal (Minor) 17,448 233 Health/Safety Other Consumables 118 2.924 25 General Repairs Meter Refrig (no action) 113 41 Meter Freezer (no action 498,762 3,990 128 Transportation Allowance 69 8.806 Landlord Contr Misc Landlord Contr Furnace

20.818

Landlord Contr DHW Client Contr (Any) Lead Safe Work

Unspecifed/Other

The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures install partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures install partially funds refrigeration measures replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures install partially funds refrigeration measures replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures install partially funds refrigeration measures replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures install partially funds refrigeration measures replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures install partially funds refrigeration measures replacements. The percentage of expenditures for each application of the percentage of the percentage of expenditures for each application of the percentage of the

¹ Estimates are based upon reduced usage of the furnace due to shell improvement

Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

impacts from communuous constants trass required by ASHINALE QLZ. I not written impacts exceed summer decause meets and constant required season impacts for ownings with electric heat.

The total number of dwellings may exceed the number of measures included in cases where the utility manifest of measures in cases and the utility manifest of measures in cases and the utility manifest of mea

Total Reported Labor, Materials and Utility Admin Expenditures: \$162,079

Utility Administration Expenditures:

\$162,079 Total Labor and Material Expenditures:

	Number of Dwellings with Impacts	Number of Dwellings with kWh Impacts			Bill	ling Adjust	ted First-Year \$	Savings				Avera		Adjusted F		osts and S	vings		
			Spending on			tricity		1	Gas			Spending on	l i	Electi	ricity	1	Gas	. L	
Measure	Fuel Total Electric Gas Propane Oil Oth	Season ner Cooling Heating	Materials & Labor (\$)	Summ kW		Winter W kW	Annual h kWh	Pk-Day therms		Propane gallons	Fuel Oil Othe gallons Mbtu	Materials Labor (\$)	Summ kW	er kWh kW	Winter kWh	Annual Pk-I kWh ther	ay Annu ns therm		e Fuel Oil Other gallons Mbtu
Total Efficiency Measures	15 15 11 2 1	0 15 15	79,734	2.3		1.0	4,736	15	1,425	177	87	5,316	0.156	0.0	64	316 1	37	130 8	9 87 -
Total Shell & Htg. Sys. Repl	15 15 11 2 1	0 15 15	58,075	2.3	2,665	0.9 1,3	302 3,967	14	1,164	177	87	3,872	0.152	178 0.0	60 87	264 1	23	106 8	9 87 -
Total Shell Measures	15 15 11 2 1	0 15 15	34,550	2.3			302 3,967	7	605				0.152	178 0.0			64		2 25 -
Wall Insul.	3 3 2 1 0	0 3 0	885	0.6		0.0	0 684	1	79		0 (0.189	228 0.0		228 0		39	7
Open Blown Ceiling Insul Cavity Fill Insul		0 6 1	8,466 1,447	0.9 0.0		0.4	510 1,631	1 1	80 79				0.155	187 0.3	53 510	233 0	18 92	16 79 -	4
Sloped Attic Insul	1 1 1 0 0	0 1 0	1,107	0.2		0.0	0 203	1	87		0 1		0.168	203 0.0	00 0		01	87 -	
Kneewall Insul	2 2 2 0 0	0 2 0	322	0.0		0.0	0 27	0			0 (161		13 0.0			05	4 -	
Infil. Reduction Found /Crawl. Insul	15 15 11 2 1 8 4 7 0 1	0 14 1	13,908 3,585	0.3		0.2	217 567 0 381					927		25 0.1 95 0.0			22 12	19 2	7 16 -
Bandjoist Insul.	0 0 0 0 0	0 - 0	3,565	0.0		0.0	0 0	0			0		0.079	95 0.0		95 0		.'' :	9 -
Furnace Blower Fan ¹	14 14 11 2 1	0 - 14	0	0.0			061 1,061						0.000	0 0.0			00)		0) (0) -
Exhaust Ventilation	3 3 2 0 0	0 3 3	4,829	0.0			485) (586				0 (1,610	-0.004	(34) (0.1			06)	(5) -	
Total Heating System Repl	7 0 5 1 1	0 - 0	23,525	0.0		0.0	0 0	·			62		-			- 1		112 11	
Condensing Htg Sys Rep	7 0 5 1 1 0 0 0 0	0	23,525	0.0		0.0	0 0				62	-,	-	: :	-	- 1		112 1	3 62 -
Non-Cond Htg Sys Repl Electric Htg Sys Repl		0 - 0	0	0.0		0.0	0 0						-					: :	
Heat Pump Repl		0 - 0	0	0.0		0.0	0 0	0			0	-	-						
Other Htg Sys Repl	0 0 0 0 0	0 - 0	0	0.0		0.0	0 0	0	0	0	0 (0	-		-			-	
		Number of Measures Installed by Fuel Type																	
	Fuel Total Electric Gas Propane Oil Otl	Fuel her Total Electric Gas Propane Oil Other		Summer kW	k	nter :W	Annual kWh	Pk-Day therms	therms	gallons	Fuel Oil Other gallons Mbtu	r	Summer kW	Wint kW	,	Annual Pk-D kWh ther	ns therm	s gallons	e Fuel Oil Other gallons Mbtu
Water Heating	10 1 0 0 0	0 18 4 14 0 0 0	20,700	0.0		0.0	257				0	1,000		0.0		64 0.1		29 -	
Temp. Reduct. WH Wrap	0 0 0 0 0	0 0 0 0 0 0 0	0	0.0 0.0		0.0	0	0.0			0 (0							1 1
Pipe Insul.	10 3 7 0 0	0 10 3 7 0 0 0	190	0.0		0.0	128			ő	0	19	0.000	0.0	00	43 (.01	3 -	
LF Showerhead		0 0 0 0 0 0 0	0	0.0		0.0	0				0 (0	-						
Faucet Aerator		0 0 0 0 0 0 0	0	0.0		0.0	0				0 (0	-					: :	: :
Std-Eff Wtr Htr Repl. Hi-Eff or Electric Wtr Htr Repl.	0 0 0 0 0 8 1 7 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	20,600	0.0 0.0		0.0	128				0 (2,575	0.000	0.0			.21	34 -	1 1
Lighting	0 0	0 0	0	0.0		0.0	0		-	-			-	-					
Refrigerator/Freezer ³	1 1	1 1	869	0.1		0.1	512		-	-		869	0.063	0.0	59	512 -			
Refrigerator Removal	0 0	0 0	0	0.0		0.0	0		-	-		0	-					-	
Refrigerator Exchange Freezer Removal	1 1 0 0	1 1 0 0	869 0	0.1 0.0		0.1	512		- 1	-		869	0.063	0.0		512 -			: :
Freezer Exchange	0 0	0 0	ő	0.0		0.0	ŏ		-	-		ő	-						
Total Non-Efficiency Measures	15		82,346									5,490							
Misc Ins,Attic Access/Ven	13		3,147									242							
Duct Sealing	0		0									0							
Duct Insulation	0		0									0							
Damming Material Htg. Sys. Tune & Clean	1 3		55 1,525									55 508							
Htg. Sys./WH Other	2		1,907									953							
Air Conditioning Work	0		0									0							
Water Heater Repair	1		125									125							
Refrigerator Coil Clean Waterbed Mattress Pad	0		0									0							
Programmable Tstat	0		0									ő							
Unspecified Utility Meas	0		0									0	1						
CO Detector Smoke Detector	11 10		368 455									33 46							
Fuses	0		455									0							
Htg Sys Safety Check	0		0									0							
Htg Sys Ventilation	8		3,000									375							
Water Heater Ventilation Bathroom Ventilation	7		2,250 2,704									321 676	1						
Dryer Ventilation	3		400									133							
Kitchen Ventilation	0		0									0	1						
Other Exhaust Ventilation	0		0									0							
Asbestos Removal (Minor)	0		7.067									0 642							
Health/Safety Repairs Health/Safety Other	11 0		7,067 0									642	1						
Consumables	0		0									0	1						
General Repairs Meter Refrig (no action)	14		14,811									1,058	-						
Meter Freezer (no action)	3		0									0							
Support	15		43,796									2,920							
Transportation Allowance Landlord Contr Misc	0		0									0	1						
Landlord Contr Misc Landlord Contr Furnace	0		0									0							
Landlord Contr DHW	0		0									0	1						
Client Contr (Any)	0		0									0	1						
Lead Safe Work Unspecifed/Other	3		737 0									246							
													1						

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

² Impacts from continuous exhaust fans required by ASHAE 62.2. The winter impacts exceed summer because these also include heating season impacts for deelings with electric heat.

3 The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Total Reported Labor, Materials and Utility Admin Expenditures: \$1,339,403

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$1,339,403

						1					ĺ	İ		Dilling A	dinatad F	irot Voo- C	ovinac				1	Avers	o Dillie -			Voor C		nd Cavi			
	Num	ber of D	wellinas	with Imr	pacts	Num	ber of D	wellinas wi	ith kWh In	npacts				Dilling A	ajusted F	irst-Year S	avings					Averag		Adjusted elling Re				nd Saving	S		
						Sea				.,	Spending on Materials			lectricity		Annual		Gas	l n	F1 011		Spending on Materials			ctricity			G			Fuel Oil Other
Measure	Total	Electric	Gas Pi		Fuel Oil Oth	er Cooling					Materials & Labor (\$)	Sum kW	imer kWh	Wir kW	nter kWh	Annual kWh	therms	Annual therms		gallons		Materials & Labor (\$)	Summ kW		Wint kW				Annual therms		gallons Mbtu
Total Efficiency Measures	97	97	84	7	0	0 96	97				727,080	20.2		14.2		56,947	192	18,608	2,110	0	0	7,496	0.210		0.146		587	2.29	222	301	
Total Shell & Htg. Sys. Repl Total Shell Measures	97 97	97 97	84 84	7	0	0 96	97 97				634,547 470,737	18.4 18.4	20,463	12.0 11.7	18,702 18,302	39,165 38,765	182 110		2,000 1,432	0	0	6,542 4,853	0.192	213 (0.123	193 189	404 400	2.17	202 122		
Wall Insul.	65	63	57	6	0	0 63	2				145,700	7.7	9,234	1.2	1,920	11,154	46	4,326	665	0	0	2,242	0.122		0.615	960	177	0.81	76	111	
Open Blown Ceiling Insul Cavity Fill Insul	75 25	72 21	66 23	5 1		0 72 0 21	4				63,789 22,581	5.6 1.2	6,736 1,395	3.1 1.6	4,915 2,458	11,651 3,853	20 12	1,893 1,092	237 120	0	0	851 903	0.078 0.055			1,229 2,458	162 183	0.31 0.51	29 47	47 120	: :
Sloped Attic Insul	31	29	28	3	0	0 29					18,022	1.5	1,826	0.0	0	1,826	11	990	127	0	ō	581	0.052	63 (0.000	0	63	0.38	35	42	
Kneewall Insul Infil. Reduction	28 96	24 93	24 84	3		0 24	1 5				12,938 115,191	0.5	580 1.596	0.1	171 561	750 2,157	3 14	235 1,303	56 120	0	0	462 1,200	0.020		0.109 0.072	171 112	31 23	0.11 0.17	10 16	19 17	1 1
Found./Crawl. Insul	45	18	40	4	0	0 18					22,616	0.9	1,145	0.0	24	1,169	7	656	119	0	ő	503	0.053	64 (0.015	24	65	0.18	16	30	
Bandjoist Insul.	51	2	44	5	-	0 -	2				7,323	0.0	0	0.2	326	326	2		24	0	0	144	0.000		0.104	163	163	0.05	4	5	
Furnace Blower Fan ¹ Exhaust Ventilation ²	91 83	91 83	84 73	7	-	0 -	91 83				62 578	0.0	(2,048)	7.6 (2.5)	11,889	11,889 (6.011)	(0)		(6)	0	0	0 754	0.000	0 (25) (0.084	131	131 (72)	(0.01)	(0)	(1)	
Total Heating System Repl	67	3	60	4	0	0 -	3				163,809	0.0	(2,040)	0.3	400	400	72		567	0	0	2,445	0.000		0.085	133	133	1.21	112		
Condensing Htg Sys Rep Non-Cond Htg Sys Repl	59 5	0	56 4	3		0 -	-				139,847 8,914	0.0	0	0.0	0	0	68 4	6,379 366	401 166	0	0	2,370 1,783	-	-	-	-	-	1.22 0.98	114 91	134 166	
Electric Htg Sys Repl	1	1	0	ó		0 -	1				4,946	0.0	0	0.1	162	162	0		0	0	ő	4,946	0.000		0.104	162	162	-	-	-	
Heat Pump Repl	2	2	0	0		0 -	2				10,102	0.0	0	0.2	238	238	0	0	0	0	0	5,051	0.000	0 (0.076	119	119	-	-	-	
Other Htg Sys Repl	0	0	0	0	U	0 -	0				0	0.0	0	0.0	0	0	0	0	0	0	U	0	-	-	-	-	-	-	-	-	
					Fuel	Numb	er of Meas	ures Installe	d by Fuel T	Гур€		Summer		Winter		Annual	Pk-Day	Annual	Propane	Euol Oil	Othor		Summer	14	/inter		Annual	Pk-Day	Annual	Bronono	Fuel Oil Other
	Total	Electric	Gas P	ropane	Oil Oth	er Total		Gas Pi	ropane C			kW		kW		kWh	therms	therms	gallons	gallons	Mbtu		kW		kW		kWh	therms	therms	gallons	gallons Mbtu
Water Heating Temp. Reduct	82 0	29	49 0	4	0	0 121	36 0		5	0 0	81,974	0.0		0.0		2,850	9.5	1,605	110	0	0	1,000	0.000		0.002		98	0.194	33	28	
WH Wrap	0	ō	0	ō	Ö	0 0	0	ō	Ö	0 0	0	0.0		0.0		ő	0.0		0	ō	0	ő	-		-		-	-		-	
Pipe Insul. LF Showerhead	55 3	23 1	30 2	2		0 55	23 1	30 2	2	0 0	242 13	0.0		0.0		1,027 218	0.2		6	0	0	4	0.000		0.000 0.005		45 218	0.01 0.02	3	3	
Faucet Aerator	4	0	4	0		0 4	0		0	0 0	9	0.0		0.0		0	0.0	5	0	0	0	2	-		-		-	0.02	1	-	1 1
Std-Eff Wtr Htr Repl.	0	0	0	0	0	0 0			0	0 0	0	0.0		0.0		0	0.0		0	0	0	0	-		-		-				
Hi-Eff or Electric Wtr Htr Repl. Lighting	59 42	12 42	44	3	0	0 59 375	12 375	44	3	0 0	81,710 704	0.0		0.0 1.1		1,605 5,421	9.2	1,500	104	- 0	-	1,385 17	0.000		0.003		134 129	0.21	34	35	
Refrigerator/Freezer ³	15	15				18					9,855	1.2		1.1		9,511	-	-	-	-	-	657	0.078	(0.073		634	-	-	-	
Refrigerator Removal Refrigerator Exchange	1 11	1 11				1 12	1 12				15 7,515	0.1 0.8		0.1 0.7		512 6,140	- 1		-	- 1		15 683	0.063 0.069		0.059 0.064		512 558		- :		: :
Freezer Removal	0	0				0	0				0	0.0		0.0		0			-			003	-		-		-	-		-	
Freezer Exchange	5	5				5	5				2,325	0.4		0.3		2,859	-	-	-	-	-	465	0.070		0.066		572	-	-	-	
Total Non-Efficiency Measures	97										612,323											6,313									
Misc Ins,Attic Access/Veni Duct Sealing	90 24										45,517 3,696											506 154									
Duct Insulation	54										7,658											142									
Damming Material	64 29										5,290 3,819											83 132									
Htg. Sys. Tune & Clear Htg. Sys./WH Other	15										9,239											616									
Air Conditioning Work	0										0											0									
Water Heater Repair Refrigerator Coil Clean	16 0										575 0											36 0									
Waterbed Mattress Pad	ō										0											ő									
Programmable Tstat Unspecified Utility Meas	0										0											0									
CO Detector	90										4,868											54									
Smoke Detector Fuses	49 0										1,732 0											35 0									
Htg Sys Safety Check	0										0											0									
Htg Sys Ventilation Water Heater Ventilation	66 48										10,448 4.472											158 93									
Bathroom Ventilation	20										4,027											201									
Dryer Ventilation Kitchen Ventilation	50 0										5,830											117									
Other Exhaust Ventilation	0										0											0									
Asbestos Removal (Minor)	0										0											0									
Health/Safety Repairs Health/Safety Other	75 5										46,243 570											617 114									
Consumables	0										0											0									
General Repairs Meter Refrig (no action)	92 78										76,936 0											836									
Meter Freezer (no action)	18										0											0									
Support Transportation Allowance	97 0				· ·		· ·				358,098									· ·	Ī	3,692									
Landlord Contr Misc	1										(2,000)											-2,000									
Landlord Contr Furnace	0										0											0									
Landlord Contr DHW Client Contr (Any)	0										0											0									
Lead Safe Work	66										25,305											383									
Unspecifed/Other	0										0											0									

Estimates are based upon reduced usage of the furnace due to shell improvements

Impacts from continuous exhaunt from required by ASPARE 62. The writter impacts exceed summer because these also include healing season impacts for deellings with electric heat.

The both number of developing may exceed the number of measures installed in case where the utility partially funds telegration measure replacements. The percentage of expenditures for each appliance is lotated to get the total number of measures installed.

The total number of developing may exceed the number of measures installed.

Total Reported Labor, Materials and Utility Admin Expenditures: \$448,386

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$448,386

																															iotai	Labor a	anu ivia	iteriai E	zxpenu	iitures.	\$448 ,	,300			
	11																		В	illing A	Adjusted	First-Year	Savings	8					Avera	ge Billing						d Savin	gs				
	N	lumbe	r of D	wellin	gs wit	th Impa	acts		Numbe	er of D	velling	s with	kWh I	mpacts	Sper	iding on			FI	ectricity	,		1	Gas	ıs				Spending on	per Dv	velling	Receivi Electric		leasur	es		as	1			
Measure	Tota	E1.	otrio	Goo	Brono		uel	hor C	Seaso ooling						Ma	terials	Sı kW	ummer kV			inter kWh	Annual kWh	Pk-Da	ay A			Fuel Oil		Materials	Sum kW			inter			Pk-Day therms	Annua therms			Fuel Oi	
																			VII		KVVII		-						(1)												WIDIU
Total Efficiency Measures	3	7	37	32		3	0	0	37	37						262,794				7.0		32,67	5 (67	6,416	650	0	0	7,103	0.275		0.190)		883	2.09		201	217	•	-
Total Shell & Htg. Sys. Repl Total Shell Measures	3		37	32		3	0	0	37 37	37 37						225,664 159.633	8.7 8.7		9,741 9.741	4.4	6,689 6,569	16,43 16.31	11 6	63 36	5,735 3,322	650 314	0	0		0.234		0.118	3 1		444 441	1.96		179 104	217 105		-
Wall Insul.	2	4	24	23		1	0	0	24	0						60,242	3.6	. 4	4,294	0.0	0	4,29	14	18	1,671	101	0	0	2,510	0.148	179	0.000)	0	179	0.80		73	105	-	-
Open Blown Ceiling Insul Cavity Fill Insul		0 5	30 12	27 12		2	0	0	30 12	1						20,840 14,371	2.8 0.9		3,433 1,093	2.3 0.2	3,562 312	6,99 1,40		6 5	519 444	10 144		0		0.095 0.076		2.330 0.204			233 117	0.21 0.41		19 37	5 72	- :	-
Sloped Attic Insul		9	9	9		0	0	Ö	9	ó						5,821	0.6		677	0.0	0	67	7	3	318	0	0	Ō	647	0.062	75	0.000)	0	75	0.39		35	-	-	-
Kneewall Insul Infil. Reduction	3	9	6 37	8 32		1 3	0	0	6 37	0						3,456 18,029	0.1 0.7		154 828	0.0	0 115	15 94		1	135 231	16 29	0	0	384 487	0.021 0.019	26 22	0.000		0 58	26 25	0.18		17 7	16 10		-
Found./Crawl. Insul Bandjoist Insul.		9 6	1	7 13		2	0	0	1	0						6,356 4,995	0.1 0.0		76 0	0.0	0		6	1	64 95	17 15		0	706 312	0.063		0.000)	0	76	0.10 0.08		9	8 5	-	-
Furnace Blower Fan ¹		5	35	32		3	0	0		35						4,555			0	2.7	4,160	4,16	-	(0)	(14)	(1		0		0.000	- 0	0.078	3 1	19	119	(0.00)		(0)	(0)	-	
Exhaust Ventilation ²		3	33	28		3	0	0	33	33						25,524			(815)	(1.0)	(1,581)	(2,39		(2)	(142)	(17		0	110			(0.031			(73)	(0.06)		(5)	(6)	-	-
Total Heating System Repl Condensing Htg Sys Rep		4	0	22		2	0	0	÷	1						66,031 60,799	0.0		0	0.1	121			26 26	2,413	336 336	0	0		0.000	- 0	0.079	-	21	121	1.20		110	168 168		
Non-Cond Htg Sys Repl Electric Htg Sys Repl		0	0	0		0	0	0	-	- 0						0	0.0		0	0.0	0			0	0	0	0	0	0	-	-	-	-		-	-			-		-
Heat Pump Repl		1	1	0		0	0	0	-	1						5,232	0.0		0	0.1	121	12		0	0	0	0	0	-	0.000	- 0	0.079	9 1:	21	121	-			-	-	-
Other Htg Sys Repl	1	0	0	0		0	0	0	-	0						0	0.0	1	0	0.0	0		0	0	0	0	0	0	0	-	-	-	-		-	-		-	-	-	-
						E.	uel	- 1	Number	of Meas	ures In	talled b		Typ€ uel			Summe		v	Vinter		Annual	Pk-Da	A	Annual	Propaga	Fuel Oil	Other		Summer		Winter		Δn	nnual E	Pk-Day	Annua	. Dr	onana	Fuel Oi	Other
	Tota				Propa	ane C	Oil Ot			Electric	Gas	Prop	ane	Oil Otl			kW			kW		kWh	therm	ns ti	herms	gallons	gallons	Mbtu		kW		kW		k۱	:Wh	therms	therms	s ga	illons	gallons	Mbtu
Water Heating Temp. Reduct.	3	2	17	20		0	0	0	76 2	28	4	3	0	0	0	31,692 0	0.0			0.0		2,09		3.9 0.0	682 0	0	0	0		0.000		0.002			123	0.194	-	34	-	- :	-
WH Wrap Pipe Insul.		0 4	0 15	0 19		0	0	0	0 34	0 15)	0	0	0	0 630	0.0			0.0		66).0).2	0 54	0	0	0	0	0.000		0.000	,		- 44	- 0.01		- 3	-	-	-
LF Showerhead		6	1	5		0	0	0	7	1		3	0	0	0	78	0.0			0.0		17).1	35	0	0	0	13	0.000		0.004			175	0.01		7	-	- 1	-
Faucet Aerator Std-Eff Wtr Htr Repl.		5 0	2	3		0	0	0	8	3		5	0	0	0	30	0.0			0.0				0.0	7	0	0	0	6	0.000		0.001	1		49	0.01		2	-	-	-
Hi-Eff or Electric Wtr Htr Repl.	2	5	7	18		0	0	0	25	7	1		0	0	0	30,954	0.0			0.0		89	9 3	3.6	586	0	0	0	1,238	0.000		0.003			128	0.20		33	- :	_ :	_ :
Lighting Refrigerator/Freezer ³		3	31					_	424 3	424						2,688 2,750				2.4 0.2		12,6°				-	- :	- :				0.079			407 512	-		-	-	-	
Refrigerator Removal		0	0						0	0						0	0.0	1		0.0		,	0 -		-	-			0	-		-			-	-	-	-	-		-
Refrigerator Exchange Freezer Removal		3 0	3						3	3						2,750	0.2			0.2		1,53	5 -		-	-	-	-	917	0.063		0.059	9		512	-			-	-	-
Freezer Exchange		0	0						0	0						0	0.0			0.0			0 -				-		0	-		-			-	-			-		
Total Non-Efficiency Measures	3	7														185,591													5,016												
Misc Ins,Attic Access/Ven		6 4														5,855 240													163 60												
Duct Insulation	2	6														2,286													88												
Damming Material Htg. Sys. Tune & Clean		5 1														477 2,530													32 230												
Htg. Sys./WH Other	1	1														6,671													606												
Air Conditioning Work Water Heater Repair		0 6														897													56												
Refrigerator Coil Clean		0														0													0												
Waterbed Mattress Pad Programmable Tstat		0														0													0												
Unspecified Utility Meas CO Detector		5													-	2,710													77												
Smoke Detector	3	0														1,823													61												
Fuses Htg Sys Safety Check		0														0													0												
Htg Sys Ventilation	2	5														3,351													134												
Water Heater Ventilation Bathroom Ventilation		6 3														2,130 315													133 105												
Dryer Ventilation		9														1,795													94												
Kitchen Ventilation Other Exhaust Ventilation		0 8														0 1,010													0 56												
Asbestos Removal (Minor)		0														0													0												
Health/Safety Repairs Health/Safety Other		0 1														11,044 20													1,104 20												
Consumables General Repairs		0 5														0 13.432													0 384												
Meter Refrig (no action)	3	1														0													0	1											
Meter Freezer (no action) Support		7														123,282													3,332	-											
Transportation Allowance		0														0													0,002												
Landlord Contr Misc Landlord Contr Furnace		0														0													0												
Landlord Contr DHW		0														Ö													0												
Client Contr (Any) Lead Safe Work		2														5,723													260	-											
Unspecifed/Other		0														0													0	1											

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

² Impacts from continuous exhaust fans required by ASHAE 62.2. The winter impacts exceed summer because these also include heating season impacts for deelings with electric heat.

3 The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Total Reported Labor, Materials and Utility Admin Expenditures: \$1,171,748

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$1,171,748

	Num	ber of D	wellings	s with Im	pacts		Numbe	r of Dwe	llings with kWh Impacts				Billing A	djusted F	irst-Year S	avings					Averag	e Billing per Dw					nd Savin	gs		
					Fuel				g	Spending on			Electricity				Gas	I	F1 011	011	Spending on			Electricit		•		as		5 I O'! O!!
Measure	Total	Electric	Gas P			Other	Seaso Cooling H			Materials & Labor (\$)	Sum kW	hmer kWh	kW	nter kWh	Annual kWh	Pk-Day therms	therms	Propane gallons	gallons	Mbtu	Materials & Labor (\$)	Sumn kW	ner kWh	Win kW	kWh	kWh	Pk-Day therms	Annual therms		Fuel Oil Other gallons Mbtu
Total Efficiency Measures	89	89	82	3	0	1	88	89		663,241	19.8		30.4		108,508	243	25,145	1,342	0	16	7,452	0.225		0.341		1,219	2.97	307	447	- 16
Total Shell & Htg. Sys. Repl	89	89	82	3	0	1	86	89		534,457	13.6	14,889	21.8	35,942	50,832			1,342	0	16	6,005	0.159	173	0.244	404		2.79	275	447	- 16
Total Shell Measures	89	89	82	3	0	1	86	89		407,036	13.6	14,889	21.5	35,606	50,496	162	15,947	989	0	16	4,573	0.159	173	0.242	400		1.97	194		- 16
Wall Insul. Open Blown Ceiling Insul	69 86	57 72	63 79	3	0	0	55 70	3		180,505 43,105	5.7 5.1	6,831 6,126	5.0 6.8	8,266 11,247	15,097 17,373	58 63	5,713 6,209	441 193	0	0 7	2,616 501	0.103 0.073	124 88	1.667 2.269	2,755 3,749	265 241	0.92 0.80	91 79		7
Cavity Fill Insul	22	16	20	2	0	o	16	0		20,623	0.5	604	0.0	0	604	9	842		ő	ó	937	0.073	38	0.000	0,743		0.43	42		
Sloped Attic Insul	42	33	39	2	0	1	33	0		31,526	1.2	1,505	0.0	0	1,505	18		84	0	6	751	0.038	46	0.000	0		0.47	47		
Kneewall Insul	23 88	17	20 81	2	0	1	17 71	0 3		14,881	0.3 0.9	387	0.0	700	387 1,840	5 9	475 865	45 71	0	3	647 424	0.019	23 15	0.000 0.157	0 260		0.24 0.11	24 11		- 3 - 0
Infil. Reduction Found /Crawl. Insul	40	73 4	36	2	0	1	4	3 1		37,278 10,885	0.9	1,060 223	0.5	780 401	623	3	321	13	0	1	272	0.012	56	0.157	401			9		
Bandjoist Insul.	24	3	19	2	0	0	- '	3		3,855	0.0	0	0.5	747	747	1	130	19	ō	0	161	0.000	0	0.151	249		0.07	7	9	
Furnace Blower Fan	86	86	82	3	0	1	-	86		0	0.0	0	10.4	17,158	17,158	(1)			0	(0)	0	0.000	0	0.121	200		(0.01)	(1) (1	
Exhaust Ventilation	77	77	70	3	0	1	77	77		64,378	-0.2	(1,845)	(1.8)	(2,993)	(4,838)				0	(1)	836	-0.003	(24)	(0.024)	(39)		(0.05)	(5	177	
Total Heating System Repl Condensing Htg Sys Rep	52 50	0	48 48	2	0	0		2		127,421 103,583	0.0	0	0.2	336	336		6,641 5,283	353 353	0	0	2,450 2,072	0.000	- 0	0.102	168	168	1.40	138 110		
Non-Cond Htg Sys Repl	11	0	11	0	0	ő				16,500	0.0	0	0.0	0	0	14			0	0	1,500			-			1.25	123		
Electric Htg Sys Repl	2	2	0	0	0	0	-	2		7,338	0.0	0		336	336	0	0	0	0	0	3,669	0.000	0	0.102	168	168	-	-	-	
Heat Pump Repl Other Htg Sys Repl	0	0	0	0	0	0	-	0		0	0.0	0	0.0	0	0	0	0	0	0	0	0	-	-	-	- 1		-	-	-	1 1
and my of a repr	Ü				- 0	-					0.0	<u> </u>	0.0			1		1	<u> </u>	Ü	U									
					Fuel		Number o	f Measur	es Installed by Fuel Type Fuel		Summer		Winter		Annual	Pk-Day	Annual	Propane	Fuel Oil	Other	,	Summer		Winter		Annual	Pk-Day	Annual	Propane	Fuel Oil Other
Water Heating	Total 87	Electric 18	Gas F	Propane	Oil	Other	Total E	lectric 49	Gas Propane Oil Other	r 88,710	kW		kW		kWh 3,239	therms		gallons	gallons		1,020	kW 0.000		kW 0.003		kWh	therms 0.206	therms		gallons Mbtu
Temp. Reduct.	0	0	09	0	0	0	0	0	0 0 0	0 00,710	0.0		0.0		3,239	0.0	2,557	0	0	0	1,020	-		-		-	0.206	- 31	-	
WH Wrap	ō	ō	ō	ō	0	0	0	0	0 0 0		0.0		0.0		0	0.0	0		ō	0	0	-		-		-	-	-	-	
Pipe Insul.	83	17	66	0	0	0	83	17	66 0 0	356	0.0		0.0		749	0.5	188		0	0	4	0.000		0.000		44	0.01	3	-	
LF Showerhead Faucet Aerator	34 70	6 13	28 57	0	0	0	34 101	6 21	28 0 0 80 0 0	105	0.0		0.0		1,093 722	0.6 0.4	193 108		0	0	3	0.000		0.004 0.001		182 56	0.02 0.01	2	1 :	
Std-Eff Wtr Htr Repl.	0	0	0	ő	0	0	0	0	0 0 0	0	0.0		0.0		0	0.0	0	0	0	0	ó	-		-		-	-		-	
Hi-Eff or Electric Wtr Htr Repl.	70	5	65	0	0	0	70	5	65 0 0	88,196	0.0		0.0		674				0	0	1,260	0.000		0.003		135	0.19	32	-	
Lighting Refrigerator/Freezer ³	76 38	76 38					844 48	844 48		4,821 35,253	3.0		5.6 2.9		28,890 25,547	-	-	-		-	63 928	0.040		0.074		380 672		-	-	
Refrigerator Removal	1	1					1	1		25	0.1		0.1		512			-		-	25	0.063		0.077		512			-	
Refrigerator Exchange	33	33					33	33		29,477	2.1		2.0		17,138	-	-	-	-	-	893	0.064		0.060		519	-	-	-	
Freezer Removal Freezer Exchange	3 11	3 11					3 11	3 11		80 5,672	0.2 0.8		0.2 0.7		1,769 6,128	-	-	-	-	-	27 516	0.073		0.068		590 557	-	-	-	
							- "				0.0		0.7		0,120			1 -				0.003		0.004		551				
Total Non-Efficiency Measures Misc Ins.Attic Access/Ven	89 87									508,507 15,236											5,714 175									
Duct Sealing	0									13,230											0									
Duct Insulation	0									0											0									
Damming Material Htg. Sys. Tune & Clean	67 35									4,964 2,914											74 83									
Htg. Sys./WH Other	54									20,249											375									
Air Conditioning Work	0									0											0									
Water Heater Repair Refrigerator Coil Clean	1									150											150									
Waterbed Mattress Pad	0									0											0									
Programmable Tstat	0									0											0									
Unspecified Utility Meas CO Detector	0									8.360											0									
CO Detector Smoke Detector	88 87									7,148											95 82									
Fuses	0									0											0									
Htg Sys Safety Check Htg Sys Ventilation	0 37									0 5,656											0 153									
Htg Sys Ventilation Water Heater Ventilation	37 50									5,656 4,623											153 92									
Bathroom Ventilation	16									3,229											202									
Dryer Ventilation	46									6,143											134									
Kitchen Ventilation Other Exhaust Ventilation	0									0											0									
Asbestos Removal (Minor)	0									0											0									
Health/Safety Repairs	40									6,486											162									
Health/Safety Other Consumables	0 88									3,505											0 40									
General Repairs	88 85									3,505 47,022											553									
Meter Refrig (no action)	42									0											0									
Meter Freezer (no action) Support	17 88									338,934											0 3,852									
Transportation Allowance	0									336,934											0,052									
Landlord Contr Misc	0									ő											Ö									
Landlord Contr Furnace	0									0											0									
Landlord Contr DHW Client Contr (Any)	0									0											0									
Lead Safe Work	84									33,889											403									
Unspecifed/Other	0									0											0									

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

³ The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Total Reported Labor, Materials and Utility Admin Expenditures:

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$725,184

																								Total	Labor an	ia mater	iai Expe	naitures:	\$725,1	>		
					ĺ							1		Billing A	Adjusted F	irst-Year S	avings					Avera	ge Billing					nd Savin	igs			
	Number	of Dwellin	gs with	Impact	s	Numbe	er of Dw	ellings	with kW	h Impacts													per Dw	elling F		•	sures					
				Fuel		Seaso	on				Spending on Materials	Sun	nmer	Electricity	/ /inter	Annual	Pk-Day	Gas Annual	Propage	Fuel Oil (Spother	ending on Naterials	Sumr		Electricit Win		Annua	l Pk-Day	Gas Annual	Propa	ne Fuel O	il Other
Measure	Total Elec	ric Gas	Propane		Other	Cooling	Heating				& Labor (\$)	kW	kWh	kW	kWh	kWh	therms	therms		gallons		Labor (\$)		kWh	kW	kWh	kWh	therms	therms		s gallon	
T					1						400 575	45.0		40.0		E4 70E	400	0.744	4.000	•	40	4 770	0.400		0.404		500	4.50				40
Total Efficiency Measures	92	92 64	19	9 0	1	92	92				439,575	15.0		16.6		51,735	100	9,714	4,899	U	18	4,778	0.163		0.181		562	1.56	15	2 2	58 -	18
Total Shell & Htg. Sys. Repl	92	92 64				89	92				383,132	13.8	15,137	15.0		38,585	95	8,838		0	18	4,164		170	0.163	255			13		50 -	18
Total Shell Measures	92	92 64		9 0 9 0		89 34	92				197,041	13.8 4.1	15,137	14.7	22,940	38,076	51	4,757	2,296 976	0	8	2,142		170	0.160	249					21 -	8
Wall Insul. Open Blown Ceiling Insul	40 76	34 29 70 54				70	6				26,186 33.588	6.5	4,928 7,794	1.7 2.8	2,620 4,410	7,548 12,205	22 9	2,021 874			1	655 442	0.120 0.092	145 111	0.839	1,310 735					08 - 34 -	- 1
Cavity Fill Insul	9	7 7	2			7	ō				4,300	0.4	500	0.0	0	500	4	396	101	0	0	478	0.059	71	0.000	0	71	0.61	5	7	51 -	- '
Sloped Attic Insul	12	11 10		1 0		11	1				3,246	0.7	847		1,409	2,256	4	378			0	271		77	0.903	1,409					27 -	-
Kneewall Insul Infil. Reduction	18 90	16 12 82 62				15 82	3 8				16,979 51,920	0.8 1.1	976 1,270	2.7 3.0	4,160 4,670	5,136 5,940	2 10	208 896			0	943 577		65 15	0.888	1,387 584					01 - 20 -	- 4
Found./Crawl. Insul	19	11 12				10	3				8,650	0.5	643		1,485	2,128	1	121			3	455	0.053	64	0.317	495					18 -	3
Bandjoist Insul.	34	4 22		8 0		-	4				10,634	0.0	0	0.6	899	899	2	145	51		0	313	0.000	0	0.144	225	225	0.07		7	6 -	-
Furnace Blower Fan	84	83 64				-	83				0	0.0	0		7,023	7,023	(0)				(0)	0	0.000	0	0.054	85					(0) -	(0)
Exhaust Ventilation	73 54	73 51		, ,	-	73	73 2				41,538	-0.2	(1,822)			(5,558)					10	569 3,446		(25)	(0.033)					5)	(6) -	10
Total Heating System Repl Condensing Htg Sys Rep	54	0 36		0 0							186,091 181,319	0.0	0		508	508	44	4,080 4,080			10	3,440	0.000	-	0.163	254	254	1.22	11		66 -	10
Non-Cond Htg Sys Repl	1	0 0	1	1 0	0	-	-				2,357	0.0	0	0.0	0	ō	0	0	131	ō	0	2,357	-	-	-	-	-	-			31 -	-
Electric Htg Sys Repl	1	1 0				-	1				2,200	0.0	0		129	129	0		-		0	2,200		0	0.083	129			-	-		-
Heat Pump Repl Other Htg Sys Repl	1	1 0				-	1				215 0	0.0	0		379 0	379 0	0	0	0		0	215	0.000	0	0.243	379	379	-	-			-
Other ring dys ricepi	- 0	0 0		0 0								0.0		0.0							- 0							-				
				Fuel		Number	of Measu	ures Instal	lled by F					Winter			DI. D			F1011 0							•	DI D.				
	Total Elec	ric Gas	Propan		Other	Total	Electric	Gas	Propage	Fuel Oil Ot	her	Summer kW		Winter		Annual kWh	Pk-Day therms	Annual	gallons	Fuel Oil O gallons	ther Mbtu		Summer kW		Winter kW		Annua kWh	Pk-Day therms	Annual therms		ne Fuel O	
Water Heating	86	39 42				120	49	63	8	0	0 49,384	0.0		0.0		3,136	5.0	876			0	574	0.000		0.001			0.119			30 -	-
Temp. Reduct.	0	0 0		0 0		0	0	0	0	0	0 0	0.0		0.0		0	0.0	0	0	0	0	0	-		-		-	-	-	-	-	-
WH Wrap Pipe Insul.	0 83	0 0				0 83	0 38	0 40	0 5	0	0 0 758	0.0		0.0		1,691	0.0	0 114			0	0	0.000		0.000		- 44	0.01	-	3 -	3 -	- 1
LF Showerhead	0	0 0				0	0	0	0	0	0 0	0.0		0.0		0	0.0	0			0	0	-		-			-				-
Faucet Aerator	0	0 0	-			0	0	0	0	0	0 0	0.0		0.0		0	0.0	0			0	0	-		-		-	-	-	-		-
Std-Eff Wtr Htr Repl. Hi-Eff or Electric Wtr Htr Repl.	0 37	0 0		0 0		0 37	0 11	0 23	0	0	0 0 0 48,626	0.0		0.0		0 1 445	0.0 4.7	0 762			0	0 1,314	0.000		0.003		- 131	0.20	- 3	-		-
Lighting	44	44		3 0	U	245	245		3	0	715	0.6		1.0		5,251	-	- 102	-	-	-	1,314			0.003		119		-			-
Refrigerator/Freezer ³	8	8				9	9				6,344	0.6		0.5		4,765	-		-		-	793			0.068		596		-	-		-
Refrigerator Removal	1	1				1	1				40	0.1		0.1		512	-	-	-	-	-	40	0.063		0.059		512	-	-	-	-	-
Refrigerator Exchange Freezer Removal	7	7				7 0	7 0				5,449 0	0.5 0.0		0.4		3,708 0	-	-	-	-	-	778 0	0.065		0.061		530	-	-	-		-
Freezer Exchange	1	1				1	1				855	0.1		0.1		545	-		-		-	855	0.067		0.063		545	-	-	-		-
Total Non-Efficiency Measures	92										285.609											3,104										
Misc Ins,Attic Access/Ven	31										285,609											3,104										
Duct Sealing	0										0											0										
Duct Insulation	3										584											195										
Damming Material Htg. Sys. Tune & Clean	0 14										0 2,214											0 158										
Htg. Sys./WH Other	6										5,550											925										
Air Conditioning Work	0										0											0										
Water Heater Repair Refrigerator Coil Clean	14 0										1,415 0											101										
Waterbed Mattress Pad	0										0											0										
Programmable Tstat	0										0	1										0										
Unspecified Utility Meas CO Detector	77										3,101											40	1									
Smoke Detector	22										280	1										13										
Fuses	0										0	1										0	1									
Htg Sys Safety Check Htg Sys Ventilation	0 51										0 15,261	1										0 299										
Water Heater Ventilation	25										3,675	1										147										
Bathroom Ventilation	38										5,895	1										155										
Dryer Ventilation Kitchen Ventilation	58 0										6,508	1										112	1									
Other Exhaust Ventilation	4										160	1										40										
Asbestos Removal (Minor)	0										0	1										0										
Health/Safety Repairs	30										4,826	1										161										
Health/Safety Other Consumables	0 4										20	-									_	0	1									
General Repairs	72										22,608											314										
Meter Refrig (no action)	45										0											0	1									
Meter Freezer (no action) Support	6 92										201,550											2,191	1									
Transportation Allowance	92 56										6,699	1										2,191										
Landlord Contr Misc	0										0,033	1										.20	1									
Landlord Contr Furnace	0										0	1										0	1									
Landlord Contr DHW Client Contr (Any)	0										0											0										
Lead Safe Work	33										3,217	-										97	1									
Unspecifed/Other	0										0											0										

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

Estimates are based upon reduced usage of the furnace use to shall improvements

Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

impacts from communuous constants trass required by ASHINALE QLZ. I not written impacts exceed summer decause meets and constant required season impacts for ownings with electric heat.

The total number of dwellings may exceed the number of measures included in cases where the utility manifest of measures in cases and the utility manifest of measures in cases and the utility manifest of mea

Total Reported Labor, Materials and Utility Admin Expenditures:

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$359,401

						Ι.								Billing A	djusted F	irst-Year S	avings				Avera	ge Billing	Adjusted				avings			
	Numi	er of Dw	ellings v	-		'		of Dwell	ings with	kWh Impacts	Spending on			Electricity				Gas			Spending on	l i	Ele	ctricity		1	Gas	1		
Measure	Total E	lectric	Gas Pro		uel Oil O	ther Co	Season	ating			Materials & Labor (\$)	Sun kW	nmer kWh	Wir kW	nter kWh	Annual kWh	Pk-Day therms	Annual therms		Fuel Oil Other		Summ kW		Winte		nnual Pk-D				uel Oil Other allons Mbtu
											1.7																			
Total Efficiency Measures	35	35	26	7	1	0	35	35			201,828	6.6		8.0		35,442	59	5,726	1,308	214	0 5,767	0.188	0	.227		1,013 2.:	29	220	187	214 -
Total Shell & Htg. Sys. Repl	35	35 35	26 26	7	1	0	33	35			154,505	3.9	4,316	4.0	6,196	10,512	56	5,161	1,269		0 4,414			.115	177	300 2.		198	181	214 -
Total Shell Measures Wall Insul.	35 13	10	9	2	1	0	33 10	35 1			75,377 11,255	3.9 1.2	4,316 1,462	4.0 0.9	6,196 1,379	10,512 2,841	30 5	2,753 505	822 32	105 52	0 2,154 0 866			.115	177 1,379	300 1. 284 0.		106 56	117 16	105 - 52 -
Open Blown Ceiling Insul	22	19	16	5	0	ő	19	1			14,531	1.8	2,152	1.5	2,289	4,441	10	941	291	0	0 660	0.094	113 1	.486	2,289	234 0.	64	59	58	
Cavity Fill Insul	8	2	6	1	1	0	2	0			7,582	0.1	98	0.0	0	98	5	464	166	49			49 0	.000	0	49 0.	84	77	166	49 -
Sloped Attic Insul Kneewall Insul	8 8	6 5	6	2	0	0	6 5	0			5,053 1,315	0.3 0.1	378 101	0.0	0	378 101	3	299 49		0	0 632 0 164			.000	0		54 09	50 8	63 21	: :
Infil. Reduction	34	30	25	7	1	ő	30	1			14,190	0.4	516	0.0	9	526	4	342			0 417			.006	9		15	14	11	5 -
Found./Crawl. Insul	13 6	1 0	9	4	0	0	1	0			7,922	0.1	61	0.0	0	61	2	220 36	53 66	0	0 609 0 181			.000	0		27	24	13	
Bandjoist Insul. Furnace Blower Fan ¹	6 34	34	2 26	4	0	0	-	0 34			1,087	0.0	0		0 2,971	0 2,971	0 (0)			0 (0)		0.000		.057	- 87		20 01)	18 (1)	16 (0)	(0) -
Exhaust Ventilation	20	20	15	5	0	0	20	20			12.442	-0.1	(453)		(453)	(906)			(28)	0	622	-0.003	(23) (0		(23)	(45) (0.		(6)	(6)	(0) -
Total Heating System Repl	24	0	19	4	1	0	-	0			79,128	0.0	0	0.0	0	0				108	0 3,297	-	- (20)	-	-		38	127	112	108 -
Condensing Htg Sys Rep	20	0	15	4	1	0	-	-			70,191	0.0	0		0	0		2,011	448		0 3,510	-	-	-	-	- 1.		134	112	108 -
Non-Cond Htg Sys Repl Electric Htg Sys Repl	4	0	4	0	0	0	1	- 0			8,936	0.0	0		0	0	4 0	396		0			1	:	1	- 10	08	99	- 1	: :
Heat Pump Repl	ő	Ö	0	0	0	ő	-	0			0	0.0	0		0	0	0			ő		-	-		-			-	-	
Other Htg Sys Repl	0	0	0	0	0	0	-	0			0	0.0	0	0.0	0	0	0	0	0	0	0 0	-	-		-			-	-	
						N	umber of	Measures	Installed	y Fuel Typ€																				
					uel					Fuel		Summer		Winter		Annual	Pk-Day			Fuel Oil Other		Summer		inter		nnual Pk-D				uel Oil Other
Water Heating	Total E	lectric 11	Gas Pro	opane 2	0il 0	ther To	otal El	ectric C	Gas Prop 32	ane Oil O	her 0 27,826	kW 0.0		kW		kWh 867	therms 3.3	therms 565		gallons Mbt		kW 0.000	N	.001		79 0.1		nerms g	allons g	allons Mbtu
Temp. Reduct.	0	0	0	0	0	0	0	0	0	0 0	0 0	0.0		0.0		0	0.0	0	0		0 0	-		-				-	-	
WH Wrap Pipe Insul.	0 32	0 11	0 19	0	0	0	0 32	0 11	0 19	0 0 2	0 0 604	0.0		0.0		0 482	0.0 0.2	0 59	0	0	0 0	0.000	0	.000		- 44 0	.01	- 3	- 3	
LF Showerhead	0	0	0	0	0	ő	0	0	0	0 0	0 004	0.0		0.0		402	0.2	0		0	0 0	-		-				-	-	
Faucet Aerator	0	0	0	0	0	0	0	0	0	0 0	0 0	0.0		0.0		0	0.0	0	0	0	0	-		-				-	-	
Std-Eff Wtr Htr Repl. Hi-Eff or Electric Wtr Htr Repl.	0 17	0	0 13	0	0	0	0 17	0	0 13	0 0	0 0 27,222	0.0		0.0		0 385	0.0 3.1	0 506		0	0 0 1,601	0.000		.003		128 0	.24	39	33	
Lighting	31	31	13	- 1	U		348	348	13	1 0	2,425	1.5		2.8		14,660		- 506	-					.003		473 -		-	-	
Refrigerator/Freezer ³	16	16					18	18			17,072	1.2		1.1		9,403	-	-	-		1,067	0.072	0	.068		588 -		-	-	
Refrigerator Removal	0	0					0 16	0			0	0.0 1.0		0.0 1.0		0 242	-	-	-		988	- 0.064	0	.060		 520 -		-	-	
Refrigerator Exchange Freezer Removal	16 0	16 0					0	16 0			15,814	0.0		0.0		8,313 0		-				0.064	U	- 000		520 -		-	-	
Freezer Exchange	2	2					2	2			1,258	0.1		0.1		1,090	-	-	-		629	0.067	0	.063		545 -		-	-	
Total Non-Efficiency Measures	35										157,573										4,502									
Misc Ins,Attic Access/Ven	29										5,103										176									
Duct Sealing Duct Insulation	3 11										350 1,560										117 142									
Damming Material	13										588										45									
Htg. Sys. Tune & Clear	10										872										87									
Htg. Sys./WH Other Air Conditioning Work	7										3,189 0										456									
Water Heater Repair	1										652										652									
Refrigerator Coil Clean	0										0										0									
Waterbed Mattress Pad Programmable Tstat	0										0										0									
Unspecified Utility Meas	ő										ő										Ö									
CO Detector	34										2,783										82									
Smoke Detector Fuses	28 1										1,986 60										71 60									
Htg Sys Safety Check	0										0										0									
Htg Sys Ventilation	25										8,891										356									
Water Heater Ventilation Bathroom Ventilation	14 17										5,364 2,254										383 133									
Dryer Ventilation	20										1,682										84									
Kitchen Ventilation	0										0										0									
Other Exhaust Ventilatior Asbestos Removal (Minor)	21 0										580 0										28									
Health/Safety Repairs	22										3,464										157									
Health/Safety Other	1										21										21									
Consumables General Repairs	0 32										0 13,050										408									
Meter Refrig (no action)	10										13,030										0	1								
Meter Freezer (no action)	6										0										0	4								
Support Transportation Allowance	35 0										99,199										2,834									
Landlord Contr Misc	0										0																			
Landlord Contr Furnace	0										Ō										0									
Landlord Contr DHW Client Contr (Any)	0										0										0									
Lead Safe Work	24										5,924										247	1								
Unspecifed/Other	0										. 0										1 0	1								

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

The total number of dwellings ma Dalhoff Associates, LLC

Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

impacts from communications are required by As-inches cut. 2. The winter impacts exceed summer occasion required association measure replacements of swellings was electric near.

"The field in market of idvallions may exceed the number of measures included in cases where the utility notability funds refliciencing measure replacements." The procreation of expreditions for each application of measures included in a cases where the utility notability funds refliciencing measure replacements. The procreation of expreditions for each application of measures included in a case where the utility to addition measures included.

Total Reported Labor, Materials and Utility Admin Expenditures: \$1,125,355

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$1,125,355

						1					1	1		В	Billing Ad	djusted Fi	irst-Year S	avings				Avera	ge Billing	Adjusted				nd Saving	gs			
	Numl	er of Dv	vellings	with Imp	oacts	Nι	ımber o	f Dwellin	gs with I	kWh Impac	S Spending	nn.		El	ectricity			-	Gas			Spending on	per Dw	elling Re	ceiving	•	ures		ias	1		
Measure	Total E	lectric	Gas Pro		Fuel Oil Ot	her Cooli	Season ing Hea	ting			Materials & Labor (Summ W	ner	Win	iter kWh	Annual kWh				Fuel Oil Other	r Materials	Summ kW	er	Winte	ter .		Pk-Day therms	Annual therms		Fuel Oil Other gallons Mbtu	
Total Efficiency Measures	91	91	79	6	0	0	91	91			607,7	90 1	17.7		16.6		54,787	220	21,646	2,310	0	0 6,679	0.195		0.182		602	2.79	274	385		i
Total Shell & Htg. Sys. Repl	91	91	79	6	0	0	84	91			506,0	15 1	16.6	18,687	15.0	23,398	42,085	207	19,236	2,250	0	0 5,561	0.198	222	0.165	257	462	2.61	243	375		
Total Shell Measures	91	91	79	6	0	0	84	91			359,8	30 1	16.6	18,687	14.8	23,169	41,855	120	11,145	1,003	0	0 3,954	0.198	222 (0.163	255	460	1.51	141	167		i
Wall Insul.	66	57	60	5	0		57	1			105,9		6.9	8,356	0.1	187	8,543	50	4,631	364	0	0 1,606			0.120	187	150	0.83	77	73		
Open Blown Ceiling Insul Cavity Fill Insul	78 32	69 23	66 28	6	0		68 23	6 2			44,1 29,1		5.7 1.1	6,929 1,339	5.3 0.9	8,347 1,472	15,277 2,811	27 15	2,496 1,421	399 67	0	0 566 0 910			0.891 0.472	1,391 736	221 122	0.41 0.54	38 51	67 33	1 1	
Sloped Attic Insul	34	27	30	2	ō		27	2			15,2		1.1	1,374	0.5	837	2,211	9	856	56	ő			51 (0.268	418	82	0.31	29			
Kneewall Insul	23	20	19	2	0		20	2			5,0		0.3	378	0.1	137	515	3	256	18	0	0 218			0.044	68	26	0.14	13			
Infil. Reduction Found./Crawl. Insul	90 28	79 11	78 24	6	0		78 10	6 2			57,2 27,6		1.1 0.5	1,322 628	0.2	322 956	1,644 1,584	12 6	1,077 598	80	0	0 637 0 988	0.014 0.052		0.034 0.306	54 478	21 144	0.15 0.27	14 25			
Bandjoist Insul.	58	4	48	6	0	0 -		4			4,9	55	0.0	020	0.4	594	594	2	169	32	0		0.000		0.095	148	148		4		1 1	
Furnace Blower Fan ¹	85	85	79	6	0	0 -		85				0	0.0	0	8.9	13,872	13,872	(1)	(51)	(5)	0	0 0	0.000	0 (0.105	163	163	(0.01)	(1	(1)		
Exhaust Ventilation	65	65	57	3	0		65	65			70,3		-0.2	(1,640)	(2.3)	(3,555)	(5,196)	(3)	(307)	(17)	0	0 1,083	-0.003		0.035)	(55)	(80)	(0.06)	(5			_
Total Heating System Repl	65 51	0	59 47	4	0	0 -		2			146,2 90.9		0.0	0	0.1	230	230	87	8,091 5,307	1,247 705	0	0 2,249 0 1,784	0.000	0 (0.074	115	115	1.47	137 113			4
Condensing Htg Sys Rep Non-Cond Htg Sys Repl	27	0	24	3	0	0 -		-			47,2		0.0	0	0.0	0	0	57 30	2,784	541	0		-	-				1.21	116			
Electric Htg Sys Repl	2	2	0	0	0	0 -		2			8,0	21	0.0	0	0.1	230	230	0	0	0	0			0 (0.074	115	115	-	-	-		
Heat Pump Repl	0	0	0	0	0	0 -		0					0.0	0	0.0	0	0	0	0	0	0	0	-	-	-	-	-	-	-	-		
Other Htg Sys Repl	U	U	U	U	U		-	U				J	J.U	U	0.0	U	0	U	0	U	U	0	-	-	-	-	-	<u> </u>		<u> </u>		-
					Fuel	Nun	nber of N	leasures Ir	stalled by	Fuel Type		Sum	mor	,	Winter		Annual	Pk-Day	Annual	Dronono	Fuel Oil Other		Summer	14	/inter		Annual	Pk-Day	Annual	Bronono	Fuel Oil Other	
Western	Total E		Gas Pr		Oil Ot			tric Ga		ne Oil (ther	k۱	w		kW		kWh	therms	therms		gallons Mbt	1	kW		kW		kWh	therms	therms	gallons	gallons Mbtu	
Water Heating Temp. Reduct	91	16 0	73	0	0	0 1	0	28 1	48 0	0 0	0 93,7		0.0		0.0		2,658	13.7	2,410	60	0	0 1,031	0.000		0.003		166	0.187	33	30	- : :	-
WH Wrap	ō	ō	ō	Ö	ō	0	0	Ō	0	0 0	ō	0	0.0		0.0		0	0.0	0	0	ō	0 0	-		-		-	-	-	-		
Pipe Insul.	90	16	72	2	0		90		72	2 0	0 1,7		0.0		0.0		749	0.6	215	6	0	0 19	0.000		0.000		47	0.01	3			
LF Showerhead Faucet Aerator	22 2	4 0	18 2	0	0		23 2			0 0	0 2		0.0		0.0		786 0	0.4	133	0	0	0 10	0.000	,	0.004		197	0.02	7	1	: :	
Std-Eff Wtr Htr Repl.	0	0	0	0	Ö		0			0 0	0	0	0.0		0.0		0	0.0	0	0		0	-		-		-	-	- '	-		
Hi-Eff or Electric Wtr Htr Repl.	65	8	55	2	0		65		55	2 0	0 91,8		0.0		0.0		1,123	12.6		54	0	0 1,413			0.003		140		37			_
Lighting	58 8	58 8					39 8	239			1,6 6,2		0.6		1.1 0.4		5,917 4,127	-		-		784			0.020 0.052		102 516		-	-		4
Refrigerator/Freezer ³ Refrigerator Removal	0	0					0	0			0,2		0.4		0.4		4,127	-				764	0.056	,	0.052		-	-	- :	-	<u> </u>	4
Refrigerator Exchange	7	7					7	7			6,0	24	0.4		0.4		3,582	-	-	-		861	0.054		0.050		512	-	-	-		
Freezer Removal Freezer Exchange	0	0					0	0					0.0		0.0		0 545	-	-	-		249	0.067		0.063		- 545	-	-	-		
	'												0.1		0.1		343	-		-		•	0.007	,	0.003		343	-		-		_
Total Non-Efficiency Measures Misc Ins,Attic Access/Ven	91 89										517,5 16,4											5,688										4
Duct Sealing	85										7,4	97										88										
Duct Insulation	26										1,2											47										
Damming Material Htg. Sys. Tune & Clean	64 18										1,6 1,0											26 59										
Htg. Sys./WH Other	41										7,7											189										
Air Conditioning Work	11											60										33										
Water Heater Repair Refrigerator Coil Clean	5 0											0										12										
Waterbed Mattress Pad	ō											0										Ö										
Programmable Tstat	10											70										97										
Unspecified Utility Meas CO Detector	0 87										4,8	0										56	1									
Smoke Detector	52										3,0	30										56 58										
Fuses	9										1,0											119										
Htg Sys Safety Check Htg Sys Ventilation	0 65										12,9	0 15										199										
Water Heater Ventilation	62										8,4	12										136										
Bathroom Ventilation	10										1,1											118										
Dryer Ventilation Kitchen Ventilation	68 0										5,5	0										81										
Other Exhaust Ventilation	55										1,2	9										22										
Asbestos Removal (Minor)	12										17,9											1,500										
Health/Safety Repairs Health/Safety Other	84 18										65,1 8											775 47										
Consumables	35										1,4	91										43										
General Repairs	88										32,8	_										373	1									
Meter Refrig (no action) Meter Freezer (no action)	68 32											0										0										
Support	91										304,1											3,343										
Transportation Allowance Landlord Contr Misc	35 0										3,9	31										112										
Landlord Contr Misc	0											0																				
Landlord Contr DHW	ō											0										0										
Client Contr (Any)	0										45.0	0										0	1									
Lead Safe Work Unspecifed/Other	64 0										15,8	0										248										
J John Grandi												-																				_

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

² Impacts from continuous exhaust fans required by ASHAE 62.2. The winter impacts exceed summer because these also include heating season impacts for deelings with electric heat.

3 The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Total Reported Labor, Materials and Utility Admin Expenditures: \$509,593

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$509,593

						1				İ	1		Billing A	diveted E	irst-Year S	avinge				1	Avoran	o Billina	Adjustos				nd Saving	,		
	Num	ber of D	wellings	with Imp	pacts	Num	ber of Dw	vellings with kWh Im	pacts				Dilling A	ujusted F	ıısı-rear S	avings					Averag		Aajusted elling Re				iu saving	15		
			. 3-		Fuel	Sea		3		Spending on Materials	Sum		Electricity Wir	ntor	Annual		Gas Annual	Propose	Fuel Oil	Othor	Spending on Materials	Summ		ectricity	or ^	lanus!	Ga Pk-Day	as Annual	Dropone	Fuel Oil Other
Measure	Total	Electric	Gas Pi			er Cooling				& Labor (\$)	kW	kWh		kWh	kWh		therms		gallons		& Labor (\$)							therms		gallons Mbtu
Total Efficiency Measures	32	32	29	2	0	0 32	32			267,418	6.1		3.6		16,056	66	6,546	600	0	0	8,357	0.190		0.112		502	2.28	226	300	
•			29				32				5.5	6.064		4.072		61		549			6,791			0.081	127			196		
Total Shell & Htg. Sys. Repl Total Shell Measures	32 32	32 32	29	2	0	0 32	32			217,304 146,803	5.5	6,064 6,064	2.6 2.5	4,073 3,951	10,136 10,015	36	5,679 3,332	260	0	0	4,588	0.172		0.081	127	317 313	2.10 1.23	196		
Wall Insul.	9	9	9	0	0	0 9	0			20,732	1.1	1,342	0.0	0 794	1,342	8	730 749	0	0	0	2,304	0.124		0.000	0 794	149	0.87	81 27	- 23	
Open Blown Ceiling Insul Cavity Fill Insul	31 7	31 7	28 6	0	0	0 31 7	1			29,146 6,407	2.2 0.4	2,647 496	0.5 0.2	794 322	3,441 818	8 4	749 375	46 0	0	0	940 915	0.071 0.059		0.508 0.206	794 322	111 117	0.29 0.67	63	- 23	: :
Sloped Attic Insul	12	12	12	0	0	0 12				5,892	0.7	839	0.0	0	839	5	505		0	0	491	0.058	70	0.000	0	70	0.45	42	-	
Kneewall Insul Infil. Reduction	14 32	14 32	14 29	0	0	0 14 0 32	0			4,406 42,544	0.4	507 525	0.0 0.2	0 305	507 830	3 7	245 632	0 89	0	0	315 1,330	0.030		0.000 0.195	0 305	36 26	0.19	17 22	- 45	1 1
Found./Crawl. Insul	14	6	13	1	0	0 6	0			10,469	0.4	377	0.0	0	377	2	184	134	0	0	748	0.052		0.000	0	63	0.15	14	134	
Bandjoist Insul.	16	0	15	1	-	0 -	0			2,077	0.0	0	0.0	0	0	1		7	0	0	130	-		-	-	-	0.04	4	7	
Furnace Blower Fan ¹ Exhaust Ventilation ²	31 28	31 28	29 25	2	-	0 -	31 28			0 25 130	0.0	0 (668)		3,581 (1,051)	3,581	(0)			0	0	0	0.000	(24)		116	116 (61)	(0.01)	(0)	(1)	
Total Heating System Repl	26	1	23	2	0	0 -	1			70,501	0.0	(000)	0.1	122	122	25		289	0	0	2,712	0.000	0 (24)		122	122	1.09	102		
Condensing Htg Sys Rep	24	0	22	2		0 -	-			63,656	0.0	0	0.0	0	0	24	2,238	289	0	0	2,652	-	-	-	-	-	1.09	102	144	
Non-Cond Htg Sys Repl Electric Htg Sys Repl	1	0	1	0		0 -	- 1			2,045 4,800	0.0	0	0.0	0 122	0 122	1 0	109		0	0	2,045 4,800	0.000	- 0	0.078	122	122	1.17	109		1 1
Heat Pump Repl	0	0	ō	ő		0 -	0			0	0.0	0	0.0	0	0	0	0		0	0	0	-	-	-	-	-	-	-	-	
Other Htg Sys Repl	0	0	0	0	0	0 -	0			0	0.0	0	0.0	0	0	0	0	0	0	0	0	-	-	-	-	-	-	-	-	
						Numb	er of Measu	res Installed by Fuel_T	урє													_								
	Total	Electric	Gas P		Fuel Oil Oth	er Total	Electric	Fu Gas Propane O	el il Other		Summer kW		Winter kW		Annual kWh	Pk-Day therms		Propane gallons	Fuel Oil gallons			Summer kW		/inter kW			Pk-Day therms	Annual therms		Fuel Oil Other gallons Mbtu
Water Heating Temp. Reduct	31	3	26	2	0	0 57	6	48 3	0 0	46,517	0.0		0.0		571		867	52	0	0	1,501			0.004		190	0.195	33		
Temp. Reduct. WH Wrap	0	0	0	0	0	0 0	0	0 0	0 0	0	0.0		0.0		0	0.0	0	0	0	0	0			-		-	-			
Pipe Insul.	30	3	25	2	0	0 30	3	25 2	0 0	300	0.0		0.0		139	0.2	71		0	0	10	0.000		0.000		46	0.01	3	4	
LF Showerhead Faucet Aerator	2	1	1 0	0		0 2 0	1 0		0 0	20 0	0.0		0.0		175 0	0.0	7		0	0	10 0	0.000		0.004		175	0.02	7	-	
Std-Eff Wtr Htr Repl.	0	0	0	0		0 0			0 0	0	0.0		0.0		0	0.0			0	0	0	-				-	-		-	1 1
Hi-Eff or Electric Wtr Htr Repl.	25	2	22	1	0	0 25	2		0 0	46,197	0.0		0.0		257	4.8	789		0	0	1,848	0.000		0.003		128	0.22	36	43	
Lighting Refrigerator/Freezer ³	30	30				287	287			2,089 1,508	0.5		0.8		4,325 1,023	-		-		-	70 754	0.015		0.028 0.059		144 512	-		-	
Refrigerator Removal	0	0				0	0			0	0.0		0.0		0	-	-	-	-	-	0	-		-		-	-	-	-	
Refrigerator Exchange Freezer Removal	2	2				2	2			1,508	0.1 0.0		0.1 0.0		1,023	-	-	-	-	-	754	0.063		0.059		512	-	-	-	
Freezer Exchange	0	0				0	0			0	0.0		0.0		0	- 1	- :	- 1			0			-		-		-	-	
Total Non-Efficiency Measures	32									242,176											7,568									
Misc Ins,Attic Access/Ven	32									13,402											419									
Duct Sealing Duct Insulation	6 17									2,106 2,896											351 170									
Damming Material	22									1,746											79									
Htg. Sys. Tune & Clean	5									2,380											476									
Htg. Sys./WH Other Air Conditioning Work	6 1									2,774 750											462 750									
Water Heater Repair	0									0											0									
Refrigerator Coil Clean Waterbed Mattress Pad	0									0											0 n									
Programmable Tstat	0									0											0									
Unspecified Utility Meas CO Detector	0 31									1,761											0 57									
Smoke Detector	30									966											32									
Fuses	0									0											0									
Htg Sys Safety Check Htg Sys Ventilation	0 26									0 6,583											0 253									
Water Heater Ventilation	22									4,325											197									
Bathroom Ventilation Dryer Ventilation	27 28									4,952 3,837											183 137									
Kitchen Ventilation	0									0,037											0									
Other Exhaust Ventilation	0									0											0									
Asbestos Removal (Minor) Health/Safety Repairs	0 30									0 28,228											0 941									
Health/Safety Other	8									571											71									
Consumables General Repairs	0 32									0 29,966											0 936									
Meter Refrig (no action)	19									29,966											0 anp									
Meter Freezer (no action)	7									0											0									
Support Transportation Allowance	30 0									129,764 0											4,325									
Landlord Contr Misc	0									0											0									
Landlord Contr Furnace	0									0											0									
Landlord Contr DHW Client Contr (Anv)	0									0											0									
Lead Safe Work	22									5,170											235									
Unspecifed/Other	0									0											0									

Estimates are based upon reduced usage of the furnace due to shell improvements

Impacts from continuous exhaust fans required by ASHPAE 02. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Total Reported Labor, Materials and Utility Admin Expenditures: \$315,958

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$315,958

						1						1			Billing A	djusted F	irst-Year S	avings					Avera	ge Billing			Year C		nd Savin	js			
	Numl	er of Dw	ellings w	ith Impa	acts	Nu	mber of	Dwellin	gs with	kWh Im	npacts	Spending on			Electricity			1	Gas			Sp	ending on	per Dw	elling R	eceivin lectricit	•	sures	l G	as	1		
Measure	Total E	lectric (as Pro	Fi pane C		er Cooli	eason ng Heati	ng				Materials & Labor (\$)	Sun kW	nmer kWh		nter kWh	Annual kWh	Pk-Day therms			Fuel Oil gallons	Other N	laterials Labor (\$)	Sumn kW	er	Win kW	ter		Pk-Day therms	Annual therms		Fuel Oil Otl gallons Mb	
Total Efficiency Measures	22	22	15	2	0	0 2	22	22				194,906	5.2		8.4		22,407	35	3,197	482	0	0	8,859	0.238		0.381		1,018	2.31	21:	3 241		-
Total Shell & Htg. Sys. Repl	22	22	15	2				22				167,824	4.8	5,333	7.7	11,418	16,751	33			0	0	7,628			0.352	519	761		194			-
Total Shell Measures Wall Insul.	22	22	15	2	0	0 2	22	22				83,129	4.8	5,333 1,533	7.2	10,669	16,002	19	1,638 691	208	0	0	3,779			0.329	485 717	727		10:			-
Open Blown Ceiling Insul	8 18	18	11	2	0	0 1	8	5				13,543 16,846	1.3 2.6	3,098	1.0 4.0	1,434 5,865	2,967 8,964	8 5	423	129	0	0	1,693 936	0.159	192 172	0.466	1,173	371 498	1.31 0.44	11:			_
Cavity Fill Insul	2	2	1	0		0	2	1				390	0.0	38	0.1	140	178	0	8	0	0	0	195		19	0.095	140	89	0.10		3 -		-
Sloped Attic Insul	6	4	5	0			4	1				3,503	0.2	297		860	1,157	2	214		0	0	584	0.062	74	0.583	860	289		4:			-
Kneewall Insul	22	0 22	1 15	2		0 2	0	0 5				138 16 482	0.0	0 427	0.0	0 1.742	2.168	0	264	73	0	0	138 749	0.016	- 19	0.236	348	- 99	0.00	18	3 36		
Found./Crawl. Insul	8	5	5	1	0		5	2				3,182	0.4	438		448	886	0	40		0	0	398	0.073		0.152	224	177			3 12		-
Bandjoist Insul.	7	2	5	0	-	0 -		2				767	0.0	0	0.1	168	168		59	0	0	0	110	0.000	0	0.057	84	84	0.13	12	2 -		-
Furnace Blower Fan ¹	17	17	15	2	-	0 -		17				0	0.0	0		2,041	2,041	(0)				0	0	0.000		0.081	120	120	(0.01)	(-
Exhaust Ventilation Total Heating System Repl	16 18	16 5	11	1		0 1	16	16				28,278 84,695	-0.1 0.0	(497)		(2,029) 749	(2,527) 749	(1)			0	0	1,767 4,705	-0.004 0.000		0.102	(127) 150	(158) 150	(0.06)	110		3)	
Condensing Htg Sys Rep	13	0	11	2		0 -						51,470	0.0	0		0	0				0	0	3,959	-	-	-	-	-	1.32	110			_
Non-Cond Htg Sys Repl	0	0	0	0		0 -						0	0.0	0	0.0	0	0	0	0	0	0	0	0	-	-	-	-	-	-	-	-		-
Electric Htg Sys Repl	3 2	3	0	0		0 -		3				9,850	0.0	0		487	487	0	0		0	0	3,283			0.110	162	162	-		-		-
Heat Pump Repl Other Htg Sys Repl	0	0	0	0		0 -		0				23,375	0.0	0		261 0	261 0	0	0	0	0	0	11,688 0	0.000	- 0	0.089	131	131	-	- :	1		-
···a -/- ··		-	-	-	-							Ĭ						ľ		Ť		-											_
				F	uel	Num	ber of Me	easures li	nstalled b	by Fuel T	ype iel		Summer		Winter		Annual	Pk-Day	Annual	Propage	Fuel Oil C	other		Summer	,	Winter		Annual	Pk-Day	Annual	Propens	Fuel Oil Otl	her
		lectric C			Oil Oth				s Prop	ane O	il Other		kW		kW		kWh	therms	therms	gallons	gallons			kW		kW		kWh	therms	therms	gallons	gallons Mb	
Water Heating Temp. Reduct	18	7	10	1		0 4	0	16	0	5	0 0	24,462	0.0		0.0		1,567		283		0	0	1,359	0.000		0.004		224	0.160	- 28	3 43	3	-
WH Wrap	0	0	0	0			0	0	0	0	0 0	0	0.0		0.0		0	0.0			0	0	0	-						- :	-		-
Pipe Insul.	12	5	7	0			12	5	7	0	0 0	108	0.0		0.0		246	0.1	20		0	0	9	0.000		0.000		49	0.01	;			-
LF Showerhead	9	5 5	3	1			9	5 5	3		0 0	77 36	0.0		0.0		1,004 189	0.1 0.0	21		0	0	9	0.000		0.005		201 38			7 8		-
Faucet Aerator Std-Eff Wtr Htr Repl.	0	0	0	0			0		2		0 0	36	0.0		0.0		189	0.0			0	0	5	0.000		0.001		- 38	0.01		3 3		
Hi-Eff or Electric Wtr Htr Repl.	10	1	8	1		0 1	10	1	8	1	0 0	24,240	0.0		0.0		128	1.5			ő	Ö	2,424			0.003		128		30	33		-
Lighting	16	16				11		16				345	0.2		0.3		1,723		-	-	-	-	22			0.021		108		-	-		-
Refrigerator/Freezer³ Refrigerator Removal	3	3					0	0				2,275	0.3		0.3		2,366	-	-	-		-	758	0.097		0.091		789	-		-		-
Refrigerator Exchange	2	2					2	2				1,475	0.0		0.0		1,276	-	- :			-	738	0.078		0.073		638		- :	-		-
Freezer Removal	0	0					0	0				0	0.0		0.0		0	-	-	-		-	0	-		-		-	-	-	-		-
Freezer Exchange	1	1					2	2				800	0.1		0.1		1,090	-	-	-	-	-	800	0.134		0.125		1,090	-	-	-		<u>. </u>
Total Non-Efficiency Measures	22											121,052											5,502										
Misc Ins,Attic Access/Ven	20 2											4,129 375											206 188										
Duct Insulation	9											474											53										
Damming Material	14											1,098											78										
Htg. Sys. Tune & Clear Htg. Sys./WH Other	7											1,525 2,278											218 570										
Air Conditioning Work	0											2,276											0										
Water Heater Repair	2											260											130										
Refrigerator Coil Clean Waterbed Mattress Pad	0											0											0										
Programmable Tstat	0											0											0										
Unspecified Utility Meas	0											0											Ō										
CO Detector Smoke Detector	21 14											644 575											31 41										
Fuses	0											0											0										
Htg Sys Safety Check	0											0											. 0										
Htg Sys Ventilation Water Heater Ventilation	13 9											4,950 2.075											381 231										
Bathroom Ventilation	5											961											192										
Dryer Ventilation	14											1,452											104										
Kitchen Ventilation Other Exhaust Ventilation	0 11											0 319											0 29										
Asbestos Removal (Minor)	0											0											0										
Health/Safety Repairs	16											5,879											367										
Health/Safety Other Consumables	2											81											41										
General Repairs	22											21,670											985										
Meter Refrig (no action)	20											0											0										
Meter Freezer (no action) Support	11 19											0 68,564											3,609										
Transportation Allowance	19											08,564											3,009 N										
Landlord Contr Misc	0											ő											ő										
Landlord Contr Furnace	0											0											0										
Landlord Contr DHW Client Contr (Any)	0											0											0										
																							U										
Lead Safe Work Unspecifed/Other	18 0											3,745										Ш	208										

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

³ The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Total Reported Labor, Materials and Utility Admin Expenditures: \$944,073

Utility Administration Expenditures:

\$944,073 Total Labor and Material Expenditures:

	Numb	er of Dw	allinas v	vith Imr	nacte	١.	Jumbar	of Dwell	lings with kV	Vh Imnacts				Billing A	djusted F	irst-Year S	avings				Aver	age Billing per Dv	Adjust				nd Savin	gs		
			_		Fuel		Season		migs with Kr	in impacts	Spending on Materials	Sum	nmer	Electricity Wir	nter	Annual		Gas Annual	Propane	Fuel Oil Of	Spending or Materials		Ē	Electricity Wint	y ter	Annual	Pk-Day	as Annual	Propane Fue	el Oil Other
Measure	Total E	lectric	Gas Pro	pane	Oil O	ther Co	oling He	ating			& Labor (\$)	kW	kWh	kW	kWh	kWh	therms	therms	gallons	gallons M	otu & Labor (\$)	kW	kWh	kW	kWh	kWh	therms	therms	gallons gal	lons Mbtu
Total Efficiency Measures	57	57	55	1	0	0	57	57			533,540	20.5		11.5		47,841	214	18,906	419	0	0 9,36	0.359		0.202		839	3.89	344	419	
Total Shell & Htg. Sys. Repl	57	57	55	1	0	0	56	57			460,500	19.2	22,913	9.6	13,548	36,461	204	17,150	383	0	0 8,07			0.168	238	640	3.70	312		
Total Shell Measures Wall Insul	57 45	57 44	55 44	11	0	0	56 44	57 0			288,589 80,678	19.2 7.9	22,913 9.487	9.6	13,548	36,461 9.487	127 48	10,675 4.075	243 91	0	0 5,06 0 1,79		409 216	0.168	238 0	640 216	2.31	194 93		
Open Blown Ceiling Insul	52	51	50	1	0	0	51	1			55,011	6.4	7,675	2.1	2,942	10,617	40		70	0	0 1,75		150		2,942	208		68		: :
Cavity Fill Insul	18	16	17	1	0	0	16	0			15,973	1.1	1,380	0.0	0	1,380	9	761	19	0	0 88	7 0.072	86	0.000	0	86	0.53	45	19	
Sloped Attic Insul Kneewall Insul	23	23	22 18	1	0	0	23 18	0			11,243	1.2	1,462	0.0	0	1,462	8	704 207	38	0	0 48		64	0.000	0	64	0.38	32		
Infil. Reduction	18 57	18 56	18 55	0	0	0	18 56	1			8,603 94,051	0.4 1.1	473 1,325	0.0	475	473 1,800	2 13			0	0 47 0 1,65		26 24	0.000 0.337	0 475	26 32	0.14 0.23	12 20	15	1 1
Found./Crawl. Insul	37	16	35	1	0	0	15	1			20,976	1.2	1,418	0.8	1,185	2,602	6	527	11	0	0 56	7 0.078	95	0.840	1,185	163	0.18	15		
Bandjoist Insul.	3	0	3	0	0	0	-	0			548	0.0	0		0	0	0			0	0 18		-	-	-	-	0.07	6		
Furnace Blower Fan	56	56	55	1	0	0	-	56			0	0.0	0		9,634	9,634	(0)			0	0			0.122		172	(0.01)	(1		
Exhaust Ventilation ² Total Heating System Repl	12 48	12	11	0	0	0	12	12			1,508 171,910	0.0	(305)	(0.5)	(688)	(994)	(1)			0	0 12		(25)	(0.041)	(57)	(83)	(0.06)	138		
Condensing Htg Sys Rep	48	0	47	1	0	0	•	-			171,910	0.0	0	0.0	0	0		6,475		0	0 3,58		-			÷	1.64	138		
Non-Cond Htg Sys Repl	0	0	0	Ó	0	0	-	-			0	0.0	0	0.0	ō	0	0	0	0	0	0		-	-	-	-	-	-	-	
Electric Htg Sys Repl	0	0	0	0	0	0	-	0			0	0.0	0	0.0	0	0	0			0	0	0 -	-	-	-	-	-	-	-	
Heat Pump Repl Other Htg Sys Repl	0	0	0	0	0	0	1	0			0	0.0	0	0.0 0.0	0	0	0	0	0	0	0	- n -	- 1		1	- 1	-		1	: :
	T J				-	-					ı ,	0.0		0.0							-									
					Fuel	N	umber of	Measures	s Installed by F	uel Type		Summer		Winter		Annual	Pk-Day	Annual	Propaga	Fuel Oil Otl	or	Summer		Winter		Annual	Pk-Day	Annual	Propane Fu	ol Oil Other
	Total E				Oil O				Gas Propane	Oil Other		kW		kW		kWh	therms	therms	gallons	gallons M	otu	kW		kW		kWh	therms	therms	gallons gal	
Water Heating Temp. Reduct.	56	<u>4</u> 0	51	1	0		101	4	95 2	0 0	68,121	0.0		0.0		182	10.3	1,757	36	0	0 1,21			0.000			0.202	34	36	
WH Wrap	0	0	0	0	0	0	0	0	0 0		0	0.0		0.0		0	0.0	0	0	0	0	D -		-		- 1	-		1	: :
Pipe Insul.	56	4	51	1	0	0	56	4	51 1	0 0	380	0.0		0.0		182	0.4	147	3	ō	0	7 0.000		0.000		45	0.01	3	3	
LF Showerhead	0	0	0	0	0	0	0	0	0 0		0	0.0		0.0		0	0.0	0		0	0	0 -		-		-	-	-	-	
Faucet Aerator Std-Eff Wtr Htr Repl.	0	0	0	0	0	0	0	0	0 0		0	0.0		0.0		0	0.0	0	0	0	0	0 -		-		-	-		1	: :
Hi-Eff or Electric Wtr Htr Repl.	45	0	44	1	0	0	45	0	44 1	0 0	67,741	0.0		0.0		ō	9.9	1,610		ő	0 1,50	5 -		-		-	0.22	37	33	
Lighting	33	33					350	350			753	0.8		1.5		7,549		-	-		- 2			0.044		229			-	
Refrigerator/Freezer ³ Refrigerator Removal	7	7					7	7			4,167	0.4		0.4		3,648	-	-	-		- 59	0.064		0.060		521	-		-	
Refrigerator Removal Refrigerator Exchange	5	5					0 5	5			0 3,438	0.0		0.0		2,558					- 68	0.063		0.059		- 512	-	- :	1	
Freezer Removal	0	0					0	0			0	0.0		0.0		0	-	-	-	-	-	0 -		-		-	-	-	-	
Freezer Exchange	2	2					2	2			729	0.1		0.1		1,090	-	-	-	-	- 36	0.067		0.063		545	-	-		<u> </u>
Total Non-Efficiency Measures	57										410,533										7,20	2								
Misc Ins,Attic Access/Ven	49										8,783										17									
Duct Sealing Duct Insulation	1 15										490 789										49 5									
Damming Material	24										852										3	5								
Htg. Sys. Tune & Clear	11										1,797										16									
Htg. Sys./WH Other Air Conditioning Work	13 15										17,092 3,419										1,31 22									
Water Heater Repair	5										982										19									
Refrigerator Coil Clean	0										0																			
Waterbed Mattress Pad	0										0											0								
Programmable Tstat Unspecified Utility Meas	0										0											n l								
CO Detector	47										2,433										5 2	2								
Smoke Detector	22										546										2	5								
Fuses	0										0											n n								
Htg Sys Safety Check											8,841										22									
Htg Sys Safety Check Htg Sys Ventilation	40										4,279										15 6	3								
Htg Sys Ventilation Water Heater Ventilation	40 28																													
Htg Sys Ventilation Water Heater Ventilation Bathroom Ventilation	40 28 21										1,437										1 4	n .								
Htg Sys Ventilation Water Heater Ventilation	40 28										1,437 1,664 0										4	0								
Htg Sys Ventilation Water Heater Ventilation Bathroom Ventilation Dryer Ventilation Kitchen Ventilation Other Exhaust Ventilatior	40 28 21 42 0 35										1,664 0 886										2	0 0 5								
Htg Sys Ventilation Water Heater Ventilation Bathroom Ventilation Dryer Ventilation Kitchen Ventilatior Other Exhaust Ventilatior Asbestos Removal (Minor)	40 28 21 42 0 35										1,664 0 886 0										2	0 5 0								
Htg Sys Ventilation Water Heater Ventilation Bathroom Ventilation Dryer Ventilation Kitchen Ventilation Other Exhaust Ventilatior	40 28 21 42 0 35										1,664 0 886										57 9	0 0 5 0 9								
Hig Sys Ventilation Water Heater Ventilation Bathroom Ventilation Dryer Ventilation Consumer Ventilation Other Exhaust Ventilation Asbestos Removal (Minor) Health/Safety Repairs Health/Safety Other Consumables	40 28 21 42 0 35 0 53 7										1,664 0 886 0 30,678 649										57 9 2	0 0 5 0 9 3								
Hig Sys Ventilation Water Heater Ventilation Bathroom Ventilation Dryer Ventilation Other Exhaust Ventilatior Other Exhaust Ventilatior Asbestos Removal (Minor) Health/Safety Repairs Health/Safety Other Consumables General Repairs	40 28 21 42 0 35 0 53 7										1,664 0 886 0 30,678 649 937 36,500										57 9	0 0 5 0 9 3								
Hig Sys Ventilation Water Heater Ventilation Bathroom Ventilation Dryer Ventilation Kitchen Ventilation Kitchen Ventilatior Other Exhaust Ventilatior Asbestos Removal (Minor) Health/Safety Repairs Health/Safety Other Consumables General Repairs Meter Refrig (no action) Meter Freezer (no action)	40 28 21 42 0 35 0 53 7 39 57										1,664 0 886 0 30,678 649 937 36,500 0										57 9 2 64	0 0 5 0 9 9 3 3 4 0 0								
Hig Sys Ventilation Water Heater Ventilation Bathroom Ventilation Dryer Ventilation Kitchen Ventilation Other Exhaust Ventilatior Other Exhaust Ventilatior Asbestos Removal (Minor) Health/Safety Repairs Health/Safety Other Consumables General Repairs Meter Refing (no action) Meter Freezer (no action) Support	40 28 21 42 0 35 0 53 7 39 57										1,664 0 886 0 30,678 649 937 36,500 0 0										57 9 2	0 0 5 0 9 9 3 3 4 0 0								
Hig Sys Ventilation Water Heater Ventilation Bathroom Ventilation Dryer Ventilation Kitchen Ventilation Kitchen Ventilation Kitchen Ventilatior Asbestos Removal (Minor) Health/Safety Repairs Health/Safety Other Consumables General Repairs Meter Refrig (no action) Meter Freezer (no action)	40 28 21 42 0 35 0 53 7 39 57										1,664 0 886 0 30,678 649 937 36,500 0										57 9 2 64	0 0 5 0 9 9 3 3 4 0 0								
Hig Sys Ventilation Water Heater Ventilation Bathroom Ventilation Dryer Ventilation Other Exhaust Ventilation Kitchen Ventilation Kitchen Ventilation Cother Exhaust Ventilatior Asbestos Removal (Minor) Health/Safety Repairs Health/Safety Other Consumables General Repairs Meter Refing (no action) Meter Freezer (no action) Support Transportation Allowance Landlord Contr Furnace	40 28 21 42 0 35 0 53 7 39 57 36 9 57 0 0										1,664 0 886 0 30,678 649 937 36,500 0 268,206										57 9 2 64	0 0 5 0 9 9 3 3 4 0 0								
Hig Sys Ventilation Water Heater Ventilation Bathroom Ventilation Dryer Ventilation Origer Ventilation Kitchen Ventilation Kitchen Ventilation Kitchen Ventilation Abbestos Removal (Minor) Health/Safety Repairs Health/Safety Other Consumables General Repairs Meter Refrig (no action) Meter Freezer (no action) Support Transportation Allowance Landlord Contr Misc Landlord Contr OHW	40 28 21 42 0 35 0 53 7 39 57 36 9 57 0 0 0										1,664 0 886 0 30,678 649 937 36,500 0 0 268,206										57 9 2 64	0 0 5 0 9 9 3 3 4 0 0								
Hig Sys Ventilation Water Heater Ventilation Bathroom Ventilation Dryer Ventilation Other Exhaust Ventilation Kitchen Ventilation Kitchen Ventilation Cother Exhaust Ventilatior Asbestos Removal (Minor) Health/Safety Repairs Health/Safety Other Consumables General Repairs Meter Refing (no action) Meter Freezer (no action) Support Transportation Allowance Landlord Contr Furnace	40 28 21 42 0 35 0 53 7 39 57 36 9 57 0 0										1,664 0 886 0 30,678 649 937 36,500 0 0 268,206										57 9 2 64	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0								

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

³ The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Total Reported Labor, Materials and Utility Admin Expenditures: \$869,299

Utility Administration Expenditures:

\$869,299 Total Labor and Material Expenditures:

	Num	ber of D)wellina	s with li	mpact	ts	Num	ber of D	wellings with	kWh Impacts				Billing A	djusted F	irst-Year S	avings					Average			ted Firs Receivii			nd Savin	gs		
			9		Fuel	-	Sea				Spending on Materials	Sum		Electricity	nter	Annual	Pk-Day	Gas	Propane	Eugl Oil		Spending on Materials	Sumn	•	Electricit Win	ty		Pk-Day	as Annual	Brongra	Fuel Oil Other
Measure	Total	Electric	Gas	Propane		Other	Cooling				& Labor (\$)	kW	kWh	kW	kWh	kWh	therms	therms		gallons		& Labor (\$)		kWh	kW	kWh		therms	therms		gallons Mbtu
Total Efficiency Measures	75	75	35	18	11	0	75	75			448,804	19.0		27.3		78,954	79	7,230	4,071	1,397	0	5,984	0.253		0.364		1,053	2.25	207	226	127 -
Total Shell & Htg. Sys. Repl	75	75	35	18	11	0	74	75			367.776	16.6	19.259	23.4	34,519	53.777	75	6.607	3.677	1.397	0	4.904	0.225	260	0.312	460	717	2.14	189	204	127 -
Total Shell Measures	75	75	35	18		_	74				222,527	16.6	19,259	23.0	33,908	53,166	40			1,008	0	2,967	0.225	260	0.307	452			100		92 -
Wall Insul.	37	36	18	7	7	. 0	36	5			34,671	5.7	6,838	5.9	8,657	15,495	10	883	382	246	0	937	0.157	190	1.174	1,731		0.56	49	55	35 -
Open Blown Ceiling Insul Cavity Fill Insul	54 8	53 6	24	12			52 5	8			52,627 5.946	7.2 0.2	8,687 276	9.3 0.3	13,763 403	22,450 680	18	1,557 72		450 44	0	975 743	0.139	167 55	1.167 0.274				65 36	68 48	45 - 22 -
Sloped Attic Insul	11	10	5	3	3	0	10				4,620	0.2	663	0.0	0	663	2	153		82	0	420	0.055	66	0.000	403			31	32	27 -
Kneewall Insul	4	4	3	0	1	0	4	C			1,151	0.2	183	0.0	0	183	1	65	0	12	0	288	0.038	46	0.000	0	46	0.25	22	-	12 -
Infil. Reduction	74	73	35	17			72				59,502	1.2	1,486	1.4	2,059	3,544	6	537		87	0	804	0.017	21	0.127	187			15	17	8 -
Found./Crawl. Insul Bandjoist Insul.	52 45	28 4	27 21	13 12	6	0	25	6			20,005 6,575	1.7 0.0	2,053 0		3,070 695	5,123 695	2		207 77	76 37	0	385 146	0.068	82 0	0.347 0.118	512 174			7	16 6	13 - 5 -
Furnace Blower Fan ¹	64	64	35	18	11			64			0,575	0.0	0		8,485	8,485	(0)			(5)	0	140	0.000	0	0.090				(0)		
Exhaust Ventilation	32	32	15	6	5	. 0	32	32			37,430	-0.1	(927)		(3,225)	(4,152)			(31)	(20)	0	1,170	-0.004	(29)					(6)	(5)	(4) -
Total Heating System Repl	53	4	30	14		0		4			145,249	0.0	0	0.4	611	611	35	3,117	1,697	389	0	2,741	0.000		0.104	153		1.18	104		78 -
Condensing Htg Sys Rep	40	0	24	13				-			116,164	0.0	0	0.0	0	0				268	0	2,904	-	-	-	-	-	1.22	108		89 -
Non-Cond Htg Sys Repl Electric Htg Sys Repl	9	0	6 0	1	2			- 4			20,535 8,550	0.0 0.0	0	0.0 0.4	0 611	0 611	6	533 0		121 0	0	2,282 2,138	0.000	- 0	0.104	- 153	153	1.01	89	105	60 -
Heat Pump Repl	0	0	0	0				0			6,550	0.0	0	0.4	011	011	0			0	0	2,136	-	- 0	0.104	155	153			1	
Other Htg Sys Repl	ő	ő	Ö	0				ď			ő	0.0	0	0.0	ő	0	0	0	0	0	o	ő	-	-	-	-	-	-		-	
					Fuel				sures Installed b	Fuel		Summer		Winter		Annual	Pk-Day		Propane			:	Summer		Winter			Pk-Day	Annual		Fuel Oil Other
Water Heating	Total 74	Electric 40	Gas 23	Propane 11					Gas Prop	ane Oil Othe	o 71,891	kW		kW		kWh 3,467	therms	therms 623		gallons 0	Mbtu 0	971	kW 0.000		kW 0.001			therms 0.156	therms 27		gallons Mbtu
Temp. Reduct.	0	0	0	0	0		0	0		0 0	0 0	0.0		0.0		0,407	0.0		0	0	0	0	-		-		-	-	- 21	-	
WH Wrap	0	0	0	0							0 0	0.0		0.0		0	0.0	0		0	0	0	-		-		-	-		-	
Pipe Insul.	73	40	23	10						10 0	0 630	0.0		0.0		1,829	0.2			0	0	9	0.000		0.000		46		3	3	
LF Showerhead Faucet Aerator	1	0	1	0				1		0 0	0 6	0.0		0.0		0 33	0.0	7		0	0	6	0.000		0.001		- 33	0.02	7	1	
Std-Eff Wtr Htr Repl.	0	0	0	0	-					0 0	0 0	0.0		0.0		33 0	0.0		-	0	0	0	0.000		0.001		- 33			1	1 1
Hi-Eff or Electric Wtr Htr Repl.	38	12	17	9	ő	-	38	12		9 0	0 71,250	0.0		0.0		1,605	3.4		360	ő	0	1,875	0.000		0.003		134	0.20	32	40	
Lighting	39	39					408	408			2,361	1.8		3.3		16,912		-	-		-	61	0.046		0.084		434		-	-	
Refrigerator/Freezer ³	8	8					9				6,777	0.6		0.6		4,798	-	-	-	-	-	847	0.074		0.069		600	-		-	
Refrigerator Removal	0	0 6					0	C			5 700	0.0		0.0 0.4		2 700	-	-	-	-	-	0	- 0.076		- 0.074		- 618	-		- 1	1 1
Refrigerator Exchange Freezer Removal	0	0					0	,			5,789	0.5		0.4		3,708						965	0.076		0.071		010	-			
Freezer Exchange	2	2					2	2			988	0.1		0.1		1,090	-	-	-		-	494	0.067		0.063		545	-	-	-	
Total Non-Efficiency Measures	75										420,495											5,607									
Misc Ins.Attic Access/Ven	63										11,935											189									
Duct Sealing	11										1,392											127									
Duct Insulation	33										1,854											56									
Damming Material Htg. Sys. Tune & Clean	46 20										3,631 5,913											79 296									
Htg. Sys./WH Other	16										9,446											590									
Air Conditioning Work	0										0											0									
Water Heater Repair	3										275											92									
Refrigerator Coil Clean	0										0											0									
Waterbed Mattress Pad Programmable Tstat	0										0											0									
Unspecified Utility Meas	0										0											0									
CO Detector	70										3,560											51									
Smoke Detector	46 0										830	1										18 0									
Fuses Htg Sys Safety Check	0										0											0									
Htg Sys Salety Check	33										8,178	1										248									
Water Heater Ventilation	26										4,199											161									
Bathroom Ventilation	40										6,814	1										170									
Dryer Ventilation Kitchen Ventilation	60 0										5,464											91 0									
Other Exhaust Ventilation	62										3,390	1										55									
Asbestos Removal (Minor)	0										0,550											0									
Health/Safety Repairs	53										44,262	1										835									
Health/Safety Other	7										480											69									
Consumables General Repairs	0 70										77,239											0 1,103									
Meter Refrig (no action)	69										0											1,103									
Meter Freezer (no action)	26										0	1										ő									
Support	74										221,752											2,997									
Transportation Allowance	0										0											0									
Landlord Contr Misc Landlord Contr Furnace	0										0											0									
Landlord Contr Furnace Landlord Contr DHW	0										0	1										0									
Client Contr (Any	ő										0											ō									
Lead Safe Work	57										9,880											173									
Unspecifed/Other	0										0											0									

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

³ The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Total Reported Labor, Materials and Utility Admin Expenditures: \$928,263

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$928,263

																												Iotai	i Labor ar	nu mate	епат Ехр	enaitures:	фэ	928,263			
														1				Billing A	Adjusted	First-Year \$	Savings					Averag						and Savir	ngs				
	N	umber	of Dwe	ellings	with Im	npacts	s	Nun	ber of I	Dwellin	ıgs wit	h kWh	Impacts														per Dw	velling	Receivi	•	asures						
						Fuel		Se	ason					Spendir Materi	ng on	Sumi	mer I	Electricity W	/ /inter	Annual	Pk-Day	Gas / Annual	Propan	e Fuel O	l Other	Spending on Materials	Sumr	mer	Electricit	ty nter	Annus	al Pk-Day	Gas Ann	nual F	ronane	Fuel Oil	Other
Measure	Total	Elec	ric G	as Pr	ropane		Other	Cooling		g				& Labo	r (\$)	kW	kWh	kW	kWh	kWh		therms		gallons			kW	kWh	kW	kWh	kWh	therms				gallons	
Tatal Efficience Managemen	81		81	73	5	0	0	80	8	4					4.67	17.0		14.6		64,089	138	44.000	6 1,85) 0	0.044	0.242		0.181		70.	1 1.90		195	371	-	
Total Efficiency Measures			01	73		U	U	80	0	1					1,157	17.0		14.0				3 14,206	1,05	\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \	, ,		0.213		0.161		79	1.90		195	3/1	-	-
Total Shell & Htg. Sys. Repl Total Shell Measures	8′		81	73 73	5	0		77	8						5,485	13.5 13.5	14,945	9.1		29,846			1,82				0.176	194		186		1.76		171	365	-	-
Wall Insul.	8°		81 44	45	5	0	0	44		0					1,968 3,986	13.5 5.3	14,945 6.408	9.1 0.9	14,901	29,846 7,796						1,843	0.176 0.121	194 146		186 1,388				99 74	163 83	- :	-
Open Blown Ceiling Insul	66	3	59	60	4	0	0	59		2				44	1,822	4.8	5,846	4.2	6,871	12,717	۶ ا	804	4 17) (679	0.082	99	2.106	3,436	6 21	0.14		13	43	-	-
Cavity Fill Insul Sloped Attic Insul	2'	!	16 16	19 19	2	0	0			0				16	5,956 5,980	1.0 1.1	1,203 1,316	0.0	0	1,203 1,316	10	940 950		1 (807 761	0.062	75 82	0.000	0				49 50	25 47	-	-
Kneewall Insul	10		8	8	2	0	0			0					1.447	0.1	1,316	0.0	0	126						445	0.068	16		0				15	7		
Infil. Reduction	79	9	70	71	5	0	0	70		3					3,284	1.0	1,221	0.6	1,029	2,250) 8		9 4	1 (0	358	0.014	17	0.210		3 3	0.12		11	9	-	-
Found./Crawl. Insul Bandjoist Insul.	34 47	1	7	31 41	2	0	0	7		1				21	1,323 3,825	0.4	444 0	0.1 0.1	161 196	605 196						627 294	0.053	63 0		161 98				11	12 5	-	-
Furnace Blower Fan ¹	78		70	73	5	0	-			0				10	0,025	0.0	0	4.9	8,022					1) (294	0.000	0						(0)	(1)		
Exhaust Ventilation ²	67		67	61	3	0	0			7				82	2.344	-0.2	(1.618)									1.229	-0.003		(0.025)					(5)	(6)		
Total Heating System Repl	51		0	47	4	0	0	-		0				133	3,517	0.0	0	0.0	0	` C					, ,		-	- '	- 1	-	-	1.15		112	253	-	-
Condensing Htg Sys Rep Non-Cond Htg Sys Repl	51		0	47 2	4	0	0	-	-						7,517 5,000	0.0	0	0.0	0	C						2,500 1,500	-	-	-		-	1.09 1.49		106 145	155 197	- :	-
Electric Htg Sys Repl			0	0	0	ō				0				`	0	0.0	0	0.0	0	Č						0	-	-	-		-	-		-	-	-	-
Heat Pump Repl	(0	0	0	0	0			0					0	0.0	0	0.0	0	C) () (0) (0	-	-	-	-	-	-		-	-	-	-
Other Htg Sys Repl	()	0	0	U	0	0	-		U					U	0.0	0	0.0	0		, ,) (J) () 0	U						-		-			
						Fuel		Numb	er of Mea	asures I	nstalled												_				_		Winter		_						
	Total	Elec	ric G	as P			Other	r Total	Electri	ic Ga	s Pro		Fuel Oil Oth	er	5	kW		Winter kW		Annual kWh	Pk-Day therms			Fuel Oil gallons			Summer kW		kW		kWh	Pk-Day therms				Fuel Oil gallons	
Water Heating	81		26	54	1	0				8 1	05	2	0	0 80),581	0.0		0.0		2,665	9.9	9 1,700				995	0.000		0.001		10:	3 0.183		31	30	-	-
Temp. Reduct. WH Wrap			4 0	1	0	0	0	5		4 0	1	0	0	0	0	0.0		0.0		461	0.0		7) (0 0	0	0.000		0.000		11:	0.02		7	-	-	-
Pipe Insul.	8		26	54	1	0	0	81			54	1	0	0 1	1,640	0.0		0.0		1,145						20	0.000		0.000		- 4	4 0.01		3	3	-	-
LF Showerhead	(0	0	0	0	0	0		0	0	0	0	0	0	0.0		0.0		C	0.0					0	-		-		-	-		-	-	-	-
Faucet Aerator Std-Fff Wtr Htr Repl	(0	0	0	0	0	0		0	0	0	0	0	0	0.0		0.0		0	0.0) (0			-		-	-		-			
Hi-Eff or Electric Wtr Htr Repl.	59	9	8	50	1	0	0	59		8	50	1	0	0 78	3,941	0.0		0.0		1,059	9.4					1,338	0.000		0.003		13:	2 0.19		31	27	-	-
Lighting	72		72					657							1,599	2.4		4.5		23,231			-			64	0.034		0.063		32			-	-	-	-
Refrigerator/Freezer³ Refrigerator Removal	16		16					16	1	6				13	3,493	1.0		1.0 0.0		8,346	-		-	-	-	843	0.064		0.060		52	2 -		-	-	-	-
Refrigerator Exchange	15		15					15	1	5				13	3,058	1.0		0.0		7,801	' I		1 1	-		871	0.064		0.060		52	0 -					-
Freezer Removal	()	0					0		0					0	0.0		0.0		C	-	-	-	-	-	0			0.063		-	-		-	-	-	-
Freezer Exchange			1					1		1					435	0.1		0.1		545	-		-			435	0.067		0.063		54	-		-			
Total Non-Efficiency Measures	8′														1,106											4,619											
Misc Ins,Attic Access/Ven	73													,	5,163 30											84 30											
Duct Insulation	29	9												1	1,851											64											
Damming Material	46														1,632											35 247											
Htg. Sys. Tune & Clear Htg. Sys./WH Other	74 22														3,249 7,551											343											
Air Conditioning Work	()													0											0											
Water Heater Repair Refrigerator Coil Clean	15														789 0											53 0											
Waterbed Mattress Pad															0											0											
Programmable Tstat															0											0											
Unspecified Utility Meas CO Detector	81														0 3,888											0 110											
Smoke Detector	79	9												5	5,192											66											
Fuses	(0 85											0 85											
Htg Sys Safety Check Htg Sys Ventilation	4													6	85 5,133											150											
Water Heater Ventilation	51	ı												7	7,745											152											
Bathroom Ventilation Dryer Ventilation	31 40														3,954 1,407											128 110											
Kitchen Ventilation	4(0											0											
Other Exhaust Ventilation	48													2	2,143											45											
Asbestos Removal (Minor) Health/Safety Repairs	37													-	0 7,867											0 213											
Health/Safety Other	,													<i>'</i>	30											30											
Consumables	(0											0											
General Repairs Meter Refrig (no action)	59 64													20	0,939											355 0											
Meter Freezer (no action)	20)													0											0											
Support	79							-						255	5,321											3,232											
Transportation Allowance Landlord Contr Misc	(0											0											
Landlord Contr Furnace	ì														0											0											
Landlord Contr DHW	(0											0											
Client Contr (Any) Lead Safe Work	62													15	5,137											244											
Unspecifed/Other	(0											0											

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

² Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

³ The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed

Total Reported Labor, Materials and Utility Admin Expenditures: \$665,352

Utility Administration Expenditures:

\$665,352 Total Labor and Material Expenditures:

																							101	tai Labor	anu wa	ateriai Ex	penunure	5. φ	\$665,352		
														Billing A	djusted F	irst-Year S	avings				Ave	rage Billir						vings			
	Number o	f Dwellings	s with Im	pacts	N	lumber	of Dwell	ings wi	th kWh	Impacts													wellin	g Receiv	•	/leasure	3				
				Fuel		Season					Spending on Materials	Sum	mor E	Electricity	inter	Annual	Pk-Day	Gas Annual	Propaga	Fuel Oil O	Spending her Materials	on Sur	nmer	Electri	city Vinter	Ann	ual Pk-Da	Gas	nnual F	Propage	uel Oil Other
Measure	Total Electri	ic Gas F			ther Coc	oling Hea	ating				& Labor (\$)	kW	kWh	kW	kWh	kWh	therms	therms		gallons N			kWh		kV	Vh kW	h thern	ns the			allons Mbtu
Total Efficience Managemen	46	10 20		^	0	46	40				202.040	44.0		40.4		20.040	07	0.002	4.024	•	0 7.8	0.200	,	0.00	•		C4 2.2	12	200	250	
Total Efficiency Measures	46 4	16 39	4	0	U	46	46				362,610	14.2		12.1		39,619	87	8,093	1,034	0	0 7,8	0.308	3	0.26	3	8	61 2.2	:3	208	259	
Total Shell & Htg. Sys. Repl		16 39	4	0	0	46	46				300,273	13.5	15,380	10.9	15,702	31,082	81	6,937	961	0	0 6,	0.293					76 2.0		178	240	
Total Shell Measures Wall Insul.		16 39 27 24	3	0	0	46 27	46				161,034 50,870	13.5 5.1	15,380 6,179	10.7 2.8	15,490 4,089	30,870 10,268	32 15	2,758 1,294				0.293 96 0.190					71 0.8 80 0.6		71 54	104 70	
Open Blown Ceiling Insul		38 34	4	0	0	38	3				32,934	5.2	6,262	5.0	7,176	13,438	7	562			0	0.137	7 16	5 1.65		392 3	54 0.1		17	17	
Cavity Fill Insul Sloped Attic Insul	1 13 1	1 1 13 10	0	0	0	1 13	0				1,835 4,733	0.1 1.5	180 1,767	0.0 1.2	0 1,786	180 3,553	1 3	58 245		0	0 1,8	0.150 0.113		0.00 6 1.23	0	0 1 786 2	80 0.6 73 0.2		58 24	32	
Kneewall Insul		7 6	1	0	0	7	0				2,319	0.3	365	0.0	1,766	365	1	245 54		0		31 0.043					73 0.2 52 0.1		9	1	1 1
Infil. Reduction		13 39	4	0	0	43	3				27,399	1.0	1,202	0.4	523	1,725	6	491			0 5	96 0.023	3 2	8 0.12		174	40 0.1		13	19	
Found./Crawl. Insul Bandjoist Insul.		7 14 3 10	2	0	0	5	2				8,063 2,035	0.4	476 0	0.1 0.3	153 385	629 385	2	168 75	8 9	0		48 0.079 20 0.000		0.05 0 0.08			90 0.1 28 0.0		12 8	4 2	
Furnace Blower Fan ¹		11 39	4	0	0	-	41				2,000	0.0	0	2.5	3,581	3,581	(0)			-	0	0 0.000		0 0.06			87 (0.0		(0)	(0)	
Exhaust Ventilation ²		12 35	4	0	0	42	42				30,846	-0.1	(1,052)		(2,201)	(3,253)	(2)				0	34 -0.003		(0.03			77) (0.0		(5)	(6)	
Total Heating System Repl	01	1 29	4	0	0	-	1				139,239	0.0	0	0.1	212	212	48 48			0		0.000)	0 0.14	7 2	212 2	12 1.6		144	137	
Condensing Htg Sys Rep Non-Cond Htg Sys Repl		0 29	0	0	0		-				130,037	0.0	0	0.0	0	0	48	4,179 0	546	0	0 3,9	0 -	- 1		-		1.6	07	144	137	1 1
Electric Htg Sys Repl	1	1 0	0	0	0	-	1				9,202	0.0	0	0.1	212	212		0	1	0		0.000		0 0.14			12 -		-	-	
Heat Pump Repl Other Htg Sys Repl		0 0	0	0	0	-	0				0	0.0	0	0.0	0	0	0	0		0	0	0 -		-	-		-		-	-	
Outer Hig dys Nepi	U	0 0	U	U	U						0	0.0	U	0.0		U	-	U	"	U		-		-		•	-		-		
				Fuel	Nι	ımber of	Measures	Installed		l Typ€ Fuel		Summer		Winter		Annual	Pk-Day	Annual	Propaga	Fuel Oil Ot	nor	Summe		Winte		Ann	ual Pk-Da	w An	nnual F	Propage I	uel Oil Other
	Total Electri					otal Ele	ectric (Gas Pro		Oil Oth	er	kW		kW		kWh	therms	therms	gallons		btu	kW		kW		kW	h thern	ns the	erms g		allons Mbtu
Water Heating Temp. Reduct.	44	9 32	3	0	0	141	28	107	6	-	0 58,693	0.0		0.0		2,215	6.3 0.0	1,156	73	0	0 1,3	0.000)	0.00	5		46 0.19	98	36	24	
WH Wrap	0	0 0	0	0	0	0	0	0	0	-	0 0	0.0		0.0		0	0.0	0	0	0	0	0 -				-	1		- 1	- 1	1 1
Pipe Insul		9 32	1	0	0	42	9	32	1	-	0 830	0.0		0.0		417	0.3	93		0		20 0.000		0.00			46 0.		3	3	
LF Showerhead Faucet Aerator	20 32	3 16 7 23	1 2	0	0	20 45	3 10	16 33	1 2	0	0 200 0 225	0.0		0.0		611 353	0.4 0.1	110 45		0	0	10 0.000 7 0.000		0.00			04 0. 50 0.		7 2	8	1 1
Std-Eff Wtr Htr Repl.	0	0 0	0	Ö	0	0	0	0	0		0 0	0.0		0.0		0	0.0	0	0	0	o o	0 -		-		-	-		-	- '	
Hi-Eff or Electric Wtr Htr Repl. Lighting	34 39 3	6 26 39	2	0	0	34 376	6 376	26	2	0	0 57,438 2,724	0.0		0.0		5,809	5.6	908	60	- 0		70 0.016		0.00	3		39 0.: 49 -	21	35	30	
Refrigerator/Freezer ³	39 3	1				1	1				920	0.6		0.1		5,609			-			20 0.063		0.02			12 -				
Refrigerator Removal	0	0				0	0				0	0.0		0.0		0	-	-	-	-	-	0 -		-		-	-		-	-	
Refrigerator Exchange Freezer Removal	1 0	1				1 0	1 0				920 0	0.1 0.0		0.1 0.0		512 0	-	-	-	-	- !	0.063	3	0.05	9		12 -		1	-	
Freezer Exchange		0				0	0				0	0.0		0.0		0	- 1				1	0 -									1 1
Total Non-Efficiency Measures	46										302.742											81									
Misc Ins,Attic Access/Ven	43										10,848											252									
Duct Sealing	11										1,080											98									
Duct Insulation Damming Material	40 32										4,463 1.475											12 46									
Htg. Sys. Tune & Clean	11										3,295										;	800									
Htg. Sys./WH Other Air Conditioning Work	9										2,283										1	254 0									
Water Heater Repair	3										230											77									
Refrigerator Coil Clean	0										0											0									
Waterbed Mattress Pad Programmable Tstat	0										0											0									
Unspecified Utility Meas	0										0											0									
CO Detector Smoke Detector	31 17										648 1,095											21 64									
Fuses	0										0											0									
Htg Sys Safety Check	0										0											0									
Htg Sys Ventilation Water Heater Ventilation	33 26										8,900 5,039											270 194									
Bathroom Ventilation	43										3,924											91									
Dryer Ventilation Kitchen Ventilation	19 0										829											44									
Other Exhaust Ventilation	42										1,942											46									
Asbestos Removal (Minor) Health/Safety Repairs	0										10.005											0 '34									
Health/Safety Repairs Health/Safety Other	26 8										19,095 361											45									
Consumables	0										0											0									
General Repairs Meter Refrig (no action)	46 43										34,836 0											757 0									
Meter Freezer (no action)	16										0											Ö									
Support	46										188,041										4,0	88									
Transportation Allowance Landlord Contr Misc	0										0											0									
Landlord Contr Furnace	0										ő											0									
Landlord Contr DHW Client Contr (Any)	0										0											0									
Lead Safe Work	31										14,359										-	163									
Unspecifed/Other	0										0											0									

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

³ The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Total Reported Labor, Materials and Utility Admin Expenditures: \$5

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$577,108

	Numbe	er of Dwe	llinge v	with Imn	vacte	1.	Numbo	r of Dw	ollinge	with k\	Vh Impa	cte				Billing	Adju:	sted Fir	st-Year S	avings					Avera	ge Billing ner Dv		sted Firs			nd Savin	gs			
	Italiibo	0. 5	gs ·			'			ciiiigs		··· iiiipu	ClS	Spending on			Electric					Gas				Spending on	1	·	Electrici	ty			Gas	1		
Measure	Total Ele	ectric G	as Pro	pane	Fuel Oil Ot	ther Co	Seasor oling H	n leating					Materials & Labor (\$)	Su kW	mmer kWh	kW	Winter k\	Wh	Annual kWh	Pk-Day therms	Annual therms			I Oil Othe ons Mbt		Sum: kW	mer kWh	Wii kW	nter kWh	Annual kWh	Pk-Day therms	Annual therms		ane Fuel (
T													040.044	40.4		40	_		05.750	=0						0.040		0.400			0.40				
Total Efficiency Measures	40	40	24	6	0	0	40	40					313,944	12.4		19.			65,759	58			573		7,849			0.488			2.42			262 -	-
Total Shell & Htg. Sys. Repl Total Shell Measures	40 39	40 39	24	6	0	0	39	40 39					271,826 165,581	9.1	10,26 10,26			2,633	32,901 31,951	56 33	5,13° 3,00		488 816	0		0.234					2.34			248 - 136 -	
Wall Insul.	20	20	12	4	0	0	20	4					22,845	3.1	3,77	1 1.	2 1	1,765	5,537	9	820	0 :	223	0	1,142	0.156	189	0.289	441	277	0.75	(88	56 -	-
Open Blown Ceiling Insul Cavity Fill Insul	32 6	32 5	18 6	6	0	0	32 5	8					37,396 6,191	3.8 0.3	4,61 37	7 7.4 '8 0.1		1,330	15,947 378	8	69i 39i		194 0	0	0 1,169 0 1,032	0.120 0.063		0.926	1,416 0	498		3	38 37	32 -	-
Sloped Attic Insul	8	8	6	1	0	0	8	1					5,233	0.5	65			154	810	3	26		97	0	0 654				154		0.73		14	97 -	
Kneewall Insul	6	6	4	1	0	0	6	1					4,953	0.3	32			378	705	1	133		16	0	826				378		0.36		33	16 -	-
Infil. Reduction Found./Crawl. Insul	39 17	39 8	24 8	3	0	0	39 6	9 6					21,242 19.268	0.7	86 53			4,084 1.888	4,953 2,419	5 2	420 172		158 62	0	0 545 0 1.133	0.018	22 89		454 315				17	26 -	-
Bandjoist Insul.	28	6	17	5	0	ō	-	6					11,302	0.0		0 1.		1,693	1,693	2			103	0	404								13	21 -	-
Furnace Blower Fan	30	30	24	6	0	0	-	30					0	0.0		0 2.3		3,571	3,571	(0)			(3)	0	0	0.000			119		(0.01)		(0)	(0) -	-
Exhaust Ventilation Total Heating System Repl	30 25	30	18	- 6	0	0	30	30					37,150 106,245	-0.1 0.0	(88)	0 0.0		(3,180) 950	(4,062) 950	(1)			(33)	0	0 1,238 0 4,250	-0.004 0.000	(29)	0.124			(0.06)		(5)	(6) -	<u> </u>
Condensing Htg Sys Rep	19	0	14	5	0	0	-	-					69,595	0.0		0 0.0		0	0	22			671	0	3,663		-	-	-	-	1.60			134 -	-
Non-Cond Htg Sys Repl	1	0	1	0	0	0	-	- 4					3,000 2,650	0.0		0 0.0		0 157	0 157	1	70		0	0		0.000	- 0	0.103	- 157	- 157	0.84		76		-
Electric Htg Sys Repl Heat Pump Repl	5	5	0	0	0	0	-	5					31,000	0.0		0 0.		793	793	0		0	0	0								- :		: :	
Other Htg Sys Repl	0	0	0	0	0	0	-	0					0	0.0		0 0.0		0	0	0	- (0	0	0	0	-	-	-	-	-	-	-			-
						N	umber o	of Measu	ıres Insta	lled by I	uel Type																								
	Total Ele	ectric G	ias Pro		Fuel Oil O				Gas		Fuel	Other		Summer kW		Winte kW	r		Annual kWh	Pk-Day therms	Annual therms			Oil Other		Summer kW		Winter kW			Pk-Day therms	Annual therms		ane Fuel (ns gallo	
Water Heating	39	18	19	2	0	0	90	39	46	5	0	0	26,003	0.0		0.			3,958	1.9		7	85	0	667	0.000		0.004			0.097		20	42 -	-
Temp. Reduct. WH Wrap	0	0	0	0	0	0	0	0	0	0		0	0	0.0		0.0			0	0.0			0	0	0 0	-		-		-	-			: :	
Pipe Insul.	39	18	19	2	0	0	39	18	19	2	. 0	0	760	0.0		0.0)		876	0.2	56	6	6	0	19	0.000		0.000		49			3	3 -	-
LF Showerhead Faucet Aerator	25	11 0	13	1	0	0	35 1	15 0	19 1	1	0	0	343 5	0.0		0.0			2,184	0.3	94	4	8	0	14	0.000		0.005		199	0.02		7	8 -	-
Std-Eff Wtr Htr Repl.	0	0	Ó	0	0	0	ó	0	ó	C			0	0.0		0.0			0	0.0			0	0		-					- 0.00		'		-
Hi-Eff or Electric Wtr Htr Repl.	15 37	6 37	7	2	0	0	15	6	7	2	0	0	24,895 3,784	0.0		3.3			898 16,797	1.4	22	5	71	0	0 1,660 102			0.004		150 454			32	36 -	-
Lighting Refrigerator/Freezer ³	18	18					516 22	516 22					12.331	1.8		1.4			12,104	-								0.088		454 672					-
Refrigerator Removal	1	1					2	2					20	0.1		0.	1		1,023	-	-				20	0.126		0.118		1,023	-	-			-
Refrigerator Exchange Freezer Removal	13 0	13 0					14 0	14 0					9,902	0.9		0.9			7,542 0	-	-		-			0.071		0.067		580	-	-			-
Freezer Exchange	6	6					6	6					2,409	0.4		0.4			3,538	-	- 1		-		402	0.073		0.068		- 590	-	- :		: :	
Total Non-Efficiency Measures	40												263,164												6,579										
Misc Ins,Attic Access/Ven	32												15,544 1,665												486										
Duct Sealing Duct Insulation	6												1,665												278										
Damming Material	8												238												30										
Htg. Sys. Tune & Clean Htg. Sys./WH Other	7 15												1,580 7,784												226 519										
Air Conditioning Work	0												0												0										
Water Heater Repair	13 0												1,350												104										
Refrigerator Coil Clean Waterbed Mattress Pad	0												0												0										
Programmable Tstat	1												100												100										
Unspecified Utility Meas CO Detector	0 40												3,906												98	-									
Smoke Detector	36												4,156												115										
Fuses Htg Sys Safety Check	0												0												0										
Htg Sys Ventilation	14												3,225												230										
Water Heater Ventilation	7												1,355												194										
Bathroom Ventilation Dryer Ventilation	16 33												4,505 7,450												282 226										
Kitchen Ventilation	0												7,430												220										
Other Exhaust Ventilation	6												390												65										
Asbestos Removal (Minor) Health/Safety Repairs	0 29												0 14,042												0 484										
Health/Safety Other	5												330												66										
Consumables	1 40												35 38,788												35 970										
General Repairs Meter Refrig (no action)	40 25												38,788												970	1									
Meter Freezer (no action)	11												0												0	1									
Support Transportation Allowance	40 0												156,721												3,918										
Landlord Contr Misc	0												0												0										
Landlord Contr Furnace	0												0												0	1									
Landlord Contr DHW Client Contr (Any)	0												0												0										
Lead Safe Work	0												0												0	1									
Unspecifed/Other	Ι Λ												0												1 0	1									

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

The total number of dwellings ma Dalhoff Associates, LLC

Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

impacts from communities from continuous constant ratio required by ASHINGLE CL. I not written impacts exceed summer occasion required specific required by ASHINGLE CL. I not written impacts exceed summer occasion replaces for occurrence and the product of the

Total Reported Labor, Materials and Utility Admin Expenditures: \$2,139,672

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$2,139,672

												1 1			Billing A	djusted F	irst-Year S	avings				Avera	ge Billing		d First			nd Saving	ys, 103,07			
	Numl	er of Dv	vellings	with Im	pacts		Numbe	r of Dw	ellings v	ith kWl	Impacts	Spending on			Electricity			1	Gas			Spending on	per Dw	elling Re	eceivin lectricit	•	sures		as	ı		
Measure	Total E	lectric	Gas Pi		Fuel Oil O	ther Co	Season ooling H					Materials & Labor (\$)	Sun kW	nmer kWh	Win	nter kWh	Annual kWh				Fuel Oil Other	r Materials	Sumn kW	ner	Win	ter		Pk-Day therms	Annual therms		Fuel Oil Othe gallons Mbt	
Total Efficiency Measures	149	149	138	3	0	0	149	149				1,141,056	37.0		35.0		119,104	373	35,639	861	0	7,658	0.248		0.235		799	2.71	258	287		
Total Shell & Htg. Sys. Repl	149	149	138	3	0	0	148	149				919,624	33.0	36,721	29.6	44,498	81,219	347	30,792	779	0	0 6,172	0.223	248	0.199	299	545	2.51	223	260		
Total Shell Measures	149	149	138	3	0	0	148	149				713,782	33.0	36,721	29.5	44,394	81,116	244	21,686	495	0	0 4,790	0.223	248	0.198	298	544	1.77	157	165		
Wall Insul.	101	84	96	3	0	0	84	2				201,499	13.2	15,959	1.7	2,591	18,550	70	6,206	84	0	1,995			0.840	1,296	221	0.73	65			
Open Blown Ceiling Insul Cavity Fill Insul	128 87	111 71	118 81	3	0	0	111 71	1				122,109 55,665	12.4 2.8	14,918 3,378	10.9 1.8	16,399 2,807	31,317 6,184	94 25	8,388 2,218	235 128	0	954 0 640	0.111 0.039		1.552 0.451	2,343 702	282 87		71 27			
Sloped Attic Insul	30	26	29	0	ő	0	26	1				12,545	1.0	1,210	0.4	694	1,904	8	742	0	ő			47	0.444	694	73		26	-		
Kneewall Insul	50	42	47	0	0	0	42	3				14,842	0.9	1,025	1.1	1,560	2,585	7	598		0	297			0.352	520	62	0.14	13			
Infil. Reduction Found./Crawl. Insul	149 67	126 12	138 64	3	0	0	126	8				134,855 69,798	2.3 0.8	2,824 983	1.2	1,790 1,273	4,614 2,256	29 19	2,567 1,707	26 41	0	905 0 1,042	0.019 0.068		0.149 0.815	224 1,273	37 188		19 27			
Bandioist Insul	14	1	13	0	0	0	12	1				2,836	0.0	903	0.8	250	2,250	19	99		0		0.000		0.615	250	250	0.30	8			
Furnace Blower Fan ¹	141	141	138	3	0	0	-	141				0	0.0	0	15.9	23,670	23,670	(1)	(100)	(2)	0	0	0.000	0	0.113	168	168		(1			
Exhaust Ventilation ²	146	146	135	3	0	0	146	146				99,633	-0.4	(3,576)		(6,639)	(10,215)	(8)	(738)	(17)	0	682	-0.003	(24)	(0.030)	(45)	(70)	(0.06)	(5) (6		
Total Heating System Repl	92	1	88	3	0	0	-	1				205,842	0.0	0	0.1	104	104	102	9,105		0	2,237	0.000	0	0.066	104	104		103			
Condensing Htg Sys Rep Non-Cond Htg Sys Repl	80 11	0	77 11	3 0	0	0	-	-				178,460 24,775	0.0 0.0	0	0.0	0	0	90 12	7,992 1,113	284 0	0	0 2,231 0 2,252	-	-	-	-	-	1.17 1.13	104 101			
Electric Htg Sys Repl	1	1	0	0	0	0		1				2,607	0.0	0		104	104	0	1,113		0		0.000	- 0	0.066	104	104	-	-			
Heat Pump Repl	0	0	0	0	0	0	-	0				0	0.0	0		0	0	0	0	0	0	0	-	-	-	-	-	-	-	-		
Other Htg Sys Repl	0	0	0	0	0	0	-	0				0	0.0	0	0.0	0	0	0	0	0	0	0	-	-	-	-	-	-	-	-		
						N	lumber o	of Measu	es Install	ed by Fu	el Type																					
	Total E	lectric	Gas P		Fuel Oil C	Other T	otal E	lectric	Gas F	ropane	Fuel Oil Oth		Summer kW		Winter kW		Annual kWh	Pk-Day therms	Annual therms		Fuel Oil Other gallons Mbt		Summer kW		Winter kW			Pk-Day therms	Annual therms		Fuel Oil Other	
Water Heating	148	14	132	2	0	0	515	43	465	. 7	0	0 194,794	0.0		0.0		2,741		4,847	82	0	1,316	0.000		0.003		196	0.204	37			
Temp. Reduct. WH Wrap	0	0	0	0	0	0	0	0	0	0		0 0	0.0 0.0		0.0		0	0.0	0		0	0	-		-		-	-	-	-		
Pipe Insul.	147	14	131	2	0	0	147	14	131	2	0	0 2,483	0.0		0.0		673	1.2	401		0	17	0.000		0.000		48	0.01	- 3	- 3	- : :	
LF Showerhead	38	3	34	1	ō	0	43	4	38	1	0	0 410	0.0		0.0		568	0.8	260	8	ō	11	0.000		0.003		189	0.02	8			
Faucet Aerator	115	11	102	2	0		211	20	189	2	0	0 1,010	0.0		0.0		730	0.9	278		0	9	0.000		0.002		66	0.01	3	1		
Std-Eff Wtr Htr Repl. Hi-Eff or Electric Wtr Htr Repl.	0 114	0	0 107	0	0	0	0 114	0 5	0 107	0	0	0 0 190,892	0.0		0.0		769	0.0 24.0	0 3,909		0	0 1,674	0.000		0.004		- 154	0.22	- 37	- 33	1 1	
Lighting	104	104	101		-		1,043	1,043	107		- 0	7,231	1.7		3.2		16,471		-	-					0.031		158		-	-		
Refrigerator/Freezer ³	32	32					36	36				19,407	2.3		2.1		18,673	-	-	-					0.067		584			-		
Refrigerator Removal	0	0					0	0				0	0.0		0.0		0	-	-	-		0						-	-	-		_
Refrigerator Exchange Freezer Removal	32 0	32 0					36 0	36 0				19,407 0	2.3 0.0		2.1 0.0		18,673 0	-	-	-		606	0.072		0.067		584	-	-	-		
Freezer Exchange	0	0					0	0				0	0.0		0.0		0					0	-		-					-		
Total Non-Efficiency Measures	149											998,616										6,702										_
Misc Ins,Attic Access/Ven	149											45,052										322										_
Duct Sealing	50											11,768										235										
Duct Insulation	123											9,309										76										
Damming Material Htg. Sys. Tune & Clean	107 45											15,600 18,410										146 409										
Htg. Sys./WH Other	17											5,489										323										
Air Conditioning Work	0											0										0										
Water Heater Repair Refrigerator Coil Clean	3											420 0										140										
Waterbed Mattress Pad	0											0										0										
Programmable Tstat	0											0										0										
Unspecified Utility Meas	0											0										0										
CO Detector Smoke Detector	144 94											10,185 3,800										71 40										
Fuses	0											0,000										0										
Htg Sys Safety Check	0											0											1									
Htg Sys Ventilation Water Heater Ventilation	94 103											18,216 18,925										194 184										
Bathroom Ventilation	147											28,044										191										
Dryer Ventilation	136											18,195										134	1									
Kitchen Ventilation Other Exhaust Ventilation	0											0 40										0 40										
Asbestos Removal (Minor)	0											0										0										
Health/Safety Repairs	128											58,103										454										
Health/Safety Other	49											4,008										82	1									
Consumables General Repairs	0 142											0 130,384										918										
Meter Refrig (no action)	117											0										0	i									
Meter Freezer (no action)	45											0										0	1									
Support Transportation Allowanes	147 0											582,709 0										3,964	1									
Transportation Allowance Landlord Contr Misc	0											0										0	1									
Landlord Contr Furnace	0											0										ő										
Landlord Contr DHW	0											0										0										
Client Contr (Any) Lead Safe Work	108											19,960										185	1									
Unspecifed/Other	108											19,960										185										
																																_

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

mpacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

³ The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Dalhoff Associates, LLC

This page intentionally left blank

5. DETAILED SPENDING AND IMPACT PROFILES BY AGENCY FOR UTILITY EXPENDITURES

This section provides tables of spending and impacts by agency for utility expenditures.

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$273,344

									Billing A	Adjusted F	irst-Year S	avings		Averaç						nd Savin	gs
		er of Dwe			of Dwellings							ı	_		per Dv		Receivir		ures		
	,	with Impac	ts	With Elec Seas	tricity Impacts	Spending on Materials	Sum		Electricity Wi	inter	Annual	Pk-Day	Gas Annual	Spending on Materials	Sumi		Electricit Win		Annual	Pk-Day	as Annual
Measure	Total	Electric	Gas	Cooling	Heating	& Labor (\$)	kW	kWh	kW	kWh	kWh	therms	therms	& Labor (\$)	kW	kWh	kW	kWh	kWh	therms	therms
Total Efficiency Measures	40	37	34	36	37	219,317	8.8		7.0		24,998	93	8,717	5,483	0.245		0.190		676	2.72	256
Total Shell & Htg. Sys. Repl	40	37	34	35	37	191,305	8.3	10,045	6.1	9,340	19,385	89	8,135	4,783	0.238	287	0.165	252	524	2.62	239
Total Shell Measures	40	37	34	35	37	106,202	8.3	10,045	6.1	9,259	19,304	52	4,709	2,655	0.238	287	0.164	250	522	1.52	139
Wall Insul.	21		18	19	1	21,119	2.8	3,373	1.1	1,708	5,080	11	1,025	1,006	0.147	178	1.117	1,708	267	0.62	57
Open Blown Ceiling Insul.	38		33	34	1	31,583	2.8	3,434	1.9	2,886 0	6,320	14 4	1,232	831	0.084	101	1.888	2,886 0	186 57	0.41 0.49	37 45
Cavity Fill Insul. Sloped Attic Insul.	10 24		8 20	10 20	0 2	6,174 10,614	0.5 1.3	575 1,509	0.0	1,273	575 2,782	10	356 923	617 442	0.048	57 75	0.000 0.416	636	132	0.49	45 46
Kneewall Insul.	15		13	13	0	5,692	0.3	413	0.0	0	413	3	250	379	0.026	32	0.000	0	32	0.21	19
Infil. Reduction	38	34	23	34	2	17,928	0.4	438	0.1	205	643	2	175	472	0.011	13	0.067	103	19	0.08	8
Found./Crawl. Insul.	17		16	4	1	8,953	0.3	304	0.2	381	685	2	207	527	0.063	76	0.249	381	137	0.14	13
Bandjoist Insul.	29		27	-	2	4,137	0.0	0	0.5	704	704	6	549	143	0.000	0	0.230	352	352	0.22	20
Furnace Blower Fan	38		34	-	35	0	0.0	0	1.4	2,102	2,102	(0)		0	0.000	0	0.039	60	60	(0.00)	(0)
Exhaust Ventilation Total Heating System Repl	32	0	31	0	0	85,104	0.0	0	0.0	0 82	0 82	38	3,426	2,659	0.000	- 0	0.053	- 82	- 82	1.21	111
Condensing Htg Sys Repl	31		31		- '	81,604	0.0	0	0.0	02	02	38	3,426	2,632	-	-	-	- 02	-	1.21	111
Non-Cond Htg Sys Repl	0		0	-	-	0	0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	-
Electric Htg Sys Repl	1	1	0	-	1	3,500	0.0	0	0.1	82	82	0	0	3,500	0.000	0	0.053	82	82	-	-
Heat Pump Repl Other Htg Sys Repl	0	0	0	-	0	0	0.0 0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	-
Other Hig Sys Repr	- 0	U	0	-	U	0	0.0	U	0.0	U	0	U	0	U		-		-	-	-	
					er of Measures Fuel Type		Summer		Winter		Annual	Pk-Day	Annual		Summer		Winter		Annual	Pk-Day	Annual
W. H. C	Total	Electric	Gas	Total	Electric Gas	07.400	kW		kW		kWh	therms	therms	700	kW		kW		kWh	therms	therms
Water Heating Temp. Reduct.	37 0	12	25 0	41 0	12 29	27,136 0	0.0		0.0		899	3.5	582	733	0.000		0.001		75	0.138	23
WH Wrap	0		0	0	0 0		0.0		0.0		0	0.0	0	ő	-		-		-	-	-
Pipe Insul.	17	8	9	17	8 9	153	0.0		0.0		353	0.1	26	9	0.000		0.000		44	0.01	3
LF Showerhead	0	0	0	0	0 0	0	0.0		0.0		0	0.0	0	0	-		-		-	-	
Faucet Aerator Std-Eff Wtr Htr Repl.	4 0	0	4	6 0	0 6	20 0	0.0 0.0		0.0		0	0.0	8	5	-		-		-	0.01	2
Hi-Eff or Electric Wtr Htr Repl.	20	4	16	18	4 14	26,962	0.0		0.0		546	3.4	548	1,348	0.000		0.003		136	0.21	34
Lighting	31	31		207	207	876	0.5		0.9		4,714	-	-	28	0.016		0.029		152		-
Refrigerator/Freezer ³	0			0	0	0	0.0		0.0		0	-	-	0	-		-		-	-	-
Refrigerator Removal	0			0	0	0	0.0		0.0		0	-	-	0	-		-		-	-	-
Refrigerator Exchange Freezer Removal	0	0		0	0	0	0.0		0.0		0	-	-	0	-				-	-	
Freezer Exchange	ő	0		Ö	Ö	ő	0.0		0.0		ő	-	-	ő	-		-		-	-	-
Total Non-Efficiency Measures	40					54,028								1,351							
Misc Ins,Attic Access/Vent	22					4,432								201							
Duct Sealing	0					0								0							
Duct Insulation Damming Material	1 0					102								102 0							
Htg. Sys. Tune & Clean	6					750								125							
Htg. Sys./WH Other	0					0								0							
Air Conditioning Work	0					0								0							
Water Heater Repair Refrigerator Coil Clean	0					0								0							
Waterbed Mattress Pad	0					0								0							
Programmable Tstat	0					0								ō							
Unspecified Utility Meas.	0					0								0							
CO Detector Smoke Detector	0					0								0							
Fuses	0					0								0							
Htg Sys Safety Check	0					0								ō							
Htg Sys Ventilation	30					5,554								185							
Water Heater Ventilation	16 0					2,938								184							
Bathroom Ventilation Dryer Ventilation	0					0								0							
Kitchen Ventilation	0					0								ő							
Other Exhaust Ventilation	0					0								0							
Asbestos Removal (Minor)	0					0								0							
Health/Safety Repairs	6					446								74 0							
Health/Safety Other Consumables	0					0	-							0							
General Repairs	37					11,040								298							
Meter Refrig (no action)	0					0								0							
Meter Freezer (no action) Support	0 40					0 28,766								719							
Transportation Allowance	0					28,766								719							
Landlord Contr Misc	0					0								0							
Landlord Contr Furnace	0					0								0							
Landlord Contr DHW Client Contr (Any)	0					0								0							
Lead Safe Work	0					0	-							0							
Unspecifed/Other	0					0								l o							

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

² Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

The total number of dwellings may exceed the number of measures installed in cases where the tillity partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$653,648

	Numbe	r of Dwe	llinas	Numbe	r of Dwellings				Billing A	djusted F	irst-Year S	avings		Averag			ted First			nd Savin	gs
		with Impac		with Elec	tricity Impacts	Spending on			Electricity				Gas	Spending on	•	_	Electricity	,			as
Measure	Total	Electric	Gas	Seas Cooling		Materials & Labor (\$)	Sum kW	mer kWh	kW	nter kWh	Annual kWh	Pk-Day therms	Annual therms	Materials & Labor (\$)	Sum kW	mer kWh	Win kW	ter kWh	Annual kWh	Pk-Day therms	Annual therms
Total Efficiency Measures	112	90	100	89	90	531,265	14.1		15.6		58,386	192	18,712	4,743	0.159		0.173		649	1.92	187
Total Shell & Htg. Sys. Repl	107	79	99	66	79	413,096	11.3	13,678	11.5	17,702	31,379	178	16,374	3,861	0.172	207	0.145	224	397	1.80	165
Total Shell Measures	107	79	99	66	79	305,198	11.3	13,678	11.3	17,447	31,125	125	11,474	2,852	0.172	207	0.143	221	394	1.26	116
Wall Insul.	50	37	45	37	1	108,004	4.3	5,174	0.9	1,437	6,611	33	3,042	2,160	0.116	140	0.933	1,437	179	0.74	68
Open Blown Ceiling Insul. Cavity Fill Insul.	73 16	55 8	65 15	55 8	3 0	68,945 20,396	5.2 0.4	6,305 450	6.3 0.0	9,708 0	16,012 450	50 10	4,558 875	944 1,275	0.095 0.047	115 56	2.101 0.000	3,236 0	291 56	0.76 0.63	70 58
Sloped Attic Insul.	20	13	17	13	1	10,815	0.4	589	0.5	773	1,362	6	508	541	0.047	45	0.502	773	105	0.03	30
Kneewall Insul.	27	16	24	16	1	11,884	0.4	432	0.1	156	588	4	337	440	0.022	27	0.101	156	37	0.15	14
Infil. Reduction	86	24	83	24	3	34,361	0.2	222	0.2	303	525	9	854	400	0.008	9	0.066	101	22	0.11	10
Found./Crawl. Insul. Bandjoist Insul.	51 48	9	49 46	8	2 2	41,468 9,325	0.4 0.0	505 0	0.6 0.2	869 357	1,375 357	12 2	1,131 201	813 194	0.052	63 0	0.282 0.116	435 179	153 179	0.25 0.05	23 4
Furnace Blower Fan ¹	104	76	99	_	76	0,020	0.0	0	2.5	3,844	3,844	(0)			0.000	0	0.033	51	51	(0.00)	(0)
Exhaust Ventilation	0	0	0	0	0	0	0.0	0	0.0	0,011	0,011	0	0	0	-	-	-	-	-	-	- (0)
Total Heating System Repl	46	2	44	-	2	107,898	0.0	0	0.2	255	255	53	4,900		0.000	0	0.083	127	127	1.21	111
Condensing Htg Sys Repl	44	0	44	-	-	101,358	0.0	0	0.0	0	0	53	4,900	2,304	-	-	-	-	-	1.21	111
Non-Cond Htg Sys Repl Electric Htg Sys Repl	0 2	0 2	0	-	2	0 6,540	0.0 0.0	0	0.0 0.2	0 255	0 255	0	0	0 3,270	0.000	- 0	0.083	- 127	- 127	-	-
Heat Pump Repl	0		0	- 1	0	0,340	0.0	0	0.2	0	0	0	0	0	-	-	-	-	-		
Other Htg Sys Repl	0	0	0	-	0	0	0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	
				Num	ber of Measures																
				b	y Fuel Type		Summer		Winter		Annual	Pk-Day	Annual		Summer		Winter		Annual		Annual
M-4	Total	Electric	Gas		Electric Gas	102,879	kW		kW		kWh	therms	therms	4.000	kW		kW		kWh	therms	therms
Water Heating Temp. Reduct.	102	25 0	77	166 0	32 134 0 0	102,879	0.0		0.0		2,049	13.5	2,338	1,009	0.000		0.001		82	0.176	30
WH Wrap	ő	0	0	0	0 0	0	0.0		0.0		0	0.0	0	ő	-		-		-	-	-
Pipe Insul.	101	25	76	101	25 76		0.0		0.0		1,102	0.7	241	19	0.000		0.000		44	0.01	3
LF Showerhead Faucet Aerator	1 0	0	1	1 0	0 1	10 0	0.0 0.0		0.0		0	0.0	11 0	10			-		-	0.04	11
Std-Eff Wtr Htr Repl.	0	0	0	0	0 0	0	0.0		0.0		0	0.0	0	ő	-		-		-	-	-
Hi-Eff or Electric Wtr Htr Repl.	74	9	65	64	7 57	100,990	0.0		0.0		947	12.8	2,087	1,365	0.000		0.003		105	0.20	32
Lighting	70			510	510	3,764	1.6		3.0		15,252	-	-	54	0.023		0.042		218	-	-
Refrigerator/Freezer ³ Refrigerator Removal	19 0	19 0		19 0	19 0	11,526 0	1.2 0.0		1.1 0.0		9,705	-	-	607	0.063		0.059		511	-	-
Refrigerator Exchange	19	19		19	19	11,526	1.2		1.1		9,705	_	-	607	0.063		0.059		511	-	-
Freezer Removal	0			0	0	0	0.0		0.0		0	-	-	0	-		-		-	-	-
Freezer Exchange	0	0		0	0	0	0.0		0.0		0		-	0							
Total Non-Efficiency Measures	112					122,383								1,093							
Misc Ins,Attic Access/Vent Duct Sealing	17 42					1,711 10,284								101 245							
Duct Insulation	3					2,945								982							
Damming Material	0					0								0							
Htg. Sys. Tune & Clean	54					4,515								84							
Htg. Sys./WH Other Air Conditioning Work	0					0								0							
Water Heater Repair	ő					ő								Ö							
Refrigerator Coil Clean	0					0								0							
Waterbed Mattress Pad Programmable Tstat	0					0								0							
Unspecified Utility Meas.	ő					0								ő							
CO Detector	0					0								0							
Smoke Detector Fuses	0					0								0							
Htg Sys Safety Check	0					0								0							
Htg Sys Ventilation	42					6,229								148							
Water Heater Ventilation	53					8,001								151							
Bathroom Ventilation Dryer Ventilation	0					0								0							
Kitchen Ventilation	ő					0								ő							
Other Exhaust Ventilation	0					0								0							
Asbestos Removal (Minor) Health/Safety Repairs	0 5					0 258								0 52							
Health/Safety Other	0					0								0							
Consumables	0					0								0							
General Repairs	65					19,587								301							
Meter Refrig (no action) Meter Freezer (no action)	10					0								0							
Support	112					68,855								615							
Transportation Allowance	0					0								0							
Landlord Contr Misc Landlord Contr Furnace	0					0								0							
Landlord Contr Pdifface Landlord Contr DHW	0					0								0							
Client Contr (Any)	0					0								0							
Lead Safe Work Unspecifed/Other	0				· <u> </u>	0								0							
onspeciled/Oiner	0					0								0							

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

² Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$734,377

	Numbe	r of Dwe	llinas	Number	of Dwellings				Billing A	Adjusted Fi	irst-Year S	avings		Averaç			ted First Receivin			nd Savin	gs
		with Impac		with Elect	ricity Impacts	Spending on			Electricity				Gas	Spending on	-	-	Electricity	,			ias
Measure	Total	Electric	Gas	Seaso Cooling		Materials & Labor (\$)	Sum kW	mer kWh	kW	inter kWh	Annual kWh	Pk-Day therms	Annual therms	Materials & Labor (\$)	Sumr kW	ner kWh	Wint kW	ter kWh	Annual kWh	Pk-Day therms	Annual therms
Total Efficiency Measures	113	97	111	97	97	598,294	15.4		7.5		44,023	228	22,160	5,295	0.159		0.077		454	2.06	200
Total Shell & Htg. Sys. Repl	113	94	111	93	94	472,648	13.4	16,183	4.8	7,385	23,568	215	19,746	4,183	0.144	174	0.051	79	251	1.94	178
Total Shell Measures	113	94	111	93	94	236,610	13.4	16,183	4.8	7,385	23,568	113	10,393	2,094	0.144	174	0.051	79	251	1.02	94
Wall Insul.	66	55	65	55	0	109,047	6.4	7,720	0.0	0	7,720	44	4,052	1,652	0.116	140	0.000	0	140	0.68	62
Open Blown Ceiling Insul. Cavity Fill Insul.	68 24	55 15	67 24	55 15	0	41,137 10,804	4.3 0.8	5,211 942	0.0	0	5,211 942	33 13	2,987 1,200	605 450	0.079	95 63	0.000	0	95 63	0.49 0.54	45 50
Sloped Attic Insul.	20	16	19	16	0	6,388	0.0	849	0.0	0	849	8	697	319	0.032	53	0.000	0	53	0.40	37
Kneewall Insul.	22	15	21	15	0	7,314	0.2	212	0.0	0	212	3	271	332	0.012	14	0.000	0	14	0.14	13
Infil. Reduction	113	89	111	89	1	48,888	0.7	894	0.1	118	1,012	11	1,047	433	0.008	10	0.077	118	11	0.10	9
Found./Crawl. Insul.	17	6	16	6	0	5,429	0.3	355	0.0	0	355	1	115	319	0.049	59	0.000	0	59	0.08	7
Bandjoist Insul.	16		16	-	0	7,604	0.0	0	0.0	0	0	1	51	475	-	-	-	-	-	0.03	3
Furnace Blower Fan ¹	112		111		93	0	0.0	0	4.7	7,267	7,267	(0)		0	0.000	0	0.051	78	78	(0.00)	(0)
Exhaust Ventilatior Total Heating System Repl	0 82	0	0 82	0	0	236,038	0.0	0	0.0	0	0	102	9,353	0 2,879	-	-		-		1.24	114
Condensing Htg Sys Repl	82	0	82		-	236,038	0.0	0	0.0	0	0	102	9,353	2,879	-:-					1.24	114
Non-Cond Htg Sys Repl	0	0	0	-	-	0	0.0	Ö	0.0	Ö	0	0	0,000	0	-	-	-	-	-	-	
Electric Htg Sys Repl	0	0	0	-	0	0	0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	-
Heat Pump Repl	0		0	-	0	0	0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	-
Other Htg Sys Repl	0	0	0	-	0	0	0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	
					er of Measures Fuel Type		Summer		Winter		Annual	Pk-Day	Annual		Summer		Winter		Annual	Pk-Day	Annual
	Total	Electric	Gas	Total	Electric Gas		kW		kW		kWh	therms	therms		kW		kW		kWh	therms	therms
Water Heating	108	23	85 0	271	44 227 0 0	111,928	0.0		0.1		3,260	13.4	2,414		0.000		0.002		142	0.158	28
Temp. Reduct. WH Wrap	0	0	0	0	0 0		0.0		0.0		0	0.0	0	0	-		-		-	-	-
Pipe Insul.	102	22	80	102	22 80		0.0		0.0		953	0.7	231	19	0.000		0.000		43	0.01	3
LF Showerhead	20	5	15	21	5 16		0.0		0.0		875	0.4	108	10	0.000		0.004		175	0.02	7
Faucet Aerator	58	6	52	81	8 73		0.0		0.0		263	0.3	99	7	0.000		0.001		44	0.01	2
Std-Eff Wtr Htr Repl. Hi-Eff or Electric Wtr Htr Repl.	0 78	0 12	0 66	0 67	0 0 9 58	0 109,378	0.0		0.0		0 1,169	0.0 12.1	0 1,976	0 1,402	0.000		0.002		97	- 0.18	30
Lighting	75		00	478	478	3,313	0.8		1.6		8,041	- 12.1	-	1,402	0.000		0.002		107	-	-
Refrigerator/Freezer ³	17	17		18	18	10,405	1.1		1.1		9,154	-	-	612	0.066		0.062		538	-	-
Refrigerator Removal	0	0		0	0	0	0.0		0.0		0	-	-	0	-		-		-	-	-
Refrigerator Exchange	12			12	12	7,465	0.7		0.7		6,007	-	-	622	0.062		0.058		501	-	-
Freezer Removal Freezer Exchange	0 6	0 6		0 6	0 6	0 2,940	0.0 0.4		0.0 0.4		0 3,147	-		0 490	0.065		0.060		- 525	-	-
1 100201 Examingo						2,010	0.1		0.1		0,111	l		100	0.000		0.000		020	l	
Total Non-Efficiency Measures	113					136,083								1,204							
Misc Ins,Attic Access/Vent Duct Sealing	56 1					3,912 270								70 270							
Duct Insulation	0					0								2/0							
Damming Material	0					0								0							
Htg. Sys. Tune & Clean	0					0								0							
Htg. Sys./WH Other	0					0								0							
Air Conditioning Work Water Heater Repair	0					0								0							
Refrigerator Coil Clean	ő					ő								ő							
Waterbed Mattress Pad	0					0								0							
Programmable Tstat	71					6,947								98							
Unspecified Utility Meas. CO Detector	0					0								0							
Smoke Detector	0					0								0							
Fuses	0					0								0							
Htg Sys Safety Check	0					0								0							
Htg Sys Ventilation Water Heater Ventilation	75 58					11,733 7,361								156 127							
Bathroom Ventilation	0					7,301								0							
Dryer Ventilation	0					ő								ő							
Kitchen Ventilation	0					0								0							
Other Exhaust Ventilation	0					0								0							
Asbestos Removal (Minor)	0					0								0							
Health/Safety Repairs Health/Safety Other	34 0					2,061								61 0							
Consumables	0					0								0							
General Repairs	97					24,687								255							
Meter Refrig (no action)	68					0								0							
Meter Freezer (no action)	26					0								0							
Support Transportation Allowance	113 0					79,113 0								700 0							
Landlord Contr Misc	0					0								0							
Landlord Contr Furnace	0					0								0							
Landlord Contr DHW	0					0								0							
Client Contr (Any) Lead Safe Work	0					0								0							
Unspecifed/Other	0					0								0							

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

² Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

³ The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$29,152

	ii								Billing A	djusted F	irst-Year S	avings		Avera	ge Billing					nd Savin	gs
	Numb	er of Dwe		Number of Dwe with Electricity Im		Spending on		E	Electricity			ı	Gas	Spending on	per Dv		Receivii Electricit		sures	6	as
Measure	Total	Electric		Season Cooling Heating		Materials & Labor (\$)	Sum kW			nter kWh	Annual kWh	Pk-Day therms	Annual therms	Materials & Labor (\$)	Sum:		Win kW		Annual kWh	Pk-Day therms	Annual therms
								KVVII		KVVII						KVVII		KVVII			
Total Efficiency Measures		6	6	5 6		23,171	0.8		0.5		1,633	6	572	3,310	0.150		0.084		272	0.99	95
Total Shell & Htg. Sys. Repl Total Shell Measures	6					15,571 9,471	0.8	907 907	0.5	726 726	1,633 1,633	5	453 198		0.150 0.150	181 181	0.084	121 121	272 272	1.05	91
Wall Insul.						9,471	0.0	907	0.0	0	1,033	0	198		0.150	-	0.084	- 121	- 212	- 0.46	40
Open Blown Ceiling Insul.	4	4	. 3	3 1		5,463	0.4	446	0.4	510	955	0	36	1,366	0.123	149	0.353	510	239	0.14	12
Cavity Fill Insul. Sloped Attic Insul.	(0	0 0		0 1,107	0.0 0.2	0 203	0.0	0	0 203	0	0 87	0 1,107	0.168	203	0.000	- 0	203	1.01	- 87
Kneewall Insul.	2			2 0		322	0.2	27	0.0	0	27	Ó	8	161	0.100	13	0.000	0	13	0.05	4
Infil. Reduction	4			4 0		1,587	0.0	41	0.0	0	41	1	45		0.008	10	0.000	0	10	0.13	11
Found./Crawl. Insul. Bandjoist Insul.	2					992 0	0.2 0.0	190 0	0.0	0	190 0	0	22 0	496	0.079	95	0.000	0	95	0.13	11
Furnace Blower Fan ¹				- 5		0	0.0	0	0.1	217	217	(0	-	J	0.000	0	0.030	43	43	(0.00)	(0)
Exhaust Ventilatiorf				0 0		0	0.0	0	0.0	0	0	0	, (.,	Ö	-	-	-	-	-	-	- (0)
Total Heating System Repl	2					6,100	0.0	0	0.0	0	0				-	-	-	-	-	1.48	128
Condensing Htg Sys Repl Non-Cond Htg Sys Repl	2					6,100 0	0.0	0	0.0	0	0	3	256 0	3,050	-	-	-	-	-	1.48	128
Electric Htg Sys Repl						0	0.0	0	0.0	0	0	0			-		- 1	- 1	- 1	-	
Heat Pump Repl	(0	0.0	0	0.0	0	0	0		0	-	-	-	-	-	-	-
Other Htg Sys Repl	() 0	0	- 0		0	0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	
				Number of Me by Fuel Typ			Summer		Winter		Annual	Pk-Day	Annual		Summer		Winter		Annual	Pk-Dav	Annual
Material	Total	Electric		Total Electric	Gas	7.000	kW		kW		kWh	therms	therms	4.0	kW		kW		kWh	therms	therms
Water Heating Temp. Reduct.	(8		0.0		0.0		0	0.7		1,267	-					0.113	20
WH Wrap	Č			0 0	Ö	0	0.0		0.0		0	0.0	0	0	-		-		-	-	-
Pipe Insul.					5	100	0.0		0.0		0	0.0			-		-		-	0.01	3
LF Showerhead Faucet Aerator	(-	0 0	0	0	0.0		0.0		0	0.0		0	-					-	-
Std-Eff Wtr Htr Repl.	i		-	0 0	0	0	0.0		0.0		0	0.0	0	0	-		-		-	-	-
Hi-Eff or Electric Wtr Htr Repl.				3 0	3	7,500	0.0		0.0		0	0.6	104		-		-		-	0.13	21
Lighting Refrigerator/Freezer ³	(0 0		0	0.0		0.0		0		-	0	-					-	-
Refrigerator Removal	(0 0		0	0.0		0.0		0	-	-	0	-		-		-	-	-
Refrigerator Exchange	(0 0		0	0.0		0.0		0	-	-	0			-		-	-	-
Freezer Removal Freezer Exchange	(0 0		0	0.0		0.0		0	-		0	-		-		-	-	
Total Non-Efficiency Measures	1 6	,				5,981								997							
Misc Ins,Attic Access/Vent	2					233								117							
Duct Sealing	(0								0							
Duct Insulation Damming Material	(0								0							
Htg. Sys. Tune & Clean						125								125							
Htg. Sys./WH Other	(0								0							
Air Conditioning Work Water Heater Repair	(0								0							
Refrigerator Coil Clean						0								0							
Waterbed Mattress Pad	(0								0							
Programmable Tstat Unspecified Utility Meas.	(0								0							
CO Detector	()				0								0							
Smoke Detector	(0								0							
Fuses Htg Sys Safety Check	(0								0							
Htg Sys Ventilation	3	3				700								233							
Water Heater Ventilation	3					650								217							
Bathroom Ventilation Drver Ventilation	(0								0							
Kitchen Ventilation	Č					0								0							
Other Exhaust Ventilation	(0								0							
Asbestos Removal (Minor) Health/Safety Repairs						0 63								63							
Health/Safety Other	()				0								0							
Consumables General Repairs	(· <u></u>	0 1,779							·	0 297							
Meter Refrig (no action)						1,779								297							
Meter Freezer (no action)						0								0							
Support Transportation Allowance	4	•				2,431 0								608							
Landlord Contr Misc						0								0							
Landlord Contr Furnace	· ·					0								0							
Landlord Contr DHW Client Contr (Any)	(0								0							
Lead Safe Work						0								0	-						
Unspecifed/Other	()				0								0							

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

² Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$493,727

Marsine Mars		п								Billing A	djusted F	irst-Year S	avings		Averaç			ted First			nd Savin	gs
Part Part							Coording on			Ele etricite			ı	Coo	Coording on	per Dv				ures		•••
Part Part		1	with impac	its				Sum				Annual				Sumi				Annual		
Part Part	Measure	Total	Electric	Gas	Cooling	Heating	& Labor (\$)	kW	kWh	kW	kWh	kWh	therms	therms	& Labor (\$)	kW	kWh	kW	kWh	kWh	therms	therms
Trans-free Memory Configuration 1	Total Efficiency Measures	92	81	73	79	81	400,025	15.5		10.9		43,514	144	14,019	4,348	0.196		0.135		537	1.98	192
Wate March	Total Shell & Htg. Sys. Repl	91	80	73	76	80	336,370	14.4	17,374	9.5	14,825	32,199	137	12,745	3,696	0.190	229	0.119	185	402	1.87	175
Cone Bounc Carling Seed. 77 58 77 28 4 44 205 4.5 5.467 31 4.515 10.345 14.5 13.15 661 6.775 14.5 202 778 2.25 7.3 2.25 2.35																						
Camp First Mark 22 19 19 19 19 19 19 19																						
Supper Alse Parel. 90																						
Inf. Non-Concording 10	Sloped Attic Insul.	30	23	25	23	0	13,904		1,463	0.0	0	1,463	9	830	463	0.053	64	0.000	0	64	0.36	33
Search Cannel Product 1985 13 23 13 15 15 15 15 15 15 1			20	22																		
Burches Name 60 2 38 2 2 5.73 0.8 0.2 308 248 2 169 160 300 0.0 1.04 183 183 183 0.80 6.75 184 1																				13		
Funes Persone Favi 99 75 73 - 75 0 0 0.0 0 30 4.79 4.78 0.0 0.00 0.00 0.00 0.00 0.00 0.00 0.					- 13																	
Enterlier Methods Company Comp					_																	
Total New York 1					n										0	-		-			-	- (-/
Nes-Cord Rig Syr Rept					-										2,076	-	-	-	-	-	1.18	110
Electric Plays Regis 0					-	-										-	-	-	-	-	1.18	110
Need Plany Rept 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0					-	-									-	-	-	-	-	-	-	-
Charles Sign Regist Column Charles Sign Regist Column Charles Column Ch					_												-		-	-	-	
Marchard Section Sec					_										ő	-	-	-	-	-	-	-
Total Electric Gas State Sta					Numl	per of Measures																
Temp. Reflock. O		Total	Electric	Gas	by Total	Fuel Type Electric Gas							Pk-Day therms									
With Warp	Water Heating	65	24	41	91	29 63		0.0		0.0		2,146	7.6	1,274	885			0.001				
Pipe Install																-		-		-	-	-
Life Showeshead Company															0.000		0.000		_	0.01	- 3	
SS-SE-FIN THE Rept. 4 8 38 6 42 8 35 57.31 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.	LF Showerhead	2	1			1 1				0.0					5						0.02	7
Hi-Eff or Electric With Hir Repul. Marting Martin												-				-				-	0.00	1
Lighting 34 34 312 312 591 0.5 0.9 4.564 17 0.014 0.026 134 -																0.000		_		120	0.20	- 33
Refrigerator Freezer				- 00									-								-	
Refrigerator Exchange		9	9		9	9	5,535	0.6		0.5		4,605	-	-	615	0.063		0.059		512	-	-
Freezer Removal													-								-	-
Tracial Non-Efficiency Measures 22 93,703 1,019													-			0.063		0.059		512	-	-
Misc Ins. Allo Accessivent 59							0						-									
Misc Ins. Allo Accessivent 59	Total Non-Efficiency Measures	92					93.703								1.019							
Duct Insulation 0 Damming Material 0 Hg. Sys. Tune & Clean 12 Hg. Sys. Tune & Clean 12 Hg. Sys. Tune & Clean 0 Air Conditioning Work 0 Well Present 0 Wall Present 0 Wall Present 0 Waller Head 0 Waller Head 0 Voganization 0 Unspecified Utility Meas. 0 0 0 Unspecified Utility Meas. 0 0 0 Smoke Detector 0 0 0 Hus Sys Purtitation 0 46 6,483 48 141 Waster Heater Verillation 0 0 0 19yer Verillation 0	Misc Ins,Attic Access/Vent	59					14,159															-
Damming Material 0 0 0 1, 1,887 951 1,987 416, Sys. Tune & Clean 1 12 1,887 951 1,887																						
Hg, Sys, Tune & Clean 12																						
Hig. Sys.WH Other Air Conditioning Work 0 Water Heater Repair Refrigerator Coll Clean 0 Waterbeld Mattress Pad 0 0 Waterbeld Mattress Pad 0 0 Unspecified Utility Meas. 0 0 Unspecified Utility Meas. 0 0 0 Smoke Detector 0 Smoke Detector 0 Smoke Detector 0 Hig Sys Safety Check 0 0 Hig Sys Safety Check 0 0 Hig Sys Safety Check 0 0 Hig Sys Safety Check 0 0 0 Hig Sys Safety Check 0 0 0 Hig Sys Safety Check 0 0 0 Hig Sys Pathilation 46 6,483 4141 Water Heater Ventilation 36 3,226 32 Battroom Ventilation 0 0 Dryer Wentilation 0 0 0 Hig Sys Fermival (Minor) 0 0 Hig Sys Fermival (Minor) 0 0 Cher Ezhaust Ventilation 0 0 Cher Ezhaust Ventilation 0 0 Cher Ezhaust Ventilation 0 0 Cher Ezhaust Ventilation 0 0 Cher Ezhaust Ventilation 0 0 Cher Ezhaust Ventilation 0 0 Cher Ezhaust Ventilation 0 0 Cher Ezhaust Ventilation 0 0 Cher Ezhaust Ventilation 0 0 Cher Ezhaust Ventilation 0 0 Cher Ezhaust Ventilation 0 0 Cher Ezhaust Ventilation 0 0 Cher Ezhaust Ventilation 0 0 Cher Ezhaust Ventilation 0 0 Cher Ezhaust Ventilation 0 0 Cher Ezhaust Ventilation 0 0 Consumables 0 0 C																						
Water Heater Repair Refrigerator Coil Clean 0	Htg. Sys./WH Other	0					0								0							
Refrigerator Coil Clean 0 Walented Mattress Pad 0 Programmable Tstat 0 Unspecified Utility Meas. 0 CO Detector 0 Smoke Detector 0 Fuses 0 0 0 Fuses 0 0 0 Hig Sys Safety Check 0 46 6.483 48 Hater Ventilation 36 58 Safety Check Ventilation 0 60 Sys Ventilation 0 70 Sys Ventilation 0 80 Safety Check Ventilation 0 81 Stroom Ventilation 0 82 Stroom Ventilation 0 83 Stroom Ventilation 0 84 Stroom Ventilation 0 85 Stroom Ventilation 0 86 Stroom Ventilation 0 86 Stroom Ventilation 0 88 Stroom Ventilation 0 89 Stroom Ventilation 0 80 Stroom Ventilation 0 81 Stroom Ventilation 0																						
Waterbed Mattress Pad 0 0 Programmable Telat 0 0 Unspecified Utility Meas. 0 0 CO Detector 0 0 Fuses 0 0 Fuses 0 0 Hg Sys Safely Check 0 0 Hg Sys Verifilation 46 6,483 Water Heater Verifilation 36 3,326 Bathroom Vermillation 0 0 Orner Echatus Verifilation 0 0 Other Echatus Verifilation 0 0																						
Programable Tstat																						
CO Detector	Programmable Tstat						0								0							
Smoke Detector 0																						
Fuses																						
Hig Sys Ventilation 46 6,483 92 Water Heater Ventilation 36 3,326 92 Bathroom Ventilation 0 0 0 0 Dryer Ventilation 0 0 0 0 Other Exhaust Ventilation 0 0 0 0 Other Exhaust Ventilation 0 0 0 0 Other Exhaust Ventilation 0 0 0 0 0 Asbestos Removal (Minor) 0 0 0 0 0 Asbestos Removal (Minor) 0 0 0 0 0 0 Asbestos Removal (Minor) 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0																						
Water Heater Ventilation 36 3,326 92 Bathroom Ventilation 0 0 0 Dryer Ventilation 0 0 0 Kitchen Ventilation 0 0 0 Other Exhaust Ventilation 0 0 0 Asbestos Removal (Minor) 0 0 0 Health/Safety Repairs 18 696 39 Health/Safety Other 0 0 0 Consumables 0 0 0 General Repairs 85 23,066 271 Meter Refrig (no action) 56 0 0 Meter Freezer (no action) 13 0 0 Support 92 44,886 488 Transportation Allowance 0 0 0 Landlord Contr Misc 0 0 0 Landlord Contr Furnace 0 0 0 Landlord Contr Furnace 0 0 0 Landlord Contr (Any) 0 0<																						
Bathroon Ventilation 0 0 0 Dryer Ventilation 0 0 0 Kitchen Ventilation 0 0 0 Other Exhaust Ventilation 0 0 0 Asbestos Removal (Minor) 0 0 0 Health/Safety Repairs 18 696 39 Health/Safety Other 0 0 0 Consumables 0 0 0 General Repairs 85 23,066 271 Meter Refrig (no action) 56 271 Meter Freezer (no action) 13 0 0 Support 92 44,886 488 Transportation Allowance 0 0 0 Landlord Contr Furnace 0 0 0 Lead Safe Work 0 0 0																						
Dyer Ventilation 0																						
Other Exhaust Ventilation 0 0 Asbestos Removal (Minor) 0 0 Health/Safety Repairs 18 696 Health/Safety Other 0 0 Consumables 0 0 General Repairs 85 23,066 271 Meter Refrig (no action) 56 0 0 Meter Freezer (no action) 13 0 0 Support 92 44,886 488 Transportation Allowance 0 0 0 Landlord Contr Misc 0 0 0 Landlord Contr Furnace 0 0 0 Landlord Contr Furnace 0 0 0 Client Contr (Any) 0 0 0 Clead Safe Work 0 0 0																						
Asbestos Removal (Minor) 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	Kitchen Ventilation	0													0							
Health/Safety Other																						
Health/Safety Other																						
Consumables 0 0 0 General Repairs 85 23,066 271 Meter Refrig (no action) 56 0 0 Meter Freezer (no action) 13 0 0 Support 92 44,886 488 Transportation Allowance 0 0 0 Landlord Contr Misc 0 0 0 Landlord Contr Furnace 0 0 0 Leaf Safe Work 0 0 0																						
Meter Refrig (no action) 56 0 0 Meter Freezer (no action) 13 0 0 Support 92 44,886 488 Transportation Allowance 0 0 0 Landlord Contr Misc 0 0 0 Landlord Contr Furnace 0 0 0 Landlord Contr DHW 0 0 0 Client Contr (Any) 0 0 0 Lead Safe Work 0 0 0	Consumables	0					0								0							
Meter Freezer (no action) 13 0 0 Support 92 44.886 488 Transportation Allowance 0 0 0 Landlord Contr Misc 0 0 0 Landlord Contr Furnace 0 0 0 Landlord Contr Furnace 0 0 0 Client Contr (Any) 0 0 0 Cleent Contr (Any) 0 0 0 Lead Safe Work 0 0 0																						
Support 92 44,886 488 Transportation Allowance 0 0 0 Landlord Contr Misc 0 0 0 Landlord Contr Furnace 0 0 0 Landlord Contr DHW 0 0 0 Client Contr (Any) 0 0 0 Lead Safe Work 0 0 0																						
Transportation Allowance 0 0 0 Landlord Contr Misc 0 0 0 Landlord Contr Furnace 0 0 0 Landlord Contr DHW 0 0 0 Client Contr (Any) 0 0 0 Lead Safe Work 0 0 0																						
Landlord Contr Furnace 0 0 Landlord Contr DHW 0 0 Client Contr (Any) 0 0 Lead Safe Work 0 0															0							
Landlord Contr DHW 0 0 Client Contr (Any) 0 0 Lead Safe Work 0 0																						
Client Contr (Any) 0 0 Lead Safe Work 0 0																						
															0							
	Lead Safe Work Unspecifed/Other	0					0								0							

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

² Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$120,318

									Billing A	Adjusted F	irst-Year S	avings		Averaç				Year Co		nd Savin	gs
		er of Dwe			r of Dwellings tricity Impacts	Spending on			Electricity			ı	Gas	Spending on	per Dv		Receivin	g Measu	res		ias
		-		Seas	on	Materials	Sum	mer	W	inter	Annual	Pk-Day	Annual	Materials	Sum	mer	Wint	ter A		Pk-Day	Annual
Measure	Total	Electric	Gas	Cooling	Heating	& Labor (\$)	kW	kWh	kW	kWh	kWh	therms	therms	& Labor (\$)	kW	kWh	kW	kWh l	Wh	therms	therms
Total Efficiency Measures	21	20	19	19	20	99,813	4.5		2.0		13,208	33	3,147	4,753	0.237		0.100		660	1.74	166
Total Shell & Htg. Sys. Repl	20		18	18	20	82,492	3.9	4,666	0.8	1,239	5,905	32	2,890	4,125	0.215	259	0.041	62	295	1.76	161
Total Shell Measures	20		18	18	20	52,633	3.9	4,666	0.8	1,239	5,905		1,534		0.215	259	0.041	62	295	0.93	85
Wall Insul. Open Blown Ceiling Insul.	13 15			12 15	0	27,729 8.939	1.7 1.4	2,072 1,675	0.0	0	2,072 1,675	9	787 234	2,133 596	0.143	173 112	0.000	0	173 112	0.72 0.17	66 16
Cavity Fill Insul.	5		5	4	0	4,083	0.2	232	0.0	0	232	2	170	817	0.093	58	0.000	0	58	0.17	34
Sloped Attic Insul.	4	4	4	4	Ō	2,887	0.3	303	0.0	0	303	2	154	722	0.063	76	0.000	0	76	0.42	38
Kneewall Insul.	4		4	3	0	1,669	0.1	75	0.0	0	75	1	74	417	0.021	25	0.000	0	25	0.20	18
Infil. Reduction	19		18	15 1	1	4,290	0.2	234	0.1	87	321	1	80	226	0.013	16	0.057	87	21	0.05	4
Found./Crawl. Insul. Bandjoist Insul.	3 5		2 5	_ '	0	882 2,154	0.1 0.0	76 0	0.0	0	76 0	0	12 28	294 431	0.063	76	0.000	0	76	0.06	6 6
Furnace Blower Fan ¹	19		-	_	19	0	0.0	0	0.8	1,152	1,152	(0)			0.000	0	0.040	61	61	(0.00)	(0)
Exhaust Ventilation	0		0	0	0	0	0.0	0	0.0	0	0,102	0	0	0	-	-	-	-	-	(0.00)	- (0)
Total Heating System Repl	12				0	29,859	0.0	0	0.0	0	0	15	1,356	2,488	-	-	-	-	-	1.24	113
Condensing Htg Sys Repl	12			-	-	29,859	0.0	0	0.0	0	0	15	1,356	2,488	-	-	-	-	-	1.24	113
Non-Cond Htg Sys Repl	0		0	-	-	0	0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	-
Electric Htg Sys Repl Heat Pump Repl	0		0	-	0	0	0.0	0	0.0	0	0	0	0	0	-			-		-	
Other Htg Sys Repl	ő		0	-	0	ő	0.0	0	0.0	0	0	0	0	ő	-	-	-	-	-	-	-
				by	ber of Measures Fuel Type		Summer		Winter		Annual	Pk-Day	Annual		Summer		Winter			Pk-Day	Annual
Water Heating	Total 20	Electric 9		Total 37	Electric Gas 16 21	15,928	kW 0.0		kW		kWh 1,270	therms 1.5	therms 257	796	kW 0.000		kW 0.002		141	0.132	therms 23
Temp. Reduct.	1		0	1	1 0	15,926	0.0		0.0		1,270	0.0	0	0	0.000		0.002		115	-	-
WH Wrap	0			0	0 0		0.0		0.0		0	0.0	0	0	-		-		-	-	-
Pipe Insul.	18		10	18	8 10		0.0		0.0		353	0.1	28	17	0.000		0.000		44	0.01	3
LF Showerhead Faucet Aerator	1 2		1	3	0 1 1 2	10 10	0.0		0.0		0 33	0.0	7	10 5	0.000		0.001		- 33	0.02	7
Std-Eff Wtr Htr Repl.	0		0	0	0 0		0.0		0.0		0	0.0	0	0	-		-		-	-	-
Hi-Eff or Electric Wtr Htr Repl.	15		9	14	6 8	15,598	0.0		0.0		768	1.3	219	1,040	0.000		0.003		128	0.15	24
Lighting	16			226	226	1,393	0.6		1.2		6,033	-	-	87	0.040		0.073		377	-	-
Refrigerator/Freezer³ Refrigerator Removal	0			0	0	0	0.0		0.0		0	-	-	0	-		-		-	-	-
Refrigerator Exchange	0			0	0	0	0.0		0.0		0	-		0						-	-
Freezer Removal	0	0		0	0	0	0.0		0.0		0	-	-	0	-		-		-	-	-
Freezer Exchange	0	0		0	0	0	0.0		0.0		0	-	-	0	-		-		-	-	
Total Non-Efficiency Measures	21					20,505								976							
Misc Ins,Attic Access/Vent	5					551								110							
Duct Sealing Duct Insulation	0					0								0							
Damming Material	ő					ő								ő							
Htg. Sys. Tune & Clean	7					865								124							
Htg. Sys./WH Other	0					0								0							
Air Conditioning Work Water Heater Repair	0					0								0							
Refrigerator Coil Clean	0					ő								ő							
Waterbed Mattress Pad	0					0								0							
Programmable Tstat Unspecified Utility Meas.	0					0								0							
CO Detector	0					0								0							
Smoke Detector	0					0								0							
Fuses	0					0								0							
Htg Sys Safety Check	0					1 522								0 117							
Htg Sys Ventilation Water Heater Ventilation	13 9					1,522 1,085								117							
Bathroom Ventilation	0					0								0							
Dryer Ventilation	0					0								0							
Kitchen Ventilation Other Exhaust Ventilation	0					0								0							
Asbestos Removal (Minor)	0					0								0							
Health/Safety Repairs	1					48								48							
Health/Safety Other	0					0								0							
Consumables General Repairs	0 19					0 3,932								0 207							
Meter Refrig (no action)	0					3,932								0							
Meter Freezer (no action)	0					0								0							
Support	21		· ·		·	12,502 0								595							
Transportation Allowance Landlord Contr Misc	0					0								0							
Landlord Contr Furnace	ő					ő								ő							
Landlord Contr DHW	0					0								0							
Client Contr (Any) Lead Safe Work	0					0								0							
Unspecifed/Other	ő					ő								Ö							

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

² Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Total Reported Labor, Materials and Utility Admin Expenditures: \$519,108

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$519,108

									Billing A	Adjusted F	irst-Year S	avings		Averaç						nd Savin	gs
		er of Dwe			of Dwellings							1	_		per Dv		Receivir		ures		
		with Impac	its	With Elec	tricity Impacts	Spending on Materials	Sum		Electricity Wi	inter	Annual	Pk-Day	Gas Annual	Spending on Materials	Sumi		Electricit Win		Annual	Pk-Day	as Annual
Measure	Total	Electric	Gas	Cooling	Heating	& Labor (\$)	kW	kWh	kW	kWh	kWh	therms	therms	& Labor (\$)	kW	kWh	kW	kWh	kWh	therms	therms
Total Efficiency Measures	81	72	80	72	72	441,706	14.2		16.5		70,576	205	21,314	5,453	0.198		0.229		980	2.56	266
		70			70			44.550		40.400		400			0.405	100	0.400	000	200	0.00	
Total Shell & Htg. Sys. Repl Total Shell Measures	81 81		80	58 58	72 72	325,689 230,869	9.6 9.6	11,552 11,552	9.9	16,420 16,280	27,972 27,832	190 139	18,785 13,707	4,021 2,850	0.165	199 199	0.138	228 226	389 387	2.38	235 171
Wall Insul.	61		59	42	1	120,070	3.9	4,754	0.8	1,309	6,063	48	4,771	1,968	0.094	113	0.792	1,309	141	0.82	81
Open Blown Ceiling Insul.	73		71	53	1	35,259	3.9	4,683	2.4	3,966	8,649	57	5,608	483	0.073	88	2.400	3,966	160	0.80	79
Cavity Fill Insul. Sloped Attic Insul.	16 35		16 34	9 24	0	13,511 23,503	0.2 0.9	252 1,055	0.0	0	252 1,055	6	603	844 672	0.023	28 44	0.000	0	28 44	0.38	38 46
Kneewall Insul.	17		17	11	0	11,644	0.9	256	0.0	0	256	16 4	1,577 397	685	0.036	23	0.000	0	23	0.47	23
Infil. Reduction	45		44	33	Ö	15,782	0.4	447	0.0	Ő	447	4	399	351	0.011	14	0.000	0	14	0.09	9
Found./Crawl. Insul.	31			2	0	8,157	0.1	105	0.0	0	105	3	278	263	0.043	52	0.000	0	52	0.09	9
Bandjoist Insul.	19		18	-	1	2,943	0.0	0	0.2	298	298	1	119	155	0.000	0	0.180	298	298	0.07	7
Furnace Blower Fan	80		80	-	71	0	0.0	0	6.5	10,707	10,707	(0)		0	0.000	0	0.091	151	151	(0.01)	(1)
Exhaust Ventilation	49		0	0	0	94,820	0.0	0	0.0	0	141	0	0	0	0.000	- 0	- 0.005	141	141	1.07	106
Total Heating System Repl Condensing Htg Sys Repl	49		48 48	-	- '	92,072	0.0	0	0.1	141 0	0	52 52	5,079 5,079	1,935 1,918	0.000	- 0	0.085	141	- 141	1.07	106
Non-Cond Htg Sys Repl	0		0	-	-	0	0.0	0	0.0	0	0	0	0,075	0	-	-	-	-	-	-	-
Electric Htg Sys Repl	1		0	-	1	2,748	0.0	0	0.1	141	141	0	0	2,748	0.000	0	0.085	141	141	-	-
Heat Pump Repl	0		0	-	0	0	0.0 0.0	0	0.0 0.0	0	0	0	0	0	-	-	-	-	-	-	-
Other Htg Sys Repl	U	U	U	-	U	U	0.0	U	0.0	U	U	U	U	U		-		-	-	-	
					er of Measures Fuel Type		Summer		Winter		Annual	Pk-Day	Annual		Summer		Winter		Annual	Pk-Day	Annual
	Total	Electric		Total	Electric Gas		kW		kW		kWh	therms	therms		kW		kW		kWh	therms	therms
Water Heating Temp. Reduct.	78 0		68	261	24 237 0 0	84,769	0.0		0.0		1,381	14.0	2,529	1,087	0.000		0.002		138	0.206	37
WH Wrap	0			0	0 0	0	0.0		0.0		0	0.0	0	0						-	-
Pipe Insul.	74		65	74	9 65	318	0.0		0.0		396	0.5	185	4	0.000		0.000		44	0.01	3
LF Showerhead	30			30	2 28	93	0.0		0.0		350	0.6	193	3	0.000		0.004		175	0.02	7
Faucet Aerator Std-Eff Wtr Htr Repl.	65 0		57 0	91 0	11 80 0 0	48 0	0.0 0.0		0.0		378 0	0.4	108	1	0.000		0.001		47	0.01	2
Hi-Eff or Electric Wtr Htr Repl.	66		64	66	2 64	84.310	0.0		0.0		257	12.5	2,042	1,277	0.000		0.003		128	0.20	32
Lighting	60	60		676	676	3,744	2.4		4.5		22,961	-	-	62	0.040		0.074		383	-	-
Refrigerator/Freezer ³	32			35	35	27,504	2.2		2.1		18,262	-	-	860	0.070		0.066		571	-	-
Refrigerator Removal Refrigerator Exchange	30			0 27	0 27	0 23,765	0.0 1.7		0.0 1.6		0 14,056	-	-	0 792	0.058		0.054		- 469	-	-
Freezer Removal	0			0	0	0	0.0		0.0		0	-	-	0	-		-		-	-	-
Freezer Exchange	8	8		8	8	3,740	0.5		0.5		4,206	-	-	467	0.065		0.060		526	-	
Total Non-Efficiency Measures	81					77,402								956							
Misc Ins,Attic Access/Vent	21					3,393								162							
Duct Sealing	0					0								0							
Duct Insulation Damming Material	0					0								0							
Htg. Sys. Tune & Clean	20					1,804								90							
Htg. Sys./WH Other	0					0								0							
Air Conditioning Work Water Heater Repair	0					0								0							
Refrigerator Coil Clean	0					0								0							
Waterbed Mattress Pad	0					0								ő							
Programmable Tstat	0					0								0							
Unspecified Utility Meas.	0					0								0							
CO Detector Smoke Detector	0					0								0							
Fuses	0					0								ō							
Htg Sys Safety Check	0					0								0							
Htg Sys Ventilation Water Heater Ventilation	34					5,220 4,555								154							
Bathroom Ventilation	49					4,555								93 0							
Dryer Ventilation	0					0								ő							
Kitchen Ventilation	0					0								0							
Other Exhaust Ventilation	0					0								0							
Asbestos Removal (Minor) Health/Safety Repairs	0					0 318								0 79							
Health/Safety Other	0					0								0							
Consumables	0					0								0							
General Repairs	41					10,556								257 0							
Meter Refrig (no action) Meter Freezer (no action)	0					0								0							
Support	81					51,557								637							
Transportation Allowance	0					0								0							
Landlord Contr Misc Landlord Contr Furnace	0					0								0							
Landlord Contr Purnace Landlord Contr DHW	0					0								0							
Client Contr (Any)	0					0								0							
Lead Safe Work Unspecifed/Other	0					0								0							
>poonou, ourol						. 0															

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

² Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

³ The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Total Reported Labor, Materials and Utility Admin Expenditures: \$209,629

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$209,629

	Numbe	r of Dwe	llinge	Number	of Dwellings				Billing A	djusted F	irst-Year S	avings		Averag	ge Billing per Dw		ted First			nd Savin	gs
		with Impa			ricity Impacts	Spending on		E	Electricity				Gas	Spending on	per D	ciiiig	Electricity				as
			_	Seas		Materials	Sum		Wi	nter	Annual	Pk-Day	Annual	Materials	Sumn		Wint			Pk-Day	Annual
Measure	Total	Electric	Gas	Cooling	Heating	& Labor (\$)	kW	kWh	kW	kWh	kWh	therms	therms	& Labor (\$)	kW	kWh	kW	kWh	kWh	therms	therms
Total Efficiency Measures	73	61	51	60	61	174,075	8.1		10.9		32,248	66	6,438	2,385	0.134		0.178		529	1.29	126
Total Shell & Htg. Sys. Repl	72	59	51	53	58	135,548	7.4	8,913	9.9	15,410	24.323	62	5,732	1,883	0.139	168	0.170	266	412	1.21	112
Total Shell Measures	72	59		53	58	72,448	7.4	8,913	9.9	15,410	24,323	32	2,998	1,006	0.139	168	0.170	266	412	0.63	59
Wall Insul.	22	16		16	2	12,418	2.0	2,356	1.7	2,620	4,976	15	1,366	564	0.122	147	0.839	1,310	311	0.81	76
Open Blown Ceiling Insul.	46	40		40	4	19,278	3.7	4,474 177	2.0	3,118	7,592 177	6	567	419	0.093	112	0.499	779	190 59	0.16	15
Cavity Fill Insul. Sloped Attic Insul.	3 5	3	3 4	3	0 1	987 1,824	0.1 0.3	358	0.0 0.9	0 1,409	1,767	1 2	75 206	329 365	0.049 0.074	59 90	0.000	0 1,409	442	0.27 0.55	25 51
Kneewall Insul.	13	11		10	3	9,320	0.6	746	2.7	4,160	4,906	2	154	717	0.062	75	0.888	1,387	446	0.17	15
Infil. Reduction	58	32	40	32	4	18,317	0.3	403	1.2	1,807	2,210	5	436	316	0.010	13	0.289	452	69	0.12	11
Found./Crawl. Insul.	10	6		6	1	3,930	0.3	398	0.2	269	667	1	79	393	0.055	66	0.172	269	111	0.12	11
Bandjoist Insul. Furnace Blower Fan ¹	19 66	3 53		-	3 53	6,374 0	0.0	0	0.4 0.9	684 1,345	684 1,345	1 (0)	124	335	0.000	0	0.146 0.016	228 25	228 25	0.08	8
Exhaust Ventilation	00	0		- 0	0	0	0.0	0	0.9	1,345	1,345	(0)	(9)	0	0.000	U	0.016	25	25	(0.00)	(0)
Total Heating System Repl	25	0		-	0	63,100	0.0	0	0.0	0	0	29	2,735	2,524		-			-	1.17	109
Condensing Htg Sys Repl	25	0		-	-	63,100	0.0	0	0.0	0	0	29	2,735	2,524	-	-	-	-	-	1.17	109
Non-Cond Htg Sys Repl	0			-	-	0	0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	-
Electric Htg Sys Repl Heat Pump Repl	0	0	0	-	0	0	0.0 0.0	0	0.0 0.0	0	0	0	0	0	-	-	-	-	-	-	-
Other Htg Sys Repl	0	0	0	-	0	0	0.0	0	0.0	0	0	0	0	0	-		-	-	-	-	-
	ľ					Ů	0.0		0.0			ľ									
					er of Measures Fuel Type		Summer		Winter		Annual	Pk-Day	Annual		Summer		Winter		Annual	Dk Dav	Annual
	Total	Electric	Gas	Total			kW		kW		kWh	therms	therms		kW		kW		kWh	therms	therms
Water Heating	53	23	30	70	29 41		0.0		0.0		1,915	4.1	706	661			0.001			0.137	24
Temp. Reduct. WH Wrap	0	0	0	0	0 0	0	0.0		0.0 0.0		0	0.0	0	0	-		-		-	-	-
Pipe Insul.	44	22		44	0 0 22 22	419	0.0		0.0		984	0.0	63	10	0.000		0.000		45	0.01	3
LF Showerhead	0	0	0	0	0 0	0	0.0		0.0		0	0.0	0	0	-		-		-	-	-
Faucet Aerator	0	0		0	0 0	0	0.0		0.0		0	0.0	0	0	-		-		-	-	-
Std-Eff Wtr Htr Repl. Hi-Eff or Electric Wtr Htr Repl.	0 27	0 7	0 20	0 26	0 0 7 19	0 34,640	0.0 0.0		0.0		0 931	0.0 3.9	0 643	0 1,283	0.000		0.003		133	0.20	32
Lighting	25	25		155	155	446	0.0		0.6		3,325	-	-	18			0.003		133	-	-
Refrigerator/Freezer ³	4	4		5	5	3,023	0.3		0.3		2,685	-	-	756	0.083		0.077		671	-	-
Refrigerator Removal	1	1		1	1	40	0.1		0.1		512	-	-	40	0.063		0.059		512	-	-
Refrigerator Exchange Freezer Removal	4 0	4		4 0	4 0	2,983 0	0.3 0.0		0.2 0.0		2,173 0	-	-	746	0.067		0.062		543	-	-
Freezer Exchange	0			ő	ő	ő	0.0		0.0		0	-	-	ő	-		-		-	-	-
T-4-I N Fffi-i M	73					35,554								487							
Total Non-Efficiency Measures Misc Ins,Attic Access/Vent	6					35,554 419								70							
Duct Sealing	0					0								0							
Duct Insulation	1					174								174							
Damming Material Htg. Sys. Tune & Clean	0 6					0 580								97							
Htg. Sys./WH Other	0					0								0							
Air Conditioning Work	0					0								0							
Water Heater Repair Refrigerator Coil Clean	0					0								0							
Waterbed Mattress Pad	0					0								0							
Programmable Tstat	0					0								0							
Unspecified Utility Meas.	0					0								0							
CO Detector Smoke Detector	0					0								0							
Fuses	ő					0								ő							
Htg Sys Safety Check	0					0								0							
Htg Sys Ventilation Water Heater Ventilation	26 17					4,781 2,665								184 157							
Bathroom Ventilation	0					2,003								0							
Dryer Ventilation	0					0								0							
Kitchen Ventilation	0					0								0							
Other Exhaust Ventilation Asbestos Removal (Minor)	0					0								0							
Health/Safety Repairs	1					111								111							
Health/Safety Other	0					0								0							
Consumables General Repairs	0 44					0 8,683								0 197							
General Repairs Meter Refrig (no action)	0					8,683								197							
Meter Freezer (no action)	0					0	L							0							
Support	72		-	-	-	18,141								252							
Transportation Allowance Landlord Contr Misc	0					0								0							
Landlord Contr Misc	0					0								0							
Landlord Contr DHW	0					0								0							
Client Contr (Any) Lead Safe Work	0					0								0							
Unspecifed/Other	0					0								0							

¹Estimates are based upon reduced usage of the furnace due to shell improvements

² Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Total Reported Labor, Materials and Utility Admin Expenditures: \$121,974

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$121,974

	II								Billing A	djusted F	irst-Year S	avings		Averaç	ge Billing					nd Savin	gs
		r of Dwel			of Dwellings tricity Impacts	Spending on			Electricity			I	Gas	Spending on	per Dw	eiiing	Receivin Electricity		sures		ias
Measure	Total	Electric	Gas	Seas Cooling		Materials & Labor (\$)	Sum kW	mer kWh	Wii kW	nter kWh	Annual kWh	Pk-Day therms	Annual therms	Materials & Labor (\$)	Sumn kW	ner kWh	Wint kW	er kWh		Pk-Day therms	Annual therms
Total Efficiency Measures	29	26	24	26	26	97,662	4.4		4.8		22,638	45	4,375	3,368	0.168		0.184		871	1.89	182
Total Shell & Htg. Sys. Repl	27	25	23	20	25	71,132	2.6	3,168	2.1	3,176	6,344	43	3,961	2,635	0.131	158	0.082	127	254	1.87	172
Total Shell Measures	27	25	23	20	25	35,319	2.6	3,168	2.1	3,176	6,344	25	2,260	1,308	0.131	158	0.082	127	254	1.07	98
Wall Insul.	10	6	8	6	1	6,918	0.7	855	0.7	1,103	1,958	5	446	692	0.118	142	0.716	1,103	326	0.61	56
Open Blown Ceiling Insul. Cavity Fill Insul.	18 6	14 2	15 6	14 2	1 0	8,620 3,686	1.3 0.1	1,564 98	1.2 0.0	1,832 0	3,396 98	8 5	740 464	479 614	0.093 0.041	112 49	1.189 0.000	1,832 0	243 49	0.54 0.84	49 77
Sloped Attic Insul.	6	4	6	4	0	3,501	0.1	251	0.0	0	251	3	299	583	0.052	63	0.000	0	63	0.54	50
Kneewall Insul.	6	3	6	3	Ō	763	0.0	60	0.0	0	60	1	49	127	0.017	20	0.000	ō	20	0.09	8
Infil. Reduction	22	20	2	20	1	5,972	0.3	341	0.0	9	350	0	19	271	0.014	17	0.006	9	17	0.10	9
Found./Crawl. Insul.	9	0	9	0	0	5,519	0.0	0	0.0	0	0	2	212	613	-	-	-	-	-	0.26	24
Bandjoist Insul.	2	0	2	-	0	340	0.0	0	0.0	0	0	0	36	170	-	-	-	-	-	0.20	18
Furnace Blower Fan ¹	26	24	23		24	0	0.0	0	0.2	232	232	(0)	(5)	0	0.000	0	0.006	10	10	(0.00)	(0)
Exhaust Ventilation	0	0	0	- 0	0	0	0.0	0	0.0	0	0	0	1 701	0		-	-	-	-	1 22	113
Total Heating System Repl Condensing Htg Sys Repl	15 15	0	15 15	- :	-	35,812 35,812	0.0	0	0.0	0	0	19 19	1,701 1,701	2,387 2,387	<u> </u>				<u> </u>	1.23	113
Non-Cond Htg Sys Repl	0	0	0	-	-	0,012	0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	-
Electric Htg Sys Repl	0	0	0	-	0	0	0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	-
Heat Pump Repl	0	0	0	-	0	0	0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	-
Other Htg Sys Repl	0	0	0	-	0	0	0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	-
				Num	per of Measures																
	Total	Electric	Gas	by Total	Fuel Type Electric Gas		Summer kW		Winter kW		Annual kWh	Pk-Day therms	Annual therms		Summer kW		Winter kW		Annual kWh	Pk-Day therms	Annual therms
Water Heating	26	8	18	35	9 26		0.0		0.0		503	2.4	414	643	0.000		0.001		63	0.132	23
Temp. Reduct.	0	0	0	0	0 0	0	0.0		0.0		0	0.0	0	0	-		-		-	-	-
WH Wrap Pipe Insul.	0 24	0 7	0 17	0 24	0 0 7 17	0 444	0.0 0.0		0.0 0.0		0 310	0.0 0.1	0 52	0 18	0.000		0.000		- 44	0.01	- 3
LF Showerhead	0	0	0	0	0 0	0	0.0		0.0		0	0.0	0	10	0.000		0.000		- 44	0.01	-
Faucet Aerator	0	0	0	0	0 0	0	0.0		0.0		0	0.0	0	ő	-		-		-	-	-
Std-Eff Wtr Htr Repl.	0	0	0	0	0 0	0	0.0		0.0		0	0.0	0	0	-		-		-	-	-
Hi-Eff or Electric Wtr Htr Repl.	12	2	10	11	2 9	16,270	0.0		0.0		193	2.2	362	1,356	0.000		0.002		96	0.22	36
Lighting	23	23		260	260	1,743	1.2		2.2		11,263	-	-	76	0.051		0.095		490	-	-
Refrigerator/Freezer ³	10	10		9	9	8,074	0.6		0.5		4,528	-	-	807	0.056		0.052		453	-	-
Refrigerator Removal Refrigerator Exchange	0 10	0 10		0 9	0 9	0 8,074	0.0 0.6		0.0 0.5		0 4,528	-	-	0 807	0.056		0.052		453	-	-
Freezer Removal	0	0		0	0	0,074	0.0		0.0		4,320			007	-		-		-		
Freezer Exchange	0	0		0	0	0	0.0		0.0		0	-	-	0	-		-		-	-	-
Total Non-Efficiency Measures	29					24,312								838							
Misc Ins,Attic Access/Vent	18					2,257								125							
Duct Sealing Duct Insulation	0					0								0							
Duct insulation Damming Material	0					0								0							
Htg. Sys. Tune & Clean	6					523								87							
Htg. Sys./WH Other	0					0								0							
Air Conditioning Work	0					0								0							
Water Heater Repair Refrigerator Coil Clean	0					0								0							
Waterbed Mattress Pad	0					0								0							
Programmable Tstat	0					0								0							
Unspecified Utility Meas.	0					0								ő							
CO Detector	0					0								0							
Smoke Detector	0					0								0							
Fuses Htg Sys Safety Check	0					0								0							
Htg Sys Salety Check	19					4,425								233							
Water Heater Ventilation	10					3,089								309							
Bathroom Ventilation	0					0								0							
Dryer Ventilation	0					0								0							
Kitchen Ventilation Other Exhaust Ventilation	0					0								0							
Asbestos Removal (Minor)	0					0								0							
Health/Safety Repairs	1					55								55							
Health/Safety Other	0				<u></u>	0								0							
Consumables	0					0								0							
General Repairs	18					3,166								176							
Meter Refrig (no action) Meter Freezer (no action)	0					0								0							
Support (no action)	29					10,797								372							
Transportation Allowance	0					0								0							
Landlord Contr Misc	0					0								0							
Landlord Contr Furnace	0					0								0							
Landlord Contr DHW Client Contr (Any)	0					0								0							
Lead Safe Work	0					0								0							
Unspecifed/Other	0					0															
						·															

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

² Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

The total number of dwellings may exceed the number of neasures installed in cases where the utility partially funds refigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$299,948

	Numbe	er of Dwe	llinas	Number	of Dwellings			ı	Billing A	Adjusted F	irst-Year S	avings		Averag			ted First			nd Savin	gs
		with Impac			ricity Impacts	Spending on		E	lectricity			1	Gas	Spending on	P		Electricit			G	as
Measure	Total	Electric	Gas	Seas	on	Materials & Labor (\$)	Sum kW	mer kWh	Wi kW	inter kWh	Annual kWh	Pk-Day therms	Annual therms	Materials & Labor (\$)	Sum: kW	mer kWh	Win kW	ter kWh	Annual kWh	Pk-Day therms	Annual therms
				Cooling				KVVII		KVVII						KVVN		KVVN			
Total Efficiency Measures	54	52	48	52	52	246,912	10.3		8.5		29,397	109	10,744	4,572	0.198		0.163		565	2.26	224
Total Shell & Htg. Sys. Repl	54	52	48	44	52	194,393	9.9	11,884	7.8	12,244	24,128	101	9,423	3,600	0.224	270	0.151	235	464	2.11	196
Total Shell Measures	54	52	48	44	52	136,574	9.9	11,884	7.8	12,194	24,078	70	6,498	2,529	0.224	270	0.150	235	463	1.45	135
Wall Insul.	41	34	39	34	0	60,932	4.1	4,927	0.0	0	4,927	32	3,011	1,486	0.120	145	0.000	0	145	0.83	77
Open Blown Ceiling Insul.	50	43	45	42	3	26,631	3.5	4,264	2.6	4,090	8,354	17	1,600	533	0.084	102	0.873	1,363	194	0.38	36
Cavity Fill Insul.	19			16	1	13,538	0.8	982	0.4	669	1,651	8	725	713	0.051	61	0.429	669	103	0.46	43
Sloped Attic Insul.	20	15		15	1	6,492	0.5	645	0.4	634	1,279	5	465	325	0.036	43	0.406	634	85	0.26	24
Kneewall Insul.	14	11	12	11	1	2,711	0.2	238	0.1	103	341	2	161	194	0.018	22	0.066	103	31	0.14	13
Infil. Reduction	52 10	45	47	44	3	18,402	0.5	629	0.1 0.2	134	762	4	375	354	0.012	14 66	0.029	45	17	0.09	8
Found./Crawl. Insul.			8	3	1	5,286	0.2	199		353	552	1	76	529	0.055		0.226	353	184	0.10	9
Bandjoist Insul.	32	2		-	2	2,582	0.0	0	0.3	397	397	1	108	81	0.000	0	0.127	199	199	0.04	4
Furnace Blower Fan	51	49		-	49	0	0.0	0	3.7	5,815	5,815	(0)			0.000	0	0.076	119	119	(0.00)	(0)
Exhaust Ventilation	0	0	0	0	0	0	0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	-
Total Heating System Repl	29	1	28	-	1	57,819	0.0	0	0.0	50	50		2,925	1,994	0.000	0	0.032	50	50	1.12	104
Condensing Htg Sys Repl	28	0	28	-	-	54,319	0.0	0	0.0	0	0	31	2,925	1,940	-	-	-	-	-	1.12	104
Non-Cond Htg Sys Repl	0	0		-	- ,	0	0.0	0	0.0	0	0	0	0	0 500	- 0.000	- 0	- 0.000	-	-	-	-
Electric Htg Sys Repl	1	1	0	-	1	3,500	0.0	0	0.0	50	50	0	0	3,500	0.000	0	0.032	50	50	-	-
Heat Pump Repl	0	0	0	-	0	0	0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	-
Other Htg Sys Repl	0	0	0	-	U	0	0.0	U	0.0	U	0	U	0	0	-	-		-		-	
					er of Measures																
	Total	Electric	Gas	Total	Fuel Type Electric Gas		Summer kW		Winter kW		Annual kWh	Pk-Day therms	Annual therms		Summer kW		Winter kW		Annual kWh	therms	Annual therms
Water Heating	51	9	42	105	16 89		0.0		0.0		1,473	7.4	1,322	956	0.000		0.003		164	0.177	31
Temp. Reduct.	0	0	0	0	0 0		0.0		0.0		0	0.0	0	0	-		-		-	-	-
WH Wrap	0	0		0	0 0		0.0		0.0			0.0	0	0	-		-				
Pipe Insul.	51	9	42	51	9 42		0.0		0.0		417	0.3	120	19	0.000		0.000		46	0.01	3
LF Showerhead Faucet Aerator	16 2	2	14 2	17 2	2 15 0 2	170 10	0.0		0.0		393 0	0.3	97 3	11	0.000		0.004		197	0.02	7 1
Std-Eff Wtr Htr Repl.	0	0	0	0	0 0	0	0.0		0.0		0	0.0	0	5 0	-		-		-	0.00	1
Hi-Eff or Electric Wtr Htr Repl.	36	5	31	35	5 30	47,588	0.0		0.0		662	6.8	1,103	1,322	0.000		0.003		132	0.22	36
Lighting	31	31	31	121	121	847	0.0		0.4		1,830	0.0	- 1,103	27	0.006		0.003		59	0.22	-
Refrigerator/Freezer ³	4			4	4	2,925	0.2		0.2		1,966	-	-	731	0.060		0.057		491		-
Refrigerator Removal	0	0		0	0	2,320	0.0		0.0		1,500	-	-	0	-		-		-	-	
Refrigerator Exchange	4	4		4	4	2,925	0.2		0.2		1,966	-	-	731	0.060		0.057		491	-	-
Freezer Removal	0	0		0	0	0	0.0		0.0		0	-	-	0	-		-		-	-	-
Freezer Exchange	0	0		0	0	0	0.0		0.0		0	-	-	0	-		-		-	-	
Total Non-Efficiency Measures	65					53,036								816							
Misc Ins,Attic Access/Vent	39					4,280								110							
Duct Sealing	0					0								0							
Duct Insulation	0					0								0							
Damming Material	0					0								0							
Htg. Sys. Tune & Clean	11					597								54							
Htg. Sys./WH Other	0					0								0							
Air Conditioning Work	0					0								0							
Water Heater Repair	0					0								0							
Refrigerator Coil Clean	0					0								0							
Waterbed Mattress Pad	0					0								0 97							
Programmable Tstat Unspecified Utility Meas.	10 0					970 0								97							
CO Detector	0					0								0							
Smoke Detector	0					0								0							
Fuses	0					0								0							
Htg Sys Safety Check	ő					ő								ő							
Htg Sys Ventilation	33					5,898								179							
Water Heater Ventilation	35					4,616								132							
Bathroom Ventilation	0					0								0							
Dryer Ventilation	0					0								0							
Kitchen Ventilation	0					0								0							
Other Exhaust Ventilation	0					0								0							
Asbestos Removal (Minor)	0					0	1							0							
Health/Safety Repairs	20					849								42							
Health/Safety Other	0					0								0							
Consumables General Repairs	0 53					9,486								0 179							
General Repairs Meter Refrig (no action)	53					9,486								1/9							
Meter Freezer (no action)	50					0								0							
Support (110 action)	52					26,340	-							507							
Transportation Allowance	0					20,340								0							
Landlord Contr Misc	0					ő								ő							
Landlord Contr Furnace	0					ő								ő							
Landlord Contr DHW	0					0								0							
Client Contr (Any)	0					0								0							
Lead Safe Work	0				-	0								0							
Unspecifed/Other	0					0	1							0							

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

² Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

The total number of dwellings may exceed the number of measures installed in cases where the tillity partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$199,130

	Numbe	r of Dwe	llings	Number	of Dwellings				Billing A	Adjusted F	irst-Year S	avings		Averaç			ted First Receivin			nd Savin	gs
		with Impac		with Elect	ricity Impacts	Spending on			Electricity				Gas	Spending on	-	_	Electricity	ī			ias
Measure	Total	Electric	Gas	Seaso Cooling		Materials & Labor (\$)	Sum kW	mer kWh	kW	inter kWh	Annual kWh	Pk-Day therms	Annual therms	Materials & Labor (\$)	Sumr kW	ner kWh	Wint kW		Annual kWh	Pk-Day therms	Annual therms
Total Efficiency Measures	29	23	27	23	23	160,214	4.1		1.7		10,452	56	5,545	5,525	0.180		0.075		454	2.09	205
Total Shell & Htg. Sys. Repl	29	23	27	23	23	127,457	3.7	4,465	1.0	1,600	6,065	53	4,924	4,395	0.161	194	0.045	70	264	1.96	182
Total Shell Measures	29	23	27	23	23	77,334	3.7	4,465	1.0	1,600	6,065	31	2,845	2,667	0.161	194	0.045	70	264 148	1.13	105
Wall Insul. Open Blown Ceiling Insul.	9 28	6 22	9 25	6 22	0	20,496 23,015	0.7 1.5	890 1,841	0.0	0	890 1,841	8 7	730 676	2,277 822	0.123	148 84	0.000	0	148 84	0.87 0.29	81 27
Cavity Fill Insul.	6	4	6	4	0	6.222	0.3	329	0.0	0	329	4	375	1,037	0.068	82	0.000	0	82	0.67	63
Sloped Attic Insul.	12	9	11	9	0	5,427	0.5	625	0.0	0	625	5	478	452	0.058	69	0.000	0	69	0.47	43
Kneewall Insul.	13	8	12	8	0	4,123	0.3	357	0.0	0	357	2	232	317	0.037	45	0.000	0	45	0.21	19
Infil. Reduction Found /Crawl. Insul.	28 12	20	25 11	20 4	0	12,151	0.1 0.2	173	0.0	0	173	2	219 95	434 356	0.007	9 63	0.000	0	9 63	0.09	9
Bandjoist Insul.	13		13	4	0	4,275 1,625	0.2	251 0	0.0	0	251 0	1	95 47	125	0.052	- 63	0.000	- 0	- 63	0.09	4
Furnace Blower Fan ¹	29		27		23	0	0.0	0	1.0	1,600	1,600	(0)			0.000	0	0.045	70	70	(0.00)	(0)
Exhaust Ventilation	0	0	0	0	0	0	0.0	0	0.0	0,000	0,000	0	0	0	0.000		0.040	70	70	(0.00)	(0)
Total Heating System Repl	20	0	20	-	0	50,123	0.0	0	0.0	0	0		2,079	2,506				-	-	1.12	104
Condensing Htg Sys Repl	20	0	20	-	-	50,123	0.0	0	0.0	0	0	22	2,079	2,506	-	-	-	-	-	1.12	104
Non-Cond Htg Sys Repl	0	0	0	-	-	0	0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	-
Electric Htg Sys Repl	0	0	0	-	0	0	0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	-
Heat Pump Repl Other Htg Sys Repl	0	0	0		0	0	0.0	0	0.0	0	0	0	0	0			-			-	
Other ring dys reepi		0				Ů	0.0		0.0	•		-		Ů							
				by	er of Measures Fuel Type		Summer		Winter		Annual	Pk-Day	Annual		Summer		Winter	,	Annual	Pk-Day	Annual
Water Heating	Total	Electric	Gas	Total 40	Electric Gas	20.070	kW		kW		kWh	therms	therms	1.405	kW		kW		kWh 341	therms	therms
Water Heating Temp. Reduct.	25 0	0	24	40	3 38		0.0		0.0		341	3.6 0.0	621	1,195	0.000		0.007		341	0.150	26
WH Wrap	0		0	0	0 0		0.0		0.0		0	0.0	0	ő	-		-		-	-	-
Pipe Insul.	23	1	22	23	1 22		0.0		0.0		43	0.2	63	10	0.000		0.000		43	0.01	3
LF Showerhead	1	1	0	1	1 0	10	0.0		0.0		175	0.0	0	10	0.000		0.004		175	-	-
Faucet Aerator Std-Eff Wtr Htr Repl.	0	0	0	0	0 0	0	0.0 0.0		0.0		0	0.0	0	0	-		-		-	-	-
Hi-Eff or Electric Wtr Htr Repl.	20	1	19	16	1 16		0.0		0.0		124	3.4	558	1,482	0.000		0.003		124	0.18	29
Lighting	21	21		191	191	1,377	0.3		0.6		3,022	-	-	66	0.015		0.028		144	-	-
Refrigerator/Freezer ³	2	2		2	2	1,508	0.1		0.1		1,023	-	-	754	0.063		0.059		512	-	-
Refrigerator Removal	0	0		0	0	0	0.0		0.0		0	-	-	_0	-		-		-	-	-
Refrigerator Exchange Freezer Removal	2	2		2	2	1,508	0.1 0.0		0.1 0.0		1,023 0	-	-	754 0	0.063		0.059		512	-	-
Freezer Exchange	0	0		0	0	0	0.0		0.0		0			0					-	-	-
Total Non-Efficiency Measures Misc Ins, Attic Access/Vent	29 14					38,917 2,208								1,342 158							
Duct Sealing	0					2,200								0							
Duct Insulation	0					0								ō							
Damming Material	0					0								0							
Htg. Sys. Tune & Clean	3					375								125							
Htg. Sys./WH Other Air Conditioning Work	0					0								0							
Water Heater Repair	0					ő								ő							
Refrigerator Coil Clean	0					0								0							
Waterbed Mattress Pad	0					0								0							
Programmable Tstat Unspecified Utility Meas.	0					0								0							
CO Detector	0					0								0							
Smoke Detector	0					0								0							
Fuses	0					0								0							
Htg Sys Safety Check Htg Sys Ventilation	0 20					0 4,143								0 207							
Water Heater Ventilation	18					3,296								183							
Bathroom Ventilation	0					0,230								0							
Dryer Ventilation	0					0								0							
Kitchen Ventilation	0					0								0							
Other Exhaust Ventilation Asbestos Removal (Minor)	0					0								0							
Health/Safety Repairs	20					29,632								1,482							
Health/Safety Other	0					0								0							
Consumables	0					0								0							
General Repairs	26					9,147								352							
Meter Refrig (no action)	9					0								0							
Meter Freezer (no action) Support	28					19,748								705							
Transportation Allowance	0					0								0							
Landlord Contr Misc	0					0								0							
Landlord Contr Furnace	0					0								0							
Landlord Contr DHW Client Contr (Any)	0					0								0							
Lead Safe Work	0					0								0							
Unspecifed/Other	0					0								0							

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

² Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

³ The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Total Reported Labor, Materials and Utility Admin Expenditures: \$120,050

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$120,050

		er of Dwe			r of Dwellings					djusted Fi	irst-Year S						sted First Receivin	g Meas			
		with Impac		Seas		Spending on Materials	Sum	mer	Electricity Wii		Annual	Pk-Day	Gas Annual	Spending on Materials	Sum		Electricity Wint	er		G Pk-Day	Annual
Measure	Total	Electric	Gas	Cooling	Heating	& Labor (\$)	kW	kWh	kW	kWh	kWh	therms	therms	& Labor (\$)	kW	kWh	kW	kWh	kWh	therms	therms
Total Efficiency Measures	22	18	15	18	18	97,230	3.9		6.0		17,432	31	2,785	4,420	0.218		0.332		968	2.04	186
Total Shell & Htg. Sys. Repl	22	18	15	18	18	83,107	3.5	4,206	5.4	7,960	12,167	30	2,615	3,778	0.194	234	0.300	442	676	1.98	174
Total Shell Measures Wall Insul.	22 8		15 6	18	<u>17</u>	41,312 12,191	3.5 0.8	4,206 956	5.3 0.1	7,883 124	12,090	17	1,476 666	1,878 1,524	0.194	234 191	0.314	464 124	672 216	1.12	98
Open Blown Ceiling Insul.	17		10	14	4	14,024	2.1	2,578	2.8	4,162	6,740	4	380	825	0.153	184	0.706	1,040	481	0.43	38
Cavity Fill Insul.	2		1	2	1	390	0.0	38	0.1	140	178	0	8	195	0.016	19	0.095	140	89	0.10	8
Sloped Attic Insul. Kneewall Insul	5	2	4	2	1	2,936 138	0.1	111 0	0.6	860 0	971 0	2	183 0	587	0.046	55	0.583	860	485	0.52	46 0
Infil. Reduction	22		15	18	0 4	8,060	0.0 0.2	245	0.0	1,182	1,428	0 2	144	138 366	0.011	14	0.200	296	- 79	0.00 0.11	10
Found./Crawl. Insul.	8		5	3	1	2,808	0.2	279	0.3	386	664	0	40	351	0.077	93	0.262	386	221	0.09	8
Bandjoist Insul.	6	1	5	-	1	767	0.0	0	0.1	106	106	1	59	128	0.000	0	0.072	106	106	0.13	12
Furnace Blower Fan ¹	17	13	15	-	13	0	0.0	0	0.6	923	923	(0)	(5)	0	0.000	0	0.048	71	71	(0.00)	(0)
Exhaust Ventilation	0	0	0	0	0	0	0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	-
Total Heating System Repl	13 11	0	11 11	-	2	41,795 34,795	0.0	0	0.1	77	77	13	1,140		0.000	0	0.026	39	39	1.18	104
Condensing Htg Sys Repl Non-Cond Htg Sys Repl	0		0		-	34,793	0.0 0.0	0	0.0	0	0	13 0	1,140 0	3,163						1.18	104
Electric Htg Sys Repl	0	0	0	-	0	0	0.0	0	0.0	0	0	0	0	Ō	-	-	-	-	-	-	-
Heat Pump Repl	2		0	-	2	7,000	0.0	0	0.1	77	77	0	0	3,500	0.000	0	0.026	39	39	-	-
Other Htg Sys Repl	0	0	0	-	0	0	0.0	0	0.0	0	0	0	0	0	-	-		-	-	-	
				Num	ber of Measures																
	T-4-1	F14-1-	0		y Fuel Type		Summer		Winter		Annual	Pk-Day	Annual		Summer		Winter		Annual		Annual
Water Heating	Total 16	Electric 7	Gas 9		Electric Gas	11.689	kW		kW		kWh 1,547	therms 0.9	therms 170	731	kW 0.000		kW 0.004		kWh 221	0.104	therms 19
Temp. Reduct.	0	0	0	0	0 0	0	0.0		0.0		0	0.0	0	0	-		-		-	-	-
WH Wrap	0		0	0	0 0	0	0.0		0.0		0	0.0	.0	0	-		-			-	
Pipe Insul. LF Showerhead	11 7	5 5	6	11 7	5 6 5 2		0.0		0.0		246 1,004	0.0	17 14	10 8	0.000		0.000		49 201	0.01 0.02	3 7
Faucet Aerator	6	5	1	7	5 2	31	0.0		0.0		189	0.0	3	5	0.000		0.003		38	0.02	3
Std-Eff Wtr Htr Repl.	ō		0	0	0 0		0.0		0.0		0	0.0	Ō	0	-		-		-	-	
Hi-Eff or Electric Wtr Htr Repl.	8	1	7	5	1 5	11,500	0.0		0.0		108	0.8	136	1,438	0.000		0.003		108	0.12	19
Lighting	13			103	103	309	0.2		0.3		1,558	-	-	24	0.013		0.023		120	-	-
Refrigerator/Freezer ³ Refrigerator Removal	3	0		0	0	2,125	0.3		0.2		2,161	-	-	708 0	0.089		0.083		720		-
Refrigerator Exchange	2			2	2	1,475	0.2		0.1		1,276	_	-	738	0.078		0.073		638	-	-
Freezer Removal	0	0		0	0	0	0.0		0.0		0	-	-	0	-					-	-
Freezer Exchange	1	1		2	2	650	0.1		0.1		885	-	-	650	0.109		0.102		885	-	
Total Non-Efficiency Measures	22					22,820								1,037							
Misc Ins,Attic Access/Vent	5					519								104							
Duct Sealing Duct Insulation	1 6					320 329								320 55							
Damming Material	0					0								0							
Htg. Sys. Tune & Clean	7					875								125							
Htg. Sys./WH Other	0					0								0							
Air Conditioning Work Water Heater Repair	0					0								0							
Refrigerator Coil Clean	ő					0								Ö							
Waterbed Mattress Pad	0					0								0							
Programmable Tstat	0					0								0							
Unspecified Utility Meas. CO Detector	0					0								0							
Smoke Detector	Ö					0								ō							
Fuses	0					0								0							
Htg Sys Safety Check Htg Sys Ventilation	0 10					0 2,500								0 250							
Water Heater Ventilation	7					1,450								207							
Bathroom Ventilation	0					0								0							
Dryer Ventilation	0					0								0							
Kitchen Ventilation Other Exhaust Ventilation	0					0								0							
Asbestos Removal (Minor)	ő					0								Ö							
Health/Safety Repairs	3					136								45							
Health/Safety Other Consumables	0					0								0							
Consumables General Repairs	21					6,009								286							
Meter Refrig (no action)	14					0								0							
Meter Freezer (no action)	8					0								0							
Support Transportation Allowance	19 0					10,682 0								562 0							
Landlord Contr Misc	0					0								0							
Landlord Contr Furnace	0					0								0							
Landlord Contr DHW	0					0								0							
Client Contr (Any) Lead Safe Work	0					0								0							
Unspecifed/Other	0					0								0							

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

² Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$351,375

	Numbe	er of Dwe	llings	Number	of Dwellings			E	Billing A	djusted Fi	irst-Year S	avings		Averag			ted First \			nd Savin	gs
	v	with Impac	ts	with Elec Seas	tricity Impacts	Spending on Materials	Sum	ımer	lectricity Wir		Annual	Pk-Day	Gas Annual	Spending on Materials	Sumr	ner	Electricity Winte	r	Annual	Pk-Day	ias Annual
Measure	Total	Electric	Gas	Cooling	Heating	& Labor (\$)	kW	kWh	kW	kWh	kWh	therms	therms	& Labor (\$)	kW	kWh	kW	kWh	kWh	therms	therms
Total Efficiency Measures	55	53	43	52	53	311,956	18.6		4.5		34,967	143	12,622	5,672	0.357		0.085		660	3.33	294
Total Shell & Htg. Sys. Repl	55	53	43	52	53	260,634	17.5	21,106	2.9	4,059	25,165	136	11,440	4,739	0.337	406	0.054	77	475	3.16	266
Total Shell Measures	55	53	43	52	53	167,201	17.5	21,106	2.9	4,059	25,165	88	7,439	3,040	0.337	406	0.054	77	475	2.05	173
Wall Insul.	44	42 48	35	42	0							36	3,042	1,494	0.179	216	0.000	0	216 149	1.03	87 61
Open Blown Ceiling Insul. Cavity Fill Insul.	49 17	14	38 16	48 14	0			1,132				28 8	2,336 648	767 838	0.123 0.076	149 92	0.000	0	92	0.73 0.48	41
Sloped Attic Insul.	22	22	19	22	0		9,523							433	0.053	63	0.000	0	63	0.46	30
Kneewall Insul.	18		16	18	0		37,574 5.9 7,132 0.0 0 7,132 2 14,245 1.1 1,283 0.0 0 1,283 9,523 1.2 1,395 0.0 0 1,395 8,175 0.4 473 0.0 0 444 14,976 1.1 1,323 0.0 0 1,323 548 0.0 0 0.0 0 0 0 0.0 0 0.0 0 0 0 0 0.0 0 0.0 0 0 0 0 33,433 0.0 0 0.0 0 0 0 0 0.0 0 0.0 0 0 0 0 0 0.0 0 0.0 0 0 0							454	0.022	26	0.000	Ö	26	0.15	12
Infil. Reduction	46	45	33	45	0		14,245							357	0.008	10	0.000	0	10	0.07	6
Found./Crawl. Insul.	30	14	27	14	0			1,323			1,323	5	452	499	0.078	95	0.000	0	95	0.20	17
Bandjoist Insul.	3		3	-	0					-	•	0	18	183	-	-	-	-	-	0.07	6
Furnace Blower Fan ¹	55	53	43	-	53	0	0.0	0	2.9	4,059	4,059	(0)	(14)	0	0.000	0	0.054	77	77	(0.00)	(0)
Exhaust Ventilation	0	0	0	0	0		0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	
Total Heating System Repl	34		34	-	0							48	4,001		-	-	-	-	-	1.40	118
Condensing Htg Sys Repl	34	0	34	-	-							48	4,001	2,748	-	-	-	-	-	1.40	118
Non-Cond Htg Sys Repl Electric Htg Sys Repl	0		0	-	0							0	0	0	-	-	-	-	-	-	-
Heat Pump Repl	0	0	0		0							0	0	0		-	-	-	-		
Other Htg Sys Repl	0	0	0		0							0	0	0				-	-		
	Ī					Ĭ		-													
					er of Measures Fuel Type		Summer		Winter		Annual	Pk-Day	Annual		Summer		Winter		Annual	Pk-Day	Annual
	Total	Electric	Gas	Total	Electric Gas		kW		kW		kWh	therms	therms		kW		kW		kWh	therms	therms
Water Heating	36	1	35	37	1 36							7.2	1,182	1,306	0.000		0.000		43	0.206	34
Temp. Reduct. WH Wrap	0	0	0	0	0 0						-	0.0	0	0	-		-		-	-	-
Pipe Insul.	0 5		4	5	0 0								11	0	0.000		0.000		43	0.01	- 3
LF Showerhead	0	0	0	0	0 0							0.0	0	0	0.000		0.000		43	0.01	-
Faucet Aerator	0	0	0	ő	0 0							0.0	Ö	ő	-		-		-	-	_
Std-Eff Wtr Htr Repl.	0	0	0	0	0 0						0	0.0	0	0	-		-		-	-	-
Hi-Eff or Electric Wtr Htr Repl.	34	0	34	32	0 32						0	7.2	1,171	1,382	-		-		-	0.21	34
Lighting	28			308	308		-					-	-	24	0.025		0.046		238	-	-
Refrigerator/Freezer ³	6	6		6	6							-	-	607	0.063		0.059		515	-	-
Refrigerator Removal	0	0 5		0	0							-	-	0	0.063		- 0.050		-	-	-
Refrigerator Exchange Freezer Removal	5 0			5 0	5 0							-	-	683 0	0.063		0.059		509	-	-
Freezer Exchange	1	1		1	1	225						-	-	225	0.067		0.063		545	-	
Total Non-Efficiency Measures	55					20 449	ı							717							
Misc Ins,Attic Access/Vent	1													16							
Duct Sealing	0													0							
Duct Insulation	0													0							
Damming Material	0													0							
Htg. Sys. Tune & Clean	7													139							
Htg. Sys./WH Other	0													0							
Air Conditioning Work	0					0								0							
Water Heater Repair Refrigerator Coil Clean	0					0								0							
Waterbed Mattress Pad	0					0								ő							
Programmable Tstat	Ö					0								ő							
Unspecified Utility Meas.	0					0								0							
CO Detector	0				·	0			· <u>-</u>		·			0							
Smoke Detector Fuses	0					0								0							
Htg Sys Safety Check	0					0								0							
Htg Sys Salety Check	26					4,293								165							
Water Heater Ventilation	21					3,145								150							
Bathroom Ventilation	0					0								0							
Dryer Ventilation	0					0								0							
Kitchen Ventilation	0					0								0							
Other Exhaust Ventilation	0					0								0							
Asbestos Removal (Minor)	0					0								0							
Health/Safety Repairs Health/Safety Other	0					63 0								63 0							
Consumables	0					0								0							
General Repairs	5					1,532								306							
Meter Refrig (no action)	0					0								0							
Meter Freezer (no action)	0					0								0							
Support	54			·		29,396								544							
Transportation Allowance	0					0								0							
Landlord Contr Misc Landlord Contr Furnace	0					0								0							
Landlord Contr Furnace Landlord Contr DHW	0					0								0							
Client Contr (Any)	0					ő								ő							
Lead Safe Work	0					0								0							
Unspecifed/Other	0					0								0							

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

² Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refligeration measure regiscements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$241,136

	Numbe	r of Dw	allinge	Number	of Dwellings				Billing A	djusted F	irst-Year S	avings		Averaç	ge Billing per Dw		ted First			nd Savin	gs
		vith Impa			ricity Impacts	Spending on Materials	Sum		Electricity	ntor	Annual	Pk-Day	Gas	Spending on Materials	Sumn	·	Electricity Wint	ĭ		Pk-Day	as Annual
Measure	Total	Electric	Gas	Cooling		& Labor (\$)	kW	kWh	kW	nter kWh	kWh	therms	Annual therms	& Labor (\$)	kW	kWh	kW	kWh	kWh	therms	therms
Total Efficiency Measures	67	67	32	67	67	186,274	15.4		17.4		56,863	63	5,731	2,780	0.230		0.260		849	1.96	179
Total Shell & Htg. Sys. Repl	65	65			64	147,705	13.6	16,433	14.3	21,032	37,465	60	5,283	2,272	0.216	261	0.223	329	576	1.94	170
Total Shell Measures Wall Insul	65 31	65 31			64 3	86,547 21,430	13.6 4.9	16,433 5,884	14.0 3.6	20,658 5,242	37,091 11,126	35 9	3,050 808	1,331 691	0.216 0.157	261 190	0.219 1.185	323 1,747	571 359	1.12 0.57	98 50
Open Blown Ceiling Insul.	45	45			5	32,013	6.1	7,310	5.7	5,242 8,368	15,678	17	1,535	711	0.137	166	1.135	1,747	348	0.57	67
Cavity Fill Insul.	6				Ö	2,015	0.2	276	0.0	0,000	276	1	72	336	0.046	55	0.000	0	55	0.41	36
Sloped Attic Insul.	8	8			0	1,882	0.4	486	0.0	0	486	1	122	235	0.050	61	0.000	0	61	0.35	31
Kneewall Insul.	4	- 4		4	0	931	0.2	183	0.0	700	183	1	65	233	0.038	46	0.000	0	46	0.25	22
Infil. Reduction Found /Crawl. Insul.	61 34	58 22	29	57 19	7 4	15,722 8,402	0.6 1.3	739 1,554	0.5 1.8	780 2.669	1,519 4,223	2	188 140	258 247	0.011	13 82	0.076 0.452	111 667	26 192	0.07	6
Bandjoist Insul.	23	- 2	3 20		3	4,153	0.0	0	0.3	500	500	1	130	181	0.000	0	0.432	167	167	0.07	6
Furnace Blower Fan ¹	57	57			57	0	0.0	0	2.1	3,099	3,099	(0)	(9)	0	0.000	0	0.037	54	54	(0.00)	(0)
Exhaust Ventilation	0			0	0	0	0.0	0	0.0	0	0	0	0	0	-	_	-	_	_	-	-
Total Heating System Repl	24	2		-	2	61,159	0.0	0	0.3	374	374	25	2,234	2,548	0.000	0	0.127	187	187	1.15	102
Condensing Htg Sys Repl	22	(-	-	56,159	0.0	0	0.0	0	0	25	2,234	2,553	-	-	-	-	-	1.15	102
Non-Cond Htg Sys Repl	0				-	0	0.0	0	0.0	0	0	0	0	0	- 0.000	-	- 0.407	407	407	-	-
Electric Htg Sys Repl Heat Pump Repl	2	2			2 0	5,000 0	0.0	0	0.3 0.0	374 0	374 0	0	0	2,500	0.000	0	0.127	187	187	-	-
Other Htg Sys Repl	ő	Ċ		-	ő	0	0.0	0	0.0	ő	0	ő	0	0	-	-	-	-	-	-	-
				Numb	er of Measures																
		-	_	by	Fuel Type		Summer		Winter		Annual	Pk-Day	Annual		Summer		Winter		Annual		Annual
Water Heating	Total 55	Electric 34		Total 76	Electric Gas 42 34	33,563	kW		kW		kWh 2,529	therms	therms 448	610	kW 0.000		kW 0.001		kWh	0.121	therms 21
Temp. Reduct.	0			0	0 0	0	0.0		0.0		0	0.0	0	0	-		-			-	
WH Wrap	0	(0 0	0	0.0		0.0		0	0.0	0	0	-		-		-	-	-
Pipe Insul. LF Showerhead	55	34			34 21	477	0.0		0.0		1,541	0.2	60	9	0.000		0.000		45	0.01	3
Faucet Aerator	1 1	(1	0 1	6 5	0.0		0.0		0 33	0.0	7 0	6 5	0.000		0.001		- 33	0.02	7
Std-Eff Wtr Htr Repl.	Ö	(0 0	0	0.0		0.0		0	0.0	0	0	-		-		-	-	-
Hi-Eff or Electric Wtr Htr Repl.	25	9			7 12	33,075	0.0		0.0		955	2.3	381	1,323	0.000		0.003		106	0.15	24
Lighting	35			359	359	2,084	1.6		2.9		14,778	-	-	60			0.082		422	-	-
Refrigerator/Freezer ³	4	4		4	4	2,922	0.3		0.2		2,091	-	-	731	0.064		0.060		523	-	-
Refrigerator Removal Refrigerator Exchange	0	(0	0 3	0 2,428	0.0 0.2		0.0 0.2		0 1,546	_	-	809	0.063		0.059		- 515	-	
Freezer Removal	0	Č		0	ő	0	0.0		0.0		0	_	-	0	-		-		-	-	-
Freezer Exchange	1			1	1	494	0.1		0.1		545	-	-	494	0.067		0.063		545	-	
Total Non-Efficiency Measures	68					54,862								807							
Misc Ins,Attic Access/Vent	21					2,446								116							
Duct Sealing Duct Insulation	0					0 58								0 58							
Damming Material	Ö					0								0							
Htg. Sys. Tune & Clean	6					750								125							
Htg. Sys./WH Other	0					0								0							
Air Conditioning Work Water Heater Repair	0					0								0							
Refrigerator Coil Clean	0					0								0							
Waterbed Mattress Pad	ő					0								Ö							
Programmable Tstat	0					0								0							
Unspecified Utility Meas.	0					0								0							
CO Detector Smoke Detector	0					0								0							
Fuses	0					0								0							
Htg Sys Safety Check	0					0								0							
Htg Sys Ventilation	16					2,673								167							
Water Heater Ventilation Bathroom Ventilation	16 0					2,263								141							
Dryer Ventilation	0					0								0							
Kitchen Ventilation	0					0								0							
Other Exhaust Ventilation	0					0								0							
Asbestos Removal (Minor)	0					0								0							
Health/Safety Repairs Health/Safety Other	14 0					1,205								86 0							
Consumables	0					0								0							
General Repairs	55					15,483								282							
Meter Refrig (no action)	0					0								0							
Meter Freezer (no action) Support	63					29,985								476							
Transportation Allowance	0					0								0							
Landlord Contr Misc	0					0								0							
Landlord Contr Furnace	0					0								0							
Landlord Contr DHW Client Contr (Any)	0					0								0							
Lead Safe Work	0					0								0							
Unspecifed/Other	0					0								0							

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

² Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$322,782

	п								Billing A	djusted F	irst-Year S	avings		Averag			sted First			nd Savin	gs
		er of Dwe with Impac			of Dwellings tricity Impacts	Spending on			Electricity			ĺ	Gas	Coording on	per Dv		Receivir Electricit		ures	,	ias
	1 '	with impac	its	Seas		Materials	Sum			nter	Annual	Pk-Day	Annual	Spending on Materials	Sumi		Win		Annual	Pk-Day	Annual
Measure	Total	Electric	Gas	Cooling	Heating	& Labor (\$)	kW	kWh	kW	kWh	kWh	therms	therms	& Labor (\$)	kW	kWh	kW	kWh	kWh	therms	therms
Total Efficiency Measures	60	41	52	41	41	270,124	9.2		8.4		33,795	89	9,206	4,502	0.224		0.204		824	1.71	177
Total Shell & Htg. Sys. Repl	59	41	51	40	41	207,759	7.6	9,210	6.0	9,744	18,955	82	7,946	3,521	0.191	230	0.146	238	462	1.60	156
Total Shell Measures	59	41	51	40	41	128,846	7.6	9,210	6.0	9,744	18,955		4,727		0.191	230	0.146	238	462	0.95	93
Wall Insul.	34	24	31	24	0	53,113	2.9	3,444	0.0	0	3,444	23	2,220	1,562	0.119	144	0.000	0	144	0.74	72
Open Blown Ceiling Insul.	47	35	42	35	1	26,967	3.0	3,670	3.6	5,858	9,528	6	562	574	0.087	105	3.591	5,858	272	0.14	13
Cavity Fill Insul. Sloped Attic Insul.	14 13	8	13 11	8 9	0	8,063 7,211	0.4 0.6	515 750	0.0	0	515 750	6 5	550 510	576 555	0.053	64 83	0.000	0	64 83	0.43 0.48	42 46
Kneewall Insul.	7	4	5	4	0	1,248	0.0	67	0.0	0	67	1	60	178	0.009	17	0.000	0	17	0.40	12
Infil. Reduction	53	31	47	31	1	13,398	0.4	443	0.2	306	749	5	439	253	0.012	14	0.188	306	24	0.10	9
Found./Crawl. Insul.	22	5	18	5	1	11,348	0.3	322	0.1	161	483	2	225	516	0.053	64	0.099	161	97	0.13	13
Bandjoist Insul.	29	1	28	-	1	7,499	0.0	0	0.0	61	61	2	178	259	0.000	0	0.038	61	61	0.07	6
Furnace Blower Fan	58		51	-	40	0	0.0	0	2.1	3,358	3,358	(0)		0	0.000	0	0.051	84	84	(0.00)	(0)
Exhaust Ventilation	0	0	0	0	0	70.043	0.0	0	0.0	0	0	0	0	0		-		-	-	- 4.00	-
Total Heating System Repl Condensing Htg Sys Repl	33	0	33	-	0	78,913 78,913	0.0	0	0.0	0	0	33	3,219 3,219	2,391 2,391					-	1.00	98 98
Non-Cond Htg Sys Repl	0	0	0	_	-	0	0.0	0	0.0	0	0	0	0,213	2,001	-	-		-	-	-	-
Electric Htg Sys Repl	0		0	-	0	0	0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	-
Heat Pump Repl	0	0	0	-	0	0	0.0 0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	-
Other Htg Sys Repl	0	U	U	-	U	0	0.0	U	0.0	U	U	U	U	0				-	-	-	
					er of Measures Fuel Type		Summer		Winter		Annual	Pk-Day	Annual		Summer		Winter		Annual	Pk-Day	Annual
	Total	Electric	Gas	Total	Electric Gas		kW		kW		kWh	therms	therms		kW		kW		kWh	therms	therms
Water Heating Temp. Reduct.	50	9	41	89	12 77 1 1	53,025	0.0		0.0		768 115	7.3	1,260	1,061	0.000		0.001		85 115	0.179	31 7
WH Wrap	0		0	0	0 0	0	0.0		0.0		0	0.0	0	0	-		-		-	-	- '
Pipe Insul.	49	9	40	49	9 40	980	0.0		0.0		396	0.3	114	20	0.000		0.000		44	0.01	3
LF Showerhead	0	0	0	0	0 0	0	0.0		0.0		0	0.0	0	0	-		-		-	-	-
Faucet Aerator Std-Eff Wtr Htr Repl.	0	0	0	0	0 0	0	0.0		0.0		0	0.0	0	0	-		-		-	-	-
Hi-Eff or Electric Wtr Htr Repl.	40	2	38	38	2 36	52,045	0.0		0.0		257	7.0	1,139	1,301	0.000		0.003		128	0.18	30
Lighting	37	37		295	295	2,065	1.0		1.9		9,926	-	-	56	0.028		0.052		268	-	-
Refrigerator/Freezer ³	9			8	8	7,274	0.5		0.5		4,147	-	-	808	0.057		0.053		461	-	-
Refrigerator Removal Refrigerator Exchange	9	0 9		0 8	0 8	7,274	0.0 0.5		0.0 0.5		0 4,147	-		0 808	0.057		0.053		- 461	-	-
Freezer Removal	0	0		0	0	0	0.0		0.0		4,147	-		0	-		-		-		
Freezer Exchange	0	0		0	0	0	0.0		0.0		0	-	-	0	-		-		-	-	-
Total Non-Efficiency Measures	60					52,659								878							
Misc Ins,Attic Access/Vent	26					2,171								84							
Duct Sealing	0					0								0							
Duct Insulation Damming Material	0					0								0							
Htg. Sys. Tune & Clean	13					1,460								112							
Htg. Sys./WH Other	0					0								0							
Air Conditioning Work	0					0								0							
Water Heater Repair Refrigerator Coil Clean	0					0								0							
Waterbed Mattress Pad	0					0								0							
Programmable Tstat	0					0								0							
Unspecified Utility Meas.	0					0								0							
CO Detector Smoke Detector	0					0								0							
Fuses	0					0								Ö							
Htg Sys Safety Check	0					0								0							
Htg Sys Ventilation	27					4,068								151							
Water Heater Ventilation Bathroom Ventilation	37 0					5,167 0								140							
Dryer Ventilation	0					0								0							
Kitchen Ventilation	0					0								0							
Other Exhaust Ventilation	0					0								0							
Asbestos Removal (Minor)	0 8					0 790								0 99							
Health/Safety Repairs Health/Safety Other	0					0								0							
Consumables	0					0								0							
General Repairs	39					7,026								180							
Meter Refrig (no action) Meter Freezer (no action)	0					0								0							
Support (no action)	60					31,977								533							
Transportation Allowance	0					0								0							
Landlord Contr Misc Landlord Contr Furnace	0					0								0							
Landlord Contr Furnace Landlord Contr DHW	0					0								0							
Client Contr (Any)	0					0								0							
Lead Safe Work Unspecifed/Other	0					0								0							
Onspecified/Officer						1 0	1														

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

² Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refligeration measure regiscements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Total Reported Labor, Materials and Utility Admin Expenditures: \$279,302

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$279,302

	Numbe	er of Dwe	llinas	Number	of Dwellings			ı	Billing A	Adjusted F	irst-Year S	avings		Averag			ted Firs Receivir			nd Savin	gs
		with Impac			ricity Impacts	Spending on		E	lectricity				Gas	Spending on	P		Electricit				ias
Measure	Total	Electric	Gas	Seas Cooling		Materials & Labor (\$)	Sum kW	mer kWh	kW	inter kWh	Annual kWh	Pk-Day therms	Annual therms	Materials & Labor (\$)	Sumi kW	ner kWh	Win kW	iter kWh	Annual kWh	Pk-Day therms	Annual therms
Total Efficiency Measures	42	39	35	39	39	223,417	11.6		11.6		35,587	67	6,288	5,319	0.298		0.296		912	1.92	180
Total Shell & Htg. Sys. Repl	41		35	35	36	179,637	11.1	13,394	10.6	15,308	28,702	62	5,340	4,381	0.317	383	0.294	425	797	1.77	153
Total Shell Measures	41		35	35	36	96,133	11.1	13,394	10.5	15,228	28,622	27	2,296	2,345	0.317	383	0.293	423	795	0.76	66
Wall Insul.	27		22	24	3	43,500	4.6	5,515	2.8	4,089	9,604	14	1,178	1,611	0.191	230	0.944	1,363	400	0.62	54
Open Blown Ceiling Insul. Cavity Fill Insul.	35 1	32 1	29 1	32 1	3 0	25,868 1.835	4.6 0.1	5,563 180	5.0 0.0	7,176 0	12,738 180	6	478 58	739 1,835	0.144	174 180	1.656	2,392	398 180	0.19 0.68	16 58
Sloped Attic Insul.	11		9	11	1	2,857	1.1	1,375	1.2	1,786	3,162	2	152	260	0.104	125	1.237	1,786	287	0.20	17
Kneewall Insul.	4	2	3	2	0	1,788	0.0	30	0.0	0	30	1	43	447	0.012	15	0.000	0	15	0.17	14
Infil. Reduction	41		35	20	3	12,783	0.3	419	0.3	428	848	3	251	312	0.017	21	0.099	143	42	0.08	7
Found./Crawl. Insul.	13		11	4	2	5,931	0.3	312	0.1	153	465	1	74	456	0.065	78	0.053	77	77	0.08	7
Bandjoist Insul.	12		9	-	3	1,570	0.0	0	0.3	385	385	1	68	131	0.000	0	0.089	128	128	0.09	8
Furnace Blower Fan ¹	38		35		33	0	0.0	0	8.0	1,211	1,211	(0)			0.000	0	0.025	37	37	(0.00)	(0)
Exhaust Ventilation Total Heating System Repl	0 26		0 25	0	0	83,504	0.0	0	0.0	0 81	0 81	0 35	3,044	0 3,212	0.000	- 0	0.056	- 81	- 81	1.41	122
Condensing Htg Sys Repl	25		25		'	80,004	0.0	0	0.1	0	0	35	3,044		0.000	-	0.036	- 01	- 01	1.41	122
Non-Cond Htg Sys Repl	0	0	0	-	-	0	0.0	0	0.0	Ő	0	0	0,011	0,200	-	-	-	-	-	-	-
Electric Htg Sys Repl	1	1	0	-	1	3,500	0.0	0	0.1	81	81	0	0	3,500	0.000	0	0.056	81	81	-	-
Heat Pump Repl	0		0	-	0	0	0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	-
Other Htg Sys Repl	0	0	0	-	0	0	0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	
				by	er of Measures Fuel Type		Summer		Winter		Annual	Pk-Day	Annual		Summer		Winter		Annual		Annual
Manager II and the second	Total	Electric	Gas		Electric Gas	10.701	kW		kW		kWh	therms	therms	4.400	kW		kW			therms	therms
Water Heating Temp. Reduct.	37 0	0	29	118	25 93 0 0		0.0		0.0		1,974	5.1 0.0	949	1,102	0.000		0.005		247	0.177	33
WH Wrap	0		0	0	0 0		0.0		0.0		0	0.0	0	0	-		-		-	_	_
Pipe Insul.	37		29	37	8 29		0.0		0.0		374	0.2	84	20	0.000		0.000		47	0.01	3
LF Showerhead	18	3	15	18	3 15	180	0.0		0.0		611	0.3	104	10	0.000		0.005		204	0.02	7
Faucet Aerator	26		20	38	9 29	190	0.0		0.0		320	0.1	39	7	0.000		0.001		53	0.01	2
Std-Eff Wtr Htr Repl. Hi-Eff or Electric Wtr Htr Repl.	0 29	0	0 23	0 25	0 0 5 20	0 39,661	0.0		0.0		0 669	0.0 4.4	0 721	1,368	0.000		0.003		111	0.19	31
Lighting	32		23	300	300	2,169	0.5		0.9		4,438	-	-	68	0.000		0.003		139	-	-
Refrigerator/Freezer ³	1	1		1	1	850	0.1		0.1		473	-	-	850	0.058		0.054		473	-	-
Refrigerator Removal	0	0		0	0	0	0.0		0.0		0	-	-	0	-		-		-	-	-
Refrigerator Exchange	1	1		1	1	850	0.1		0.1		473	-	-	850	0.058		0.054		473	-	-
Freezer Removal Freezer Exchange	0	0		0	0	0	0.0 0.0		0.0		0	-	-	0	-		-		-	-	-
Freezer Exchange	U	0		U	0	0	0.0		0.0		U	-		U						-	
Total Non-Efficiency Measures	42					55,884								1,331							
Misc Ins,Attic Access/Vent	29					4,802								166							
Duct Sealing	0					0								0							
Duct Insulation Damming Material	9					1,547 0								172 0							
Htg. Sys. Tune & Clean	10					1,250								125							
Htg. Sys./WH Other	0					0								0							
Air Conditioning Work	0					0								0							
Water Heater Repair	0					0								0							
Refrigerator Coil Clean Waterbed Mattress Pad	0					0								0							
Programmable Tstat	0					0								0							
Unspecified Utility Meas.	ő					ő								0							
CO Detector	0					0								0							
Smoke Detector Fuses	0					0								0							
Htg Sys Safety Check	0					0								0							
Htg Sys Ventilation	25					5,775								231							
Water Heater Ventilation	20					3,554								178							
Bathroom Ventilation	0					0								0							
Dryer Ventilation	0					0								0							
Kitchen Ventilation Other Exhaust Ventilation	0					0								0							
Asbestos Removal (Minor)	0					0								0							
Health/Safety Repairs	11					705								64							
Health/Safety Other	0					0								0							
Consumables	0				-	0								0							
General Repairs	41					12,608								308							
Meter Refrig (no action) Meter Freezer (no action)	0					0								0							
Support (no action)	36					25,643								712							
Transportation Allowance	0					0								0							
Landlord Contr Misc	0					0								0							
Landlord Contr Furnace	0					0								0							
Landlord Contr DHW Client Contr (Any)	0					0								0							
Lead Safe Work	0					0								0							
Unspecifed/Other	o o					ő	1							0							

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

² Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refligeration measure regiscements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$150,112

	Numba	er of Dwel	llingo	Number	of Dwellings				Billing A	Adjusted F	irst-Year S	avings		Avera	ge Billing		ted First Receivin			nd Savin	gs
	Numbe	vith Impac	iiings ts		ricity Impacts	Spending on			Electricity			1	Gas	Spending on	per Dw		Electricity		uies	(as
				Seas	on	Materials	Sum	mer	Wi	inter	Annual	Pk-Day	Annual	Materials	Sumn	ner	Wint	er .		Pk-Day	Annual
Measure	Total	Electric	Gas	Cooling	Heating	& Labor (\$)	kW	kWh	kW	kWh	kWh	therms	therms	& Labor (\$)	kW	kWh	kW	kWh	kWh	therms	therms
Total Efficiency Measures	40	37	24	37	37	134,962	8.5		15.3		52,966	39	3,779	3,374	0.230		0.413		1,432	1.64	157
Total Shell & Htg. Sys. Repl	37	34	23	29	34	104.384	5.6	6.702	11.0	16.773	23,475	38	3,447	2.821	0.192	231	0.323	493	690	1.64	150
Total Shell Measures	37	34	23	29	34	69,214	5.6	6,702	11.0	16,773	23,475	23	2,063	1,871	0.192	231	0.323	493	690	0.98	90
Wall Insul.	15	12	10	12	2	14,171	1.4	1,744	0.8	1,196	2,940	7	608	945	0.120	145	0.391	598	245	0.67	61
Open Blown Ceiling Insul.	28	26	15	26	8	28,963	3.1	3,707	7.4	11,330	15,037	7	595	1,034	0.118	143	0.926	1,416	578	0.43	40
Cavity Fill Insul.	4	3	4	3	0	3,758	0.2	256	0.0	0	256	3	258	940	0.071	85	0.000	0	85	0.71	65
Sloped Attic Insul.	5	4	5	4	0	2,820	0.3	371	0.0	0	371	3	249	564	0.077	93	0.000	0	93	0.55	50
Kneewall Insul.	3	2	2	2	0	1,140	0.1	165	0.0	0	165	1	81	380	0.068	82	0.000	0	82	0.44	40
Infil. Reduction	1	1	0	1	0	665	0.0	24	0.0	0	24	0	0	665	0.020	24	0.000	0	24	-	-
Found./Crawl. Insul.	11	7	6	5	5 5	11,766	0.4 0.0	437 0	0.9 0.9	1,432	1,868 1,375	1 2	130 148	1,070	0.072 0.000	87	0.187	286 275	267 275	0.24 0.16	22 15
Bandjoist Insul.	15	5	10	-		5,931				1,375				395		0	0.180				
Furnace Blower Fan ¹	28	25	23	-	25	0	0.0	0	0.9	1,440	1,440	(0)		0	0.000	0	0.038	58	58	(0.00)	(0)
Exhaust Ventilation	0	0	0	0	0	0	0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	
Total Heating System Repl	12	0	12	-	0	35,170	0.0	0	0.0	0	0	15	1,384	2,931	-	-	-	-	-	1.26	115
Condensing Htg Sys Repl	12 0	0	12	-	-	35,170 0	0.0 0.0	0	0.0	0	0	15 0	1,384 0	2,931	-	-	-	-	-	1.26	115
Non-Cond Htg Sys Repl	0		0	-	- 0	0	0.0	0	0.0	0	0	0		0		-	-	-		- 1	-
Electric Htg Sys Repl Heat Pump Repl	0		0		0	0	0.0	0	0.0	0	0	0		0		-	-		- [-
Other Htg Sys Repl	0	0	0		0	0	0.0	0	0.0	0	0	0	0	0		-	-	-	-	-	-
	1	<u> </u>			-	ľ	0.0		0.0			ľ	0	1							
					er of Measures																
				by	Fuel Type		Summer		Winter		Annual	Pk-Day	Annual		Summer		Winter		Annual		Annual
Metavillandina	Total	Electric	Gas		Electric Gas	40.440	kW		kW		kWh	therms	therms	470	kW		kW			therms	therms
Water Heating Temp. Reduct.	35	16 0	19	74	33 42 0 0		0.0		0.1		3,300	1.6 0.0	332	470			0.004		206	0.085	17
WH Wrap	0	0	0	0	0 0		0.0		0.0		0	0.0	0	0	-		-		-	-	-
Pine Insul	33	15	18	33	15 18		0.0		0.0		748	0.0	53	19	0.000		0.000		50	0.01	- 3
LF Showerhead	22	10	12	31	14 17	303	0.0		0.0		2,009	0.3	85	14			0.005		201	0.02	7
Faucet Aerator	1	0	1	1	0 1	5	0.0		0.0		0	0.0		5	-		-		-	0.00	1
Std-Eff Wtr Htr Repl.	0	0	0	0	0 0	0	0.0		0.0		0	0.0	0	0	-		-		-	-	-
Hi-Eff or Electric Wtr Htr Repl.	12	5	7	9	4 6	15,500	0.0		0.0		544	1.2	193	1,292	0.000		0.003		109	0.17	28
Lighting	35	35		480	480	3,399	1.7		3.1		15,749	-	-	97	0.047		0.087		450	-	-
Refrigerator/Freezer ³	17	17		19	19	10,731	1.3		1.2		10,442	-	-	631	0.076		0.071		614	-	-
Refrigerator Removal	0	0		0	0	0	0.0		0.0		0	-	-	0	-		-		-	-	-
Refrigerator Exchange	12			13	13	8,322	0.8		0.8		6,904	-	-	694	0.071		0.066		575	-	-
Freezer Removal	0	0		0	0	0	0.0		0.0		0	-	-	0	-		-			-	-
Freezer Exchange	6	6		6	6	2,409	0.4		0.4		3,538	-		402	0.073		0.068		590	-	
Total Non-Efficiency Measures	37					15,150								409							
Misc Ins,Attic Access/Vent	1					500								500							
Duct Sealing	0					0								0							
Duct Insulation	0					0								0							
Damming Material	0					0								0							
Htg. Sys. Tune & Clean	0					0								0							
Htg. Sys./WH Other	0					0								0							
Air Conditioning Work	0					0								0							
Water Heater Repair	0					0								0							
Refrigerator Coil Clean Waterbed Mattress Pad	0					0								0							
Programmable Tstat	1					100								100							
Unspecified Utility Meas.	ò					0								0							
CO Detector	0					0								0							
Smoke Detector	0					0								0							
Fuses	0					0								0							
Htg Sys Safety Check	0					0								0							
Htg Sys Ventilation	6					940								157							
Water Heater Ventilation	4					660								165							
Bathroom Ventilation	0					0								0							
Dryer Ventilation Kitchen Ventilation	0					0								0							
Other Exhaust Ventilation	0					0								0							
Asbestos Removal (Minor)	0					0								0							
Health/Safety Repairs	12					15,500								1,292							
Health/Safety Other	0					0								0							
Consumables	0					0								0							
General Repairs	1					360								360							
Meter Refrig (no action)	19					0								0	1						
Meter Freezer (no action)	8					0	<u> </u>							0							
Support	32					12,590								393							
Transportation Allowance	0					0								0							
Landlord Contr Misc	0					0								0							
Landlord Contr Furnace	0					0								0							
Landlord Contr DHW	0					0								0							
Client Contr (Any) Lead Safe Work	0					0								0	1						
Unspecifed/Other	0					0								0							
poonourourol						U									1						

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

² Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

The total number of aveilings may exceed the number of neasures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

Utility Administration Expenditures:

Total Labor and Material Expenditures: \$630,919

	Numbe	er of Dwe	llinge	Number	of Dwellings				Billing A	djusted F	irst-Year S	avings		Averaç	ge Billing		ted First			nd Savin	gs
		with Impac		with Elec	ricity Impacts	Spending on			Electricity				Gas	Spending on	· ·	·	Electricity	ĭ			ias
Measure	Total	Electric	Gas	Sease Cooling		Materials & Labor (\$)	Sum kW	mer kWh	Wi kW	nter kWh	Annual kWh	Pk-Day therms	Annual therms	Materials & Labor (\$)	Sumn kW	ner kWh	Wint kW	er kWh	Annual kWh	Pk-Day therms	Annual therms
						,,,															
Total Efficiency Measures	103	103	91	97	103	527,948	22.5		22.7		79,324	224	21,161	5,126	0.232		0.220		770	2.47	233
Total Shell & Htg. Sys. Repl	99	99		77	98	419,177	19.5	23,518	18.9	28,393	51,911	212	18,878	4,234	0.253	305	0.193	290	524	2.33	207
Total Shell Measures Wall Insul.	99 63	99 52		77 52	98	319,470 126,592	19.5 8.2	23,518 9,876	18.9	28,393 527	51,911 10,403	149	13,295 3,912	3,227	0.253	305 190	0.193	290 527	524 200	1.64 0.74	146
Open Blown Ceiling Insul.	81	52 71		71	5	77,128	7.6	9,876	8.8	13,236	22,456	61	5,498	2,009 952	0.157	130	1.753	2,647	316	0.74	65 74
Cavity Fill Insul.	60	49		49	2	41,015	1.8	2,193	0.0	72	2,265	18	1,598	684	0.037	45	0.024	36	46	0.32	29
Sloped Attic Insul.	20	17	19	17	0	8,783	0.7	787	0.0	0	787	5	475	439	0.038	46	0.000	0	46	0.29	25
Kneewall Insul.	37	30		30	1	11,812	0.7	798	0.5	726	1,524	6	500	319	0.022	27	0.495	726	51	0.16	14
Infil. Reduction Found /Crawl. Insul.	1 45	1 8	1 44	1 8	0	15 52,073	0.0	643	0.0	0 1,273	1,916	0 14	0 1,277	15 1,157	0.001	1 80	0.000 0.815	0 1.273	1 240	0.00	0 29
Bandjoist Insul.	11	1		- "	i	2,053	0.0	043	0.0	250	250	1	83	187	0.000	0	0.013	250	250	0.09	8
Furnace Blower Fan ¹	92	92		-	92	0	0.0	0	8.3	12,308	12,308	(1)		0	0.000	0	0.090	134	134	(0.01)	(1)
Exhaust Ventilatiorf	0	0		0	0	0	0.0	0	0.0	0	0	O O	0	0	-	_	-	_		-	- '
Total Heating System Repl	52	0		-	0	99,707	0.0	0	0.0	0	0	63	5,583	1,917	-	-	-	-	-	1.21	107
Condensing Htg Sys Repl	52	0		-	-	99,707	0.0	0	0.0	0	0	63	5,583	1,917	-	-	-	-	-	1.21	107
Non-Cond Htg Sys Repl	0			-	-	0	0.0	0	0.0	0	0	0	0	0	-	-	-	-		-	-
Electric Htg Sys Repl Heat Pump Repl	0	0	0		0	0	0.0 0.0	0	0.0 0.0	0	0	0	0	0	-					-	
Other Htg Sys Repl	0	0	0	-	0	ő	0.0	0	0.0	0	0	0	0	0	-	-	-	-	-	-	-
					er of Measures Fuel Type		Summer		Winter		Annual	Pk-Day	Annual		Summer		Winter		Annual	Pk-Day	Annual
	Total	Electric		Total	Electric Gas		kW		kW		kWh	therms	therms		kW		kW		kWh	therms	therms
Water Heating	86	11	75		29 256		0.0		0.0		1,773	12.5	2,283	1,028	0.000		0.002		161	0.166	30
Temp. Reduct. WH Wrap	0	0		0	0 0	0	0.0		0.0		0	0.0	0	0	-		-			-	-
Pipe Insul.	84	10		84	10 74	1,415	0.0		0.0		481	0.6	212	17	0.000		0.000		48	0.01	3
LF Showerhead	21	2	19	25	3 22	230	0.0		0.0		393	0.5	140	11	0.000		0.002		197	0.02	7
Faucet Aerator	67	8	59	121	13 108		0.0		0.0		476	0.5	149	9	0.000		0.001		59	0.01	3
Std-Eff Wtr Htr Repl. Hi-Eff or Electric Wtr Htr Repl.	0 59	0	0 56	0 54	0 0 3 52	0 86,170	0.0		0.0		0 423	0.0 10.9	0 1,782	0 1,461	0.000		0.003		- 141	0.20	32
Lighting	70	70		655	655	4,515	1.1		2.0		10,432	-	- 1,702	65			0.003		149	-	-
Refrigerator/Freezer ³	26	26		29	29	15,867	1.9		1.7		15,209	-	-	610	0.072		0.067		585	-	-
Refrigerator Removal	0	0		0	0	0	0.0		0.0		0	-	-	0						-	-
Refrigerator Exchange Freezer Removal	26 0	26 0		29 0	29 0	15,867 0	1.9 0.0		1.7 0.0		15,209 0	-	-	610	0.072		0.067		585	-	-
Freezer Exchange	0	0		0	0	0	0.0		0.0		0			0	-						
	100					100.070								4 040							
Total Non-Efficiency Measures Misc Ins,Attic Access/Vent	102					102,972								1,010							
Duct Sealing	0					0								0							
Duct Insulation	0					0								0							
Damming Material	0					0								0							
Htg. Sys. Tune & Clean Htg. Sys./WH Other	26 0					3,305 0								127							
Air Conditioning Work	0					0								0							
Water Heater Repair	0					0								0							
Refrigerator Coil Clean	0					0								0							
Waterbed Mattress Pad Programmable Tstat	0					0								0							
Unspecified Utility Meas.	0					0								0							
CO Detector	0					0								0							
Smoke Detector Fuses	1 0					80								80							
Htg Sys Safety Check	0					0								0							
Htg Sys Ventilation	50					8,657								173							
Water Heater Ventilation	52					8,845								170							
Bathroom Ventilation	0					0								0							
Dryer Ventilation Kitchen Ventilation	0					0								0							
Other Exhaust Ventilation	0					0								0							
Asbestos Removal (Minor)	0					0								0							
Health/Safety Repairs	59					86,170								1,461							
Health/Safety Other Consumables	0					0								0							
General Repairs	0					ő								o o							
Meter Refrig (no action)	0					0								0							
Meter Freezer (no action) Support	102					81,965								0 804							
Support Transportation Allowance	102					81,965								804 n							
Landlord Contr Misc	0					0								0							
Landlord Contr Furnace	0					0								0							
Landlord Contr DHW	0					0								0							
Client Contr (Any) Lead Safe Work	0					120								120							
Unspecifed/Other	Ö					0								0							

¹ Estimates are based upon reduced usage of the furnace due to shell improvements

² Impacts from continuous exhaust fans required by ASHRAE 62.2. The winter impacts exceed summer because these also include heating season impacts for dwellings with electric heat.

The total number of dwellings may exceed the number of measures installed in cases where the utility partially funds refrigeration measure replacements. The percentage of expenditures for each appliance is totaled to get the total number of measures installed.

This page intentionally left blank

APPENDIX A -- CLIENT CHARACTERISTICS

	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017
Household characteristics										
Quarterly gross income	\$4,002	\$4,190	\$4,130	\$4,344	\$4,355	\$4,286	\$4,406	\$4,600	\$6,691	\$9,414
Average members	2.8	2.8	2.9	2.9	2.8	2.7	2.7	2.7	2.7	2.7
Percentage of households with:										
Elderly	31.5	34.2	24.0	29.1	29.4	30.8	28.9	31.3	34.4	35.5
Handicapped	42.7	35.7	25.4	32.9	30.1	32.6	31.3	30.6	34.1	33.4
Young children	21.5	21.5	18.6	25.2	21.9	20.1	22.4	19.4	17.4	20.7
Housing type (%)										
Single family home	87.7	87.9	82.6	89.6	87.3	84.8	87.4	88.4	88.1	89.1
Mobile home	7.5	9.9	7.6	10.0	10.2	11.9	10.6	8.6	7.9	7.2
Duplex	0.1	0.3	0.3	0.1	0.7	3.2	1.9	2.8	3.9	3.6
Three+ unit apartment	1.3	1.0	6.8	0.3	1.8	0.1	0.1	0.2	0.1	0.2
Rent a room	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Unknown/other	3.5	1.0	2.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Heating system type (%)										
Natural gas	85.8	85.6	82.7	81.0	80.8	80.3	84.2	86.7	85.4	84.1
Propane	10.1	9.3	11.9	12.9	13.3	12.3	9.2	8.1	8.6	8.3
Fuel oil	0.7	0.3	0.8	0.8	0.8	0.9	0.2	0.1	0.5	1.1
Electricity	3.3	4.7	4.5	5.4	5.1	6.4	6.4	5.2	5.5	6.4
Other	0.1	0.1	0.0	0.0	0.0	0.2	0.0	0.0	0.0	0.2
Air conditioning type (%)										
Central	52.5	55.3	54.1	58.7	57.3	60.2	63.6	62.0	62.6	64.9
Room	34.6	32.5	31.4	27.8	30.4	29.4	26.3	29.5	28.0	27.3
None or Missing Data	12.8	12.2	14.5	13.6	12.3	10.4	10.1	8.5	9.4	7.8
Blower door readings (average o	fm50)									
Pre	3,608	3,374	3,281	3,294	3,454	3,281	3,437	3,429	3,420	3,447
Post	2,215	2,120	2,040	2,054	2,139	2,053	2,100	2,148	2,565	2,160

This page intentionally left blank

APPENDIX B -FIGURE DATA

Fig. 1. 4 4 Fig. 1 V. 1 F. 1	(11) . 5									
Figure 1.1 First Year Energy Savii	ngs (therms) – P 2008	rogram 2009	2010	2011	2012	2013	2014	2015	2016	2017
Heating System Work	2008 114,444	2009 173,277	286,866	286,414	192,441	102,711	116,295	113,515	107,412	89,404
Infiltration Reduction	26,915	37,383	54,194	59,030	35,991	24,403	24,864	22,482	20,948	16,743
Insulation	225,799	307,272	480,401	494,564	333,793	197,200	197,846	184,203	148,756	123,312
Light/Water Heat/Other Utilit	7,229	11,235	17,070	16,057	9,698	7,726	6,002	6,062	4,403	3,874
Water Heater Replacement	17,880	22,830	44,509	54,904	32,819	25,296	28,290	33,942	29,679	23,656
Whole House Ventilation	17,000	22,030	44,303	34,304	32,013	23,230	20,230	-2,392	-4,936	-4,269
vinole riouse ventilution								2,332	4,550	4,203
Figure 1.2 First Year Energy Savii	ngs (kWh) – Pro	gram								
	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017
Heating System Work	2,159	3,693	6,770	8,324	4,975	3,937	186,516	201,190	185,546	159,209
Infiltration Reduction	53,435	81,711	146,544	150,295	59,937	39,935	46,035	32,037	41,401	42,306
Insulation	690,330	1,101,156	1,779,971	1,811,722	759,702	466,832	466,307	358,537	446,239	470,351
Light/Water Heat/Other Utilit	1,195,736	1,799,651	2,589,000	2,734,566	947,748	596,538	567,195	572,018	371,009	369,048
Water Heater Replacement	9,621	9,359	15,535	19,171	7,824	12,343	14,023	15,089	17,269	15,857
Whole House Ventilation								-24,538	-59,517	-70,405
Figure 1.3 Overall Program Expe			2242		2212	2212		2015		
	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017
Heating System Work	2,575,473	3,699,209	6,943,168	8,182,168	5,189,193	3,123,974	3,465,461	3,376,066	3,390,913	2,747,745
Infiltration Reduction	725,427	1,139,440	2,142,574	2,357,653	1,476,133	1,002,359	1,041,087	1,005,719	1,182,412	1,045,485
Insulation	3,848,467	6,258,426	10,920,427	12,616,772	7,584,763	4,317,731	4,509,492	4,279,518	4,188,388	3,440,858
Light/Water Heat/Other Utilit	611,081	838,645	1,198,884	1,233,806	720,138	424,488	356,538	327,532	328,738	241,252
Other	771,670	1,416,454	3,151,309	2,584,355	1,988,982	1,752,150	1,700,878	2,151,835	1,982,511	1,558,300
Repair	930,825	1,476,901	2,348,113	2,405,336	1,491,583	1,039,839	971,976	785,187	930,041	828,300
Support	3,550,464	5,626,121	9,459,046	8,932,316	5,818,840	4,656,124	4,864,035	4,756,716	5,302,237	4,570,198
Water Heater Replacement	521,733	777,795	1,673,951	2,426,666	1,527,656	1,034,375	1,316,775	1,562,901	1,579,574	1,289,234
Whole House Ventilation				687,151	648,556	367,224	488,871	368,924	1,018,951	898,996
Figure 1.4 Average Program Exp	anditures per H	oucing Unit								
rigure 1.4 Average Frogram Exp	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017
Heating System Work	1,400	1,370	1,640	1,800	1,750	1,690	2,080	2,230	2,302	2,189
Infiltration Reduction	390	420	480	520	500	540	620	660	803	833
Insulation	2,090	2,320	2,420	2,780	2,550	2,330	2,710	2,830	2,843	2,742
Light/Water Heat/Other Ut	400	310	270	270	240	230	210	220	223	192
Other	350	520	600	690	670					
Repair	500					950			1 346	
Support		550				950 560	1,020 580	1,420 520	1,346 631	1,242 660
		550 2.080	520	530	500	560	580	520	631	660
• •	1,920	2,080	520 2,100	530 1,970	500 1,960	560 2,520	580 2,920	520 3,140	631 3,600	660 3,642
Water Heater Repl			520	530 1,970 540	500 1,960 510	560 2,520 560	580 2,920 790	520 3,140 1,030	631 3,600 1,072	660 3,642 1,027
• •	1,920 280	2,080 290	520 2,100 370	530 1,970 540 150	500 1,960 510 220	560 2,520 560 200	580 2,920 790 290	520 3,140 1,030 240	631 3,600 1,072 692	660 3,642 1,027 716
Water Heater Repl	1,920	2,080	520 2,100	530 1,970 540	500 1,960 510	560 2,520 560	580 2,920 790	520 3,140 1,030	631 3,600 1,072	660 3,642 1,027
Water Heater Repl	1,920 280 7,336	2,080 290 7,864	520 2,100 370	530 1,970 540 150	500 1,960 510 220	560 2,520 560 200	580 2,920 790 290	520 3,140 1,030 240	631 3,600 1,072 692	660 3,642 1,027 716
Water Heater Repl Whole House Ventilation	1,920 280 7,336	2,080 290 7,864	520 2,100 370	530 1,970 540 150	500 1,960 510 220	560 2,520 560 200	580 2,920 790 290	520 3,140 1,030 240	631 3,600 1,072 692	660 3,642 1,027 716
Water Heater Repl Whole House Ventilation	1,920 280 7,336 Cost Savings (No	2,080 290 7,864 minal Dollars)	520 2,100 370 8,392	530 1,970 540 150 9,258	500 1,960 510 220 8,901	560 2,520 560 200 9,577	580 2,920 790 290 11,227	520 3,140 1,030 240 12,295	631 3,600 1,072 692 13,512	660 3,642 1,027 716 13,255
Water Heater Repl Whole House Ventilation Figure 1.6 First Year Client Fuel C	1,920 280 7,336 Cost Savings (No	2,080 290 7,864 minal Dollars)	520 2,100 370 8,392	530 1,970 540 150 9,258	500 1,960 510 220 8,901	560 2,520 560 200 9,577	580 2,920 790 290 11,227	520 3,140 1,030 240 12,295	631 3,600 1,072 692 13,512	660 3,642 1,027 716 13,255
Water Heater Repl Whole House Ventilation Figure 1.6 First Year Client Fuel C Whole House Ventilation	1,920 280 7,336 Cost Savings (No 2008	2,080 290 7,864 (minal Dollars) 2009	520 2,100 370 8,392	530 1,970 540 150 9,258	500 1,960 510 220 8,901	560 2,520 560 200 9,577	580 2,920 790 290 11,227	520 3,140 1,030 240 12,295 2015 -5,593	631 3,600 1,072 692 13,512 2016 -12,094	660 3,642 1,027 716 13,255 2017 -13,169
Water Heater Repl Whole House Ventilation Figure 1.6 First Year Client Fuel C Whole House Ventilation Heating System Work	1,920 280 7,336 Cost Savings (No 2008 162,531	2,080 290 7,864 (minal Dollars) 2009	520 2,100 370 8,392 2010 347,960	530 1,970 540 150 9,258 2011	500 1,960 510 220 8,901 2012	560 2,520 560 200 9,577 2013	580 2,920 790 290 11,227 2014	520 3,140 1,030 240 12,295 2015 -5,593 123,290	631 3,600 1,072 692 13,512 2016 -12,094 114,855	660 3,642 1,027 716 13,255 2017 -13,169 107,911
Water Heater Repl Whole House Ventilation Figure 1.6 First Year Client Fuel C Whole House Ventilation Heating System Work Infiltration Reduction	1,920 280 7,336 Cost Savings (No 2008 162,531 42,514	2,080 290 7,864 minal Dollars) 2009 194,435 50,567	520 2,100 370 8,392 2010 347,960 79,880	530 1,970 540 150 9,258 2011 371,197 84,236	500 1,960 510 220 8,901 2012 227,712 43,906	560 2,520 560 200 9,577 2013 121,871 29,920	580 2,920 790 290 11,227 2014 129,924 28,584	520 3,140 1,030 240 12,295 2015 -5,593 123,290 23,482	631 3,600 1,072 692 13,512 2016 -12,094 114,855 23,425	660 3,642 1,027 716 13,255 2017 -13,169 107,911 21,220
Water Heater Repl Whole House Ventilation Figure 1.6 First Year Client Fuel C Whole House Ventilation Heating System Work Infiltration Reduction Insulation	1,920 280 7,336 Cost Savings (No 2008 162,531 42,514 372,028	2,080 290 7,864 minal Dollars) 2009 194,435 50,567 438,803	520 2,100 370 8,392 2010 347,960 79,880 731,293	530 1,970 540 150 9,258 2011 371,197 84,236 759,964	500 1,960 510 220 8,901 2012 227,712 43,906 424,194	560 2,520 560 200 9,577 2013 121,871 29,920 256,624	580 2,920 790 290 11,227 2014 129,924 28,584 234,798	520 3,140 1,030 240 12,295 2015 -5,593 123,290 23,482 199,673	631 3,600 1,072 692 13,512 2016 -12,094 114,855 23,425 183,128	660 3,642 1,027 716 13,255 2017 -13,169 107,911 21,220 174,531
Water Heater Repl Whole House Ventilation Figure 1.6 First Year Client Fuel C Whole House Ventilation Heating System Work Infiltration Reduction Insulation Light/Water Heat/Other Ut	1,920 280 7,336 Cost Savings (No 2008 162,531 42,514 372,028 110,391	2,080 290 7,864 minal Dollars) 2009 194,435 50,567 438,803 164,826	520 2,100 370 8,392 2010 347,960 79,880 731,293 264,515	530 1,970 540 150 9,258 2011 371,197 84,236 759,964 280,880	500 1,960 510 220 8,901 2012 227,712 43,906 424,194 103,539	560 2,520 560 200 9,577 2013 121,871 29,920 256,624 66,702	580 2,920 790 290 11,227 2014 129,924 28,584 234,798 63,990	520 3,140 1,030 240 12,295 2015 -5,593 123,290 23,482 199,673 67,400	631 3,600 1,072 692 13,512 2016 -12,094 114,855 23,425 183,128 45,384	660 3,642 1,027 716 13,255 2017 -13,169 107,911 21,220 174,531 46,038
Water Heater Repl Whole House Ventilation Figure 1.6 First Year Client Fuel C Whole House Ventilation Heating System Work Infiltration Reduction Insulation Light/Water Heat/Other Ut	1,920 280 7,336 Cost Savings (No 2008 162,531 42,514 372,028 110,391 28,086	2,080 290 7,864 minal Dollars) 2009 194,435 50,567 438,803 164,826 26,646	520 2,100 370 8,392 2010 347,960 79,880 731,293 264,515 49,095	530 1,970 540 150 9,258 2011 371,197 84,236 759,964 280,880 63,944	500 1,960 510 220 8,901 2012 227,712 43,906 424,194 103,539 37,826	560 2,520 560 200 9,577 2013 121,871 29,920 256,624 66,702 29,556	580 2,920 790 290 11,227 2014 129,924 28,584 234,798 63,990 31,404	520 3,140 1,030 240 12,295 2015 -5,593 123,290 23,482 199,673 67,400 35,593	631 3,600 1,072 692 13,512 2016 -12,094 114,855 23,425 183,128 45,384 31,142	660 3,642 1,027 716 13,255 2017 -13,169 107,911 21,220 174,531 46,038 27,027
Water Heater Repl Whole House Ventilation Figure 1.6 First Year Client Fuel C Whole House Ventilation Heating System Work Infiltration Reduction Insulation Light/Water Heat/Other Ut Water Heater Replacement Figure 1.8 First Year Energy Savin	1,920 280 7,336 Cost Savings (No 2008 162,531 42,514 372,028 110,391 28,086 ngs (therms) – U	2,080 290 7,864 minal Dollars) 2009 194,435 50,567 438,803 164,826 26,646 Utility only 2009	520 2,100 370 8,392 2010 347,960 79,880 731,293 264,515 49,095	530 1,970 540 150 9,258 2011 371,197 84,236 759,964 280,880 63,944	500 1,960 510 220 8,901 2012 227,712 43,906 424,194 103,539 37,826	560 2,520 560 200 9,577 2013 121,871 29,920 256,624 66,702 29,556	580 2,920 790 290 11,227 2014 129,924 28,584 234,798 63,990 31,404	520 3,140 1,030 240 12,295 2015 -5,593 123,290 23,482 199,673 67,400 35,593	631 3,600 1,072 692 13,512 2016 -12,094 114,855 23,425 183,128 45,384 31,142	660 3,642 1,027 716 13,255 2017 -13,169 107,911 21,220 174,531 46,038 27,027
Water Heater Repl Whole House Ventilation Figure 1.6 First Year Client Fuel C Whole House Ventilation Heating System Work Infiltration Reduction Insulation Light/Water Heat/Other Ut Water Heater Replacement Figure 1.8 First Year Energy Savial Heating System Work	1,920 280 7,336 Cost Savings (No 2008 162,531 42,514 372,028 110,391 28,086	2,080 290 7,864 minal Dollars) 2009 194,435 50,567 438,803 164,826 26,646 Utility only 2009 67,873	520 2,100 370 8,392 2010 347,960 79,880 731,293 264,515 49,095	530 1,970 540 150 9,258 2011 371,197 84,236 759,964 280,880 63,944 2011 111,218	500 1,960 510 220 8,901 2012 227,712 43,906 424,194 103,539 37,826	560 2,520 560 200 9,577 2013 121,871 29,920 256,624 66,702 29,556	580 2,920 790 290 11,227 2014 129,924 28,584 234,798 63,990 31,404	520 3,140 1,030 240 12,295 2015 -5,593 123,290 23,482 199,673 67,400 35,593 2015 67,323	631 3,600 1,072 692 13,512 2016 -12,094 114,855 23,425 183,128 45,384 31,142 2016 69,667	660 3,642 1,027 716 13,255 2017 -13,169 107,911 21,220 174,531 46,038 27,027
Water Heater Repl Whole House Ventilation Figure 1.6 First Year Client Fuel C Whole House Ventilation Heating System Work Infiltration Reduction Insulation Light/Water Heat/Other Ut Water Heater Replacement Figure 1.8 First Year Energy Savii Heating System Work Infiltration Reduction	1,920 280 7,336 Cost Savings (No 2008 162,531 42,514 372,028 110,391 28,086 ngs (therms) – U 2008 68,807	2,080 290 7,864 minal Dollars) 2009 194,435 50,567 438,803 164,826 26,646 Utility only 2009 67,873 3,350	520 2,100 370 8,392 2010 347,960 79,880 731,293 264,515 49,095 2010 77,401 4,425	530 1,970 540 150 9,258 2011 371,197 84,236 759,964 280,880 63,944 2011 111,218 10,340	500 1,960 510 220 8,901 2012 227,712 43,906 424,194 103,539 37,826 2012 67,910 5,358	560 2,520 560 200 9,577 2013 121,871 29,920 256,624 66,702 29,556 2013 60,813 5,129	580 2,920 790 290 11,227 2014 129,924 28,584 234,798 63,990 31,404 2014 70,795 5,467	520 3,140 1,030 240 12,295 2015 -5,593 123,290 23,482 199,673 67,400 35,593 2015 67,323 4,923	631 3,600 1,072 692 13,512 2016 -12,094 114,855 23,425 183,128 45,384 31,142 2016 69,667 4,784	660 3,642 1,027 716 13,255 2017 -13,169 107,911 21,220 174,531 46,038 27,027 2017 58,964 5,275
Water Heater Repl Whole House Ventilation Figure 1.6 First Year Client Fuel C Whole House Ventilation Heating System Work Infiltration Reduction Insulation Light/Water Heat/Other Ut Water Heater Replacement Figure 1.8 First Year Energy Savin Heating System Work Infiltration Reduction Insulation	1,920 280 7,336 Cost Savings (No 2008 162,531 42,514 372,028 110,391 28,086 ngs (therms) – U 2008 68,807	2,080 290 7,864 minal Dollars) 2009 194,435 50,567 438,803 164,826 26,646 Utility only 2009 67,873 3,350 147,574	520 2,100 370 8,392 2010 347,960 79,880 731,293 264,515 49,095 2010 77,401 4,425 123,140	530 1,970 540 150 9,258 2011 371,197 84,236 759,964 280,880 63,944 2011 111,218 10,340 207,156	500 1,960 510 220 8,901 2012 227,712 43,906 424,194 103,539 37,826 2012 67,910 5,358 131,917	560 2,520 560 200 9,577 2013 121,871 29,920 256,624 66,702 29,556 2013 60,813 5,129 131,486	580 2,920 790 290 11,227 2014 129,924 28,584 234,798 63,990 31,404 2014 70,795 5,467 132,525	520 3,140 1,030 240 12,295 2015 -5,593 123,290 23,482 199,673 67,400 35,593 2015 67,323 4,923 119,370	631 3,600 1,072 692 13,512 2016 -12,094 114,855 23,425 183,128 45,384 31,142 2016 69,667 4,784 102,315	660 3,642 1,027 716 13,255 2017 -13,169 107,911 21,220 174,531 46,038 27,027 2017 58,964 5,275 93,879
Water Heater Repl Whole House Ventilation Figure 1.6 First Year Client Fuel C Whole House Ventilation Heating System Work Infiltration Reduction Insulation Light/Water Heat/Other Ut Water Heater Replacement Figure 1.8 First Year Energy Savii Heating System Work Infiltration Reduction	1,920 280 7,336 Cost Savings (No 2008 162,531 42,514 372,028 110,391 28,086 ngs (therms) – U 2008 68,807	2,080 290 7,864 minal Dollars) 2009 194,435 50,567 438,803 164,826 26,646 Utility only 2009 67,873 3,350	520 2,100 370 8,392 2010 347,960 79,880 731,293 264,515 49,095 2010 77,401 4,425	530 1,970 540 150 9,258 2011 371,197 84,236 759,964 280,880 63,944 2011 111,218 10,340	500 1,960 510 220 8,901 2012 227,712 43,906 424,194 103,539 37,826 2012 67,910 5,358	560 2,520 560 200 9,577 2013 121,871 29,920 256,624 66,702 29,556 2013 60,813 5,129	580 2,920 790 290 11,227 2014 129,924 28,584 234,798 63,990 31,404 2014 70,795 5,467	520 3,140 1,030 240 12,295 2015 -5,593 123,290 23,482 199,673 67,400 35,593 2015 67,323 4,923	631 3,600 1,072 692 13,512 2016 -12,094 114,855 23,425 183,128 45,384 31,142 2016 69,667 4,784	660 3,642 1,027 716 13,255 2017 -13,169 107,911 21,220 174,531 46,038 27,027 2017 58,964 5,275

Figure 1.9 First Year Energy Savi	ngs (kWh) – Util	itv onlv								
0	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017
Heating System Work		832	536	3,286	417	224	64,339	66,083	71,506	66,476
Infiltration Reduction	13	7,456	11,035	18,659	7,535	6,267	9,268	8,069	8,430	12,372
Insulation	465,814	491,564	497,304	613,470	264,752	237,590	282,915	212,946	283,722	321,895
Light/Water Heat/Other Utilit	720,681	705,236	704,991	922,461	347,294	336,976	344,858	350,640	218,339	251,166
Water Heater Replacement	3,727	5,779	8,485	11,516	4,774	3,587	5,753	6,780	9,119	9,580
Figure 1.10 Utility Expenditures										
	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017
Heating System Work	1,099,188	1,052,918	1,207,970	2,082,247	1,176,515	1,200,207	1,557,590	1,520,693	1,594,196	1,379,543
Infiltration Reduction	29	72,138	142,164	288,225	173,869	172,746	198,737	204,838	212,265	273,962
Insulation	2,238,735	2,417,435	2,285,914	3,753,358	2,295,748	2,306,634	2,528,094	2,353,124	2,422,997	2,190,461
Light/Water Heat/Other Utilit	327,658	291,378	296,528	375,480	249,184	227,782	200,560	188,571	180,770	160,696
Other	63,409	51,664	60,862	128,109	72,842	62,892	107,646	124,082	147,766	176,289
Repair	170,974	163,350	104,189	157,260	96,832	104,157	129,832	121,538	123,880	168,145
Support	463,990	495,431	458,520	706,131	420,502	466,296	564,572	523,448	602,760	585,371
Water Heater Replacement	161 764	103 004	272 140	702 707	111 525	181 837	507 828	762 163	8/19 8/19	215 113